

2011 Consumer Confidence Report

MORO MUTUAL WATER COMPANY

Report Date: February 27, 2012

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2010.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Moro Road Water System #9 System #: 270-1926

Type of water source in use: Wells

Name & Location of wells:

#1 - north side of Fallenleaf - collapsed August 2011

#2 -south side of Fallenleaf

#3 -on tank/well easement site at 7610 Fallenleaf Lane

#4 - north side of Fallenleaf - drilled 2011

Drinking Water Source Assessment Information: Completed by Monterey County November 2011 on wells #1, #2, and #3. Copies are available from Debbie Stowe at the number listed below.

Vulnerability: septic systems - high density.

Annual Water meeting will be held Wednesday April 11, 2012 at 7pm at Prunedale Library

For more information contact Debbie Stowe at 663-2871

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

Environmental Protection Agency.

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

| Microbiological Contaminants (to be completed only if there was a detection of bacteria) | Highest No. of detections | No. of months in violation | MCL | MCLG | Typical Source of Bacteria |
|---|---------------------------|----------------------------|--|------|--------------------------------------|
| Total Coliform Bacteria **** | (In a mo.) 1 | 2 | More than 1 sample in a month with a detection | 0 | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> | 0 | 0 | A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i> | 0 | Human and animal fecal waste |

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

| Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set) | No. of samples collected | 90 th percentile level detected | No. Sites exceeding AL | AL | PHG | Typical Source of Contaminant |
|---|--------------------------|--|------------------------|----|-----|--|
| Lead (ppb) test 2011 next testing July 2011 | 5 | 0.0025 | 0 | 15 | 2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits. |

| Copper (ppm) test 2011 next testing July 2012 | 5 | 0.9970 | 0 | 1.3 | .17 | Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives. |
|---|-------------|----------------|---------------------|------|------------|--|
| TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | |
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
| Sodium (ppm) | 4/1/2010 | 56/49/41 | | none | none | Generally found in ground and surface water |
| Hardness (ppm) | 4/1/2010 | 167/109/96.9 | | none | none | Generally found in ground and surface water |

*Any violation of an MCL or AL is marked with an asterisk. Additional information regarding the violation is provided later in this report.

| TABLE 4 - DETECTION OF CONTAMINANTS WITH A <u>PRIMARY</u> DRINKING WATER STANDARD | | | | | | |
|---|--------------------|----------------|---------------------|-----------------------|------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
| <u>Nitrate –blended tap (ppm)</u> ** | 3/1/2011 4/4/11 | 47 46 | 3-47 | 45 | | Runoff and leaching from fertilizer ⁴ use; leaching from septic tanks, sewage; erosion of natural deposits |
| <u>Arsenic – well #3</u> *** | 4/4/11 10/4/11 | 14 23 | | 10 ^(b) ppb | | Erosion of natural deposits; runoff from orchards; glass and electronics production wastes Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer. |

* Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided on the next page.

(b) Effective 1/23/2006, the federal arsenic MCL is 0.010 mg/L. The new state MCL has not yet been adopted and remains as 0.5 mg/L (or 50 ppb).

| TABLE 5 - DETECTION OF CONTAMINANTS WITH A <u>SECONDARY</u> DRINKING WATER STANDARD | | | | | | |
|---|-------------|----------------|---------------------|-----|------------|-------------------------------|
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Summary Information for Contaminants Exceeding an MCL or AL, or a Violation of any Treatment or Monitoring and Reporting Requirements

**Nitrates

test results through out year:

well #1: 45, 44 well #2: 45 well#3: 3 WELLS #4: ND
 blended tap at lower tank: 38,44,47,3,46,29,41,43,45,39,32,17,18
 Homesites: 36,20,41,21,

Nitrate levels are being testing at the blended tap at the lower tank that collects water from well #4 & #2. This is being done to insure that the water collected has the lowest possible nitrate level before going into the system. It then blends with the water from our lowest nitrate producing well (well #3).

Nitrate in drinking water at levels above 45 ppm is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

*** Arsenic:

test results through out year:

| | | | | | |
|--------------------|--------------|-------------|-------------|--------------|-----------|
| Well #4: | 10/11/11 = 2 | | | | |
| Well #3: | 1/3/11 = 2 | 4/4/11 = 14 | 8/1/11 = 6 | 10/4/11 = 23 | |
| Homesites: | 1/3/11 = 2 | 4/4/11 = 6 | 7/6/11 = ND | 10/4/11 = 7 | |
| Pressure Tank Tap: | 8/1/11 = 2 | 9/2/11=6 | 10/4/11=7 | 11/1/11=7 | 12/1/11=8 |

Arsenic levels are being testing at well #3 and at a residence quarterly. The water from Well #3 is blended with the blended water from wells #4 & #2. This is being done to insure that the water collected has the lowest possible arsenic level before going into the system.

While your drinking water meets the EPA standard for arsenic, it does contain low levels of arsenic. The standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The California Department of Health Services continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

The Health Department has granted our water system the following testing waivers:

- Primary Organics - applying for another waiver
- Secondary organics - applying for another waiver
- VOC's - waived until 2012
- SOC's - applying for another waiver
- Asbestos (source) - waived
- Lead & Copper - next testing July 2012
- Gross Alpha Radiological - next test 2013
- Perchlorate testing completed in 2011
- Radium 228 - no further testing required at this time