

WHOLESALE (SCWA) Detect Primary Drinking Water Constituents regulated to protect your health.

CONSTITUENT	UNITS	MCL	PHG	SURFACE WATER			GROUNDWATER			MAJOR SOURCES
				RANGE	AVG	YEAR OF SAMPLING	RANGE	AVG	YEAR OF SAMPLING	
Aluminum	ppm	1	0.6	ND - 0.18	90	2011	ND - ND	ND	2011	Erosion of leaching of natural deposits and water treatment chemicals added to water
Arsenic	ppb	10	0.004	ND - ND	ND	2011	ND - 8.9	ND	2008-2011	Erosion of leaching of natural deposits
Barium	ppm	1	2	21	21	2011	ND - 0.71	ND	2011	Erosion of leaching of natural deposits
Chromium (Total Cr)	ppb	50	-100	ND - ND	ND	2011	ND - 21	ND	2011	Erosion of leaching of natural deposits
Fluoride	ppm	2	1	ND - ND	ND	2011	ND - 0.71	0.16	2011	Water additive that promotes strong teeth
Nitrate(as nitrite, NO3)	ppm	45	45	ND - ND	ND	2011	ND - 14	ND	2011	Runoff and leaching from fertilizer use; leaching from septic tank and sewage; erosion of natural deposits
Total Trihalomethanes	ppb	80	n/a	ND - 51	25.5	2011	ND - 52	ND	2008-2011	By-product of drinking water disinfection
Total Haloacetic Acids	ppb	60	n/a	48	48	2011	ND	ND	2011	By-product of drinking water disinfection

DISTRIBUTION SYSTEM	UNITS	MCL	PHG	RANGE	AVERAGE	YEAR	MAJOR SOURCE
Chlorine (distribution system)	ppm	[4]	[4.0]	0.5 - 0.86	0.69	2011	Drinking water disinfectant added for treatment
Total Trihalomethanes (distribution system)	ppb	n/a	80	ND - 53	10.6	2011	By-product of drinking water treatment
Haloacetic Acids (distribution system)	ppb	n/a	60	ND - 27	6.9	2011	By-product of drinking water treatment
Control of Disinfection By-Product precursors (TOC) (raw) (b)	ppm	n/a	treatment requirement if average TOC >2	0.92 - 1.4	1.16	2011	Various natural and man-made sources

CONSTITUENT	UNITS	MCL or MRDL	PHG or MCLG	LEVEL FOUND	YEAR OF SAMPLING	MAJOR SOURCES
Total Coliform Bacteria (Total Coliform Rule)	% samples positive	more than 5.0% of monthly samples are positive	0	0.83%	2011	Naturally present in the environment
Turbidity (c),(d)	ntu	TT=1 ntu	0	0.1		
		TT=95% of samples ≤0.3 ntu	n/a	100.00%	2011	Soil runoff

Detected Secondary Drinking Water Constituents regulated for aesthetic qualities

CONSTITUENT	UNITS	MCL	PHG	SURFACE WATER			GROUNDWATER			MAJOR SOURCES
				RANGE	AVG	YEAR OF SAMPLING	RANGE	AVG	YEAR OF SAMPLING	
Chloride	ppm	500	n/a	5.3	5.3	2011	2.6 - 370	18	2011	Erosion or leaching of natural deposits
Color	color unit	15	n/a	15	15	2011	ND - 10	1	2011	Naturally occurring organic materials
Iron	ppb	300	n/a	ND - 270	135	2011	ND - 163	ND	2011	Erosion or leaching of natural deposits
Maganese	ppb	50	n/a	ND - 19	9.5	2011	ND - 38	ND	2011	Erosion or leaching of natural deposits
Odor	odor unit	3	n/a	2	2	2011	ND - 38	ND	2011	Naturally occurring organic substances in water. Disinfectants added to water.
Specific Conductance	uS/cm	1600	n/a	120-190	155	2011	100-1600	293	2011	Substances that form ions when in water
Sulfate	ppm	500	n/a	3.9	3.9	2011	ND - 11	2	2011	Erosion or leaching of natural deposits
Total Dissolved Solids (TDS)	ppm	1000	n/a	79	79	2011	76 - 940	210	2011	Erosion or leaching of natural deposits
Turbidity	ntu	5	n/a	4.1	1.1	2011	ND - 3.6	0.2	2011	Soil runoff

Detected Unregulated Drinking Water Constituents (e)

CONSTITUENT	UNITS	MCL	PHG	SURFACE WATER			GROUNDWATER			MAJOR SOURCES
				RANGE	AVG	YEAR OF SAMPLING	RANGE	AVG	YEAR OF SAMPLING	
Hardness	ppm	n/a	n/a	48	48	2011	13-380	83	2011	Hardness is the sum of polyvalent cations in the water, generally naturally occurring magnesium and calcium.
Sodium	ppm	n/a	n/a	6.7	6.7	2011	12-170	30	2011	Naturally occurring salt in the water
Calcium	ppm	n/a	n/a	10	10	2011	3 - 87	17	2011	Erosion or leaching of natural deposits
Magnesium	ppm	n/a	n/a	5.3	5.3	2011	1.4 - 36	10	2011	Erosion or leaching of natural deposits
pH	units	6.5 - 8.5	n/a	7.3 - 8.1	7.7	2011	6.6 - 8.3	7.95	2011	
Total Alkalinity	ppm	n/a	n/a	49 - 70	59.2	2011	33 - 220	110	2011	Due to chemicals naturally occurring in the soil below the earth's surface
Bicarbonate	ppm	n/a	n/a	56 - 70	62.7	2011	40 - 270	134	2011	Due to chemicals naturally occurring in the soil below the earth's surface
Carbonate	ppm	n/a	n/a	ND	ND	2011	ND - 2.9	ND	2011	Due to chemicals naturally occurring in the soil below the earth's surface
Chromium VI (Hexavalent chromium)	ppb	n/a	0.02				1.0 - 12.6	5.5	2002	Erosion or leaching of natural deposits

LEAD AND COPPER

CONSTITUENT	UNITS	PHG or (MCLG)	AL	# OF SAMPLES COLLECTED	90th PRECENTILE LEVEL DETECTED	# of SITES EXCEEDING AL	YEAR OF SAMPLING	MAJOR SOURCES
Lead	ppb	2	15	51	ND	2	2010	Internal Corrosion of household water plumbing system; discharge from industrial manufacturing; erosion of natural deposits
Copper	ppm	0.3	1.3	51	0.16	0	2010	Internal Corrosion of household water plumbing system; erosion of natural deposits; leaching from wood preservatives



Elk Grove Water District
 9257 Elk Grove Blvd.
 Elk Grove, CA 95624

Postage



2011

Drinking Water Consumer Confidence Report

2011 Drinking Water Consumer Confidence Report

Get More Information

Learn more about the Elk Grove Water District by going to www.egwd.org or by attending any of our public monthly meetings. Our board of directors meet on the 4th Wednesday of the month. Call the water district office at (916) 685-3556 for exact times and locations. If you have specific questions about water quality, call General Manager Mark J. Madison for assistance.



Elk Grove Water District Water Quality Report: 2012

Produced in compliance of California Department of Public Health regulations.

This report contains important information about your drinking water. Translate it, or speak with someone who understands it.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

General Manager Message

Each year, the Elk Grove Water District issues this Consumer Confidence Report to assure our customers that your water has continued to meet or exceed all State and Federal standards. The Elk Grove Water District prides itself on providing reliable, safe drinking water, and an exceptional level of customer care.

We understand that, as our customer, you expect your water to be safe and to taste good. Our staff is available 24 hours a day, 365 days a year so that superior quality is something you can take for granted. We care about you and your families.

This year, the District has embarked on numerous water quality and production improvement projects. We have also implemented a new Strategic Plan redefining our mission and establishing values to govern how we do business. We are committed to our key values: leadership, caring, integrity, professionalism and vision. As your hometown water provider, we strive to continually exceed your expectations. If you ever have an issue or concern, please do not hesitate to contact us.

-Mark Madison

Water Quality Improvement Projects

Elk Grove Water District is currently in construction on projects designed to enhance the water quality throughout the district. These projects include the filter plant improvements, pump and electrical upgrades to wells, and well rehabilitation. The costs of these projects total approximately \$1.5 million and are scheduled to be completed by August 31, 2012.

The filter plant improvements project adds a fourth filter train at the water treatment plant to remove manganese and arsenic. The added treatment capacity will enhance water quality during periods of high demand. The projects related to well upgrades and rehabilitation will improve the reliability, production capacities and water quality of the district's groundwater wells.

Elk Grove Water District takes pride in delivering high quality water to its customers. The water delivered to our customers consistently meets all State and Federal drinking water standards. The projects mentioned above will ensure that our customers today, and in the future, will continue to receive the high quality of water that Elk Grove Water District is proud to deliver.

Fluoridated Water May be Coming Your Way

Sacramento County supplies water to the Elk Grove Water District in Area Two, which is located east of Waterman Road to Grant Line Road and most of the water service between Bond and Sheldon roads. Water being supplied by the Sacramento County Water Agency will be treated with fluoride beginning this fall.

The water provided by the Elk Grove Water District in our older areas between Highway 99 and Waterman Road will not be fluoridated. The County has indicated that there will be no charge for the first two years for fluoridation, as a grant will cover the costs. For additional information about the fluoridation program, please visit www.SCWA.net.

The Sources of Your Water

Most of Elk Grove Water District's water comes from groundwater sources. The Sacramento Valley Groundwater Basin lies below us and there are several wells throughout our community that produce our drinking water. A treatment facility on Railroad Avenue ensures that the water meets all government standards.

The water for the area east of Waterman Blvd. is supplied by Sacramento County Water Agency under a wholesale purchase agreement. Therefore, water quality data for Sacramento County is also listed in this report.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- **Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- **Pesticides and herbicides**, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

- **Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Elk Grove Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Water Quality Report

EGWD GROUNDWATER CONSTITUENT	UNITS	MCL	PHG	RANGE	AVG	TYPICAL SOURCES
PRIMARY DRINKING WATER STANDARDS: <i>Mandatory Health-Related Standards Established by California Department of Public Health.</i>						
MICROBIOLOGICAL CONTAMINANTS						
Total Coliform Bacteria	# Tests	>5% or 1	0	0 out of 501 tests	0	Naturally present in the environment
INORGANIC CHEMICALS						
Arsenic	ppb	10	0.004	ND - 14	ND	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium	ppm	1	2	.083 - .14	0.116	Discharges from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate(as nitrite, NO3)	ppm	45	45	ND - 18	ND	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Perchlorate explosives, flares, matches, and a variety of	ppb	6	6	ND - 0.0023	ND	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, industries. It usually gets into drinking water as a result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.
SECONDARY STANDARDS: <i>Aesthetic Standards Established by California Department of Public Health.</i>						
NOTIFICATION						
	UNITS	MCL	LEVEL	RANGE	AVG	
Chloride	ppb	500	n/a	2.4 - 19	5.4	Runoff/leaching from natural deposits
Iron	ppb	300	n/a	ND - 128	10	Leaching from natural deposits; industrial wastes
Manganese	ppb	50	n/a	ND - 210	30	Leaching from natural deposits
Sulfate	ppm	500	n/a	ND - 11	ND	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS)	ppm	1000	n/a	160 - 310	251	Runoff/leaching from natural deposits
ADDITIONAL CONSTITUENTS ANALYZED						
	UNITS	MCL	LEVEL	RANGE	AVG	
Hardness (as CaCO3)	ppm (grains)	mo	n/a	71 - 72	71.33	Due to chemicals naturally occurring in the soil below the earth's surface.
Sodium	ppm	mo	n/a	17 - 22	19.57	Due to chemicals naturally occurring in the soil below the earth's surface.
CONSTITUENT						
	UNITS	AL	PHG	SAMPLES COLLECTED	90% LEVEL DETECTED	TYPICAL SOURCES
Lead	ppb	15	0.2	30	0.08	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper	ppm	1.3	0.3	30	<5.0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.