



# County of San Diego

RICHARD E. CROMPTON  
DIRECTOR

## DEPARTMENT OF PUBLIC WORKS

5500 OVERLAND AVE, SUITE 315  
SAN DIEGO, CALIFORNIA 92123-1295

(858) 694-2212 FAX: (858) 268-0461  
Web Site: [www.sdcounty.ca.gov/dpwl](http://www.sdcounty.ca.gov/dpwl)

June 22, 2012

TO: Valued Customer

FROM: Daniel S. Brogadir, LUEG Program Manager  
Department of Public Works, Wastewater Management

### 2011 CONSUMER CONFIDENCE REPORT – RANCHO DEL CAMPO WATER SERVICE AREA


The County of San Diego is pleased to provide you the annual Consumer Confidence Report. Last year, as in the past, your drinking water met all California and U.S. Environmental Protection Agency health standards. This report provides a snapshot of the quality of water provided to customers within the Rancho del Campo community by the County of San Diego. Included are details about where your water comes from, what it contains, and how it compares to state and federal standards. The County of San Diego is committed to providing you with this timely information.

In order to ensure that tap water is safe to drink, the California Department of Public Health (DPH) established regulations that limit the amount of certain contaminants in the water provided by public water systems. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk.

Sources of drinking water (both tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

During the period between January 1, 2011 and December 31, 2011, the County of San Diego, through a state-certified laboratory, conducted tests for drinking water contaminants. Test results indicated that the drinking water met all state and federal drinking water standards.

If you have any questions or require further information, please phone Jim LeSire, Wastewater Facilities Supervisor, at (619) 660-6323 or e-mail at [Jim.Lesire@sdcounty.ca.gov](mailto:Jim.Lesire@sdcounty.ca.gov).



DANIEL S. BROGADIR, LUEG Program Manager

Enclosed

c: Peter Neubauer (O564); Richard Crompton (O332); Mohamad Fakhrriddine (O332); Milica Kaludjerski (O384)

# 2011 Consumer Confidence Report

Water System Name: Rancho del Campo 3700859

Report Date: June 22, 2012

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2011.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Well water from three wells

Name & location of source(s): Wells #1 and #3 near Parker Rd. and Well #4, near Moore Rd.

Water from wells #1 and #3 is processed through a radiation-removal facility before release into the distribution system.

Drinking Water Source Assessment information: On file with the Department of Environmental Health

Time and place of regularly scheduled board meetings for public participation: [sdcounty.ca.gov/general/bos.html](http://sdcounty.ca.gov/general/bos.html)  
9:00 am - Wednesday Agenda - 1600 Pacific Highway, Room 310, San Diego, California

For more information, contact: James LeSire Phone: (619) 660-2008

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1 through 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	1	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	11	5.54	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	11	0.309	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

\*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	10/21/11	64.3	50-79	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	10/21/11	180	140-210	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Fluoride (ppm)	10/27/11	0.55	0.51-0.58	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	2/16/11-10/20/11	0.835	0.323-1.91	15	(0)	Erosion of natural deposits
Nitrate (NO <sub>3</sub> ) (ppm)	2/16/11-10/27/11	1.75	1.3-2.7	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	10/27/11	61.3	55-68	500		Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	10/21/11	260	260	300		Leaching from natural deposits; industrial wastes
Manganese (ppb)	10/21/11	1.15	1-1.3	50		Leaching from natural deposits
Sulfate (ppm)	10/27/11	31	20-39	500		Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	2/16/11-10-27-11	388.3	300-480	1000		Runoff/leaching from natural deposits

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron (ppb)	10/21/11	84	70-100	1000	

\*Any violation of an MCL, MRDL, AL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

ATTACHMENT 7


Consumer Confidence Report  
Certification Form

(to be submitted with a copy of the CCR)

Water System Name: Rancho Del Campo

Water System Number: 3700859

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 26, 2012 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified by: Name: Daniel S. Brogadir  
Signature:   
Title: LUEG Program Manager  
Phone Number: (858)694-2714 Date: 6/28/12

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: \_\_\_\_\_
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - Posting the CCR on the Internet at www.\_\_\_\_\_
  - Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - Advertising the availability of the CCR in news media (attach copy of press release)
  - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - Posted the CCR in public places (attach a list of locations)
  - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - Delivery to community organizations (attach a list of organizations)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.\_\_\_\_\_
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission