

O'Connor Tract Co-Operative Water Co.

P.O. Box 1375
Palo Alto, California 94302
650-321-2723

January 23, 2012

Report on Water Quality Measurements

The U.S. Environmental Protection Agency (USEPA) requires that all water users be given a report on water quality measurements.

Our water is pumped from two wells on Oak Court into a large tank for pumping into the distribution system. We have a connection with East Palo Alto's water district that is used as an emergency supply, and that water is treated surface water.

The O'Connor Tract Co-Operative Water Co. routinely monitors for contaminants in your drinking water according to Federal and State laws. Water quality is regulated under two types of standards: 1) Primary Drinking Water Standards set maximum contaminant levels for contaminants that affect health. They also set monitoring, reporting, and water treatment requirements. 2) Secondary standards are for substances affecting qualities such as taste and odor. Bacteriological tests are run on three samples a month. The accompanying tables show the results of our monitoring for the period of January 1 to December 31, 2011, and give values for drinking water standards and measurements made from samples from the two wells. Values reported as ND indicate that the substance could not be detected with the testing procedure used or was below the detection limit for reporting purposes. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

O'Connor water met primary drinking water standards in 2011. Positive coliform results were found in August and November, but retesting 2 days later yielded no positives out of 4 samples. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other potentially harmful bacteria may be present. The positive results could have been from contamination at the sampling station. Bacteriological sampling for the other ten months showed that coliforms were absent.

Bacteriological Testing

Total Coliform Bacteria	Unit	No. Tested	No. Present	MCL	MCLG
August 2011	absent or present	7	1	no more than 1	0
November 2011	absent or present	7	1	no more than 1	0

The water from each well was tested for 27 organic chemicals in 2010, and none were found at the detection limits for reporting purposes. The water from each well was tested for 16 metals, and selenium and zinc were detected (see table). Cyanide and perchlorate test results were not detected. Because of recent publicity about hexavalent chromium, the company tested for it in both wells, and it was not detected. Our water was above the secondary standard for manganese in both wells. Manganese concentrations above the standard have an effect on taste and tend to leave deposits in some plumbing systems.

A requirement from USEPA was to test for lead and copper in the water in people's homes as it comes out of the tap. The supply water has no lead or copper at the detection limit, but these constituents can be leached from lead solder and copper pipe. Samples were tested from 10 homes with copper pipe installed between 1983 and 1988 (lead solder for water pipes was banned in 1988). The lead Action Level (the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow) is 15 ppb, and the copper action level is 1.3 ppm. All of the samples met the standard in two sets of 20 tests conducted in 1993 and 1994, and 7 sets of 10 tests in 1995, 1996, 1997, 2000, 2004, 2007, and 2010. For the 2010 tests, the 90th percentile (ninth highest) value for lead was 4.5 ppb, and for copper was 0.39 ppm.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. O'Connor Water Co. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

A note to parents: Some neighboring districts are fluoridating their water, but the O'Connor Water Company is not. Please discuss this with your pediatrician or your child's dentist. More information about fluoridation, oral health, and current issues can be obtained at <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/Fluoridation.aspx>.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the State Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Your Board hopes that this report helps you to understand water quality issues as they apply to our drinking water. If you have any questions about this report or concerning your water company, please contact the Secretary Ana Pedreiro at 650-321-2723. As always, you are invited to the Annual Meeting the last Thursday in January if you would like further information. Further information may also be obtained at Board meetings on the second Thursday of each month at 7:30 PM at the Company office at 211 Oak Court.

O'Connor Tract Co-Operative Water Co.

2011 Annual Water Quality Report
Results from 2011 except where noted

PRIMARY STANDARDS							
Substance tested	Unit	MCL	MCLG	PHG	Well 1	Well 2	Source
Inorganic constituents							
Nitrate	ppm	45	--	45	3.7	3.3	Erosion of natural deposits
Fluoride	ppm	2	--	1	0.21	0.19	Erosion of natural deposits
Selenium	ppb	50	50	30	ND	8.5	Erosion of natural deposits
Radionuclides							
Gross Alpha (2009)	pCi/L	15	0	--	ND	4.4	Erosion of natural deposits
Uranium (2002)	pCi/L	20	--	0.43	ND	2.1(ND-2.6)	Erosion of natural deposits
Radium-226 & -228 (2000)	pCi/L	5	0	--	1.2(ND-2.2)	ND(ND-1.5)	Erosion of natural deposits

SECONDARY STANDARDS						
Substance tested	Unit	MCL	Well 1	Well 2	Source	
Boron (2004)	ppm	1 (AL)	0.19	0.24	Erosion of natural deposits	
Manganese	ppb	50	92	140	Erosion of natural deposits	
Chloride	ppm	500	87	50	Erosion of natural deposits	
Sulfate	ppm	500	58	53	Erosion of natural deposits	
Zinc	ppm	5	ND	0.16	Erosion of natural deposits	
Total dissolved solids	ppm	1000	480	460	Erosion of natural deposits	
Color	Units	15	<5.0	<5.0	Erosion of natural deposits	
Odor	TON	3	ND	ND	Erosion of natural deposits	
Turbidity	NTU	5	0.16	0.36	Erosion of natural deposits	
Foaming agents (MBAS)	ppb	500	<50	<50	Erosion of natural deposits	

OTHER CONSTITUENTS (with no standards)						
Total hardness	ppm		260	252	Erosion of natural deposits	
Calcium	ppm		77	75	Erosion of natural deposits	
Magnesium	ppm		16	16	Erosion of natural deposits	
Sodium	ppm		57	69	Erosion of natural deposits	
Bicarbonate	ppm		270	320	Erosion of natural deposits	
pH (Laboratory)	pH Units		7.89	7.85		

Abbreviations:

MCL = maximum contaminant level. The highest level of a contaminant that is allowed in drinking water.

Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible.

Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

MCLG = maximum contaminant level goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by USEPA.

PHG = public health goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

AL = action level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ppm = parts per million (mg/L)

NTU = Nephelometric turbidity unit

ppb = parts per billion (µg/L)

TON = threshold odor number

pCi/L = pico Curies per liter (a measure of radioactivity in water)

< = less than the amount given. May not be present.

ND = not detected or below detection limit for reporting purposes