

ATTACHMENT 7

Consumer Confidence Report
Certification Form
(to be submitted with a copy of the CCR)

Water System Name: GREEN RUN

Water System Number: 50000 JS

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 3/25/12 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the California Department of Public Health.

Certified by: Name: J. RENDLER
Signature: [Signature]
Title: AGENT
Phone Number: (530) 269-6079 Date: 3/25/12

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

[X] CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: INCLUDED WITH REST STATEMENTS AND DELIVERED TO EACH HOME/SIDE.

[ ] "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- [ ] Posting the CCR on the Internet at www.
[ ] Mailing the CCR to postal patrons within the service area (attach zip codes used)
[ ] Advertising the availability of the CCR in news media (attach copy of press release)
[ ] Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
[ ] Posted the CCR in public places (attach a list of locations)
[ ] Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
[ ] Delivery to community organizations (attach a list of organizations)
[ ] Other (attach a list of other methods used)

[ ] For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

[ ] For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

# 2011 Consumer Confidence Report

Water System Name: **Green Run Mobile Home Park** Report Date: 02/21/12

*We test the drinking water quality for many constituents as required by State and Federal Regulations.  
This report shows the results of our monitoring for the period of January 1 - December 31, 2011*

**Este informe contiene información muy importante sobre su agua potable.  
Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: **Groundwater Well**  
Name & location of source(s): **West (Main) Well at 5061 E. Nunes Rd. Turlock, CA**  
For more information, contact: **Don LeQue** Phone #: **(209) 632-5786**

## **TERMS USED IN THIS REPORT:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Primary Drinking Water Standards (PDWS):** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**NTU:** nephelometric turbidity unit

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**ppb:** parts per billion or micrograms per liter (ug/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

### **Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the U. S. Environmental Protection Agency (USEPA) and the State Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Lead and Copper (and reporting units)	No. of Samples Collected (Date)	90 <sup>th</sup> Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	5 (07/09/10)	< 5	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm)	5 (07/09/10)	< 0.05	0	1.3	0.17	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	11/02/11	25		None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	11/02/11	132		None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Nitrate as NO3 (ppm)	2011	5	5 - 6		45	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Uranium (pCi/l)	2009	< 1	< 1 - 1	20	N/A	Erosion of natural deposits
Arsenic (ppb)	2011	15*	13* - 19*	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Chromium (ppb)	09/06/11	11		50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	2011	0.2	0.1 - 0.4	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (ppm)	11/02/11	158		1000	N/A	Runoff/leaching from natural deposits
Specific Conductance (umho/cm)	11/02/11	258		1600	N/A	Substances that form ions when in water; seawater influence
Chloride (ppm)	11/02/11	5		500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	11/02/11	5		500	N/A	Runoff/leaching from natural deposits' industrial wastes

*\*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided on the next page.*