

Consumer Confidence Report Certification Form

Water System Name: **DENNISON PARK**
Water System Number: **5601701**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name _____

Signature _____

Title _____

Phone Number (_____) _____ Date _____

=====

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

___ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: _____

___ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

___ Posted the CCR on the internet at www. _____

___ Mailed the CCR to postal patrons within the service area (attach zip codes used)

___ Advertised the availability of the CCR in news media (attach copy of press release)

___ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

___ Posted the CCR in public places (attach a list of locations)

___ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools

___ Delivery to community organizations (attach a list of organizations)

___ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. _____

___ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2011 Consumer Confidence Report

Water System Name: **DENNISON PARK**

Report Date: **March 2012**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2011

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water sources(s) in use: This info is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 1 source: Well 01.

For more information about this report, or for any questions relating to your drinking water, please call (805) 647 - 5603 and ask for Lori Frost.

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picograms per liter (pg/L)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2011 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Health Services (Department) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2,3,4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/mo. (2011)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

TABLE 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	2010	96	79 - 112	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2010	278	242 - 313	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

2011 Consumer Confidence Report

TABLE 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Aluminum (Al) ppm	2010	0.035	ND - 0.07	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (As) ppb	2010	4.0	ND - 8	10	n/a	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (Ba) ppm	2010	0.15	0.05 - 0.3	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (Total Cr) ppb	2010	5	ND - 10	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nitrate + Nitrite as N ppm	2010	4.5	ND - 9.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (Se) ppb	2010	7.0	ND - 14	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha pCi/L	2010	6.7	7 - 7	15	n/a	Erosion of natural deposits.
Uranium pCi/L	2010	5.6	6 - 6	20	0.5	Erosion of natural deposits

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Chloride ppm	2010	50	21 - 78	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Unfiltered) Units	2010	4	ND - 7	15	n/a	Naturally-occurring organic materials
Iron (Fe) ppb	2010	660	200 - 1200	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (Mn) ppb	2010	15	10 - 20	50	500	Leaching from natural deposits
Odor Threshold at 60 °C TON	2010	2	ND - 4	3	n/a	Naturally-occurring organic materials.
Specific Conductance umhos/cm	2010	904	839 - 969	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (SO4) ppm	2010	74.5	26 - 123	500	n/a	Runoff/leaching from natural deposits; industrial wastes
TDS ppm	2010	540	520 - 560	1000	n/a	Runoff/leaching from natural deposits

2011 Consumer Confidence Report

TABLE 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Zinc (Zn) ppm	2010	0.01	ND - 0.02	5	n/a	Runoff/leaching from natural deposits

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

TABLE 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron ppm	2010	0.3	0.2 - 0.3 (2010)	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
Vanadium ppm	2010	0.002	ND - 0.004 (2010)	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *DENNISON PARK* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

2011 Consumer Confidence Report

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

For Arsenic (As) results above 5 ppb up to and including 10 ppb: While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from the drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

About our Iron (Fe): Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Odor Threshold at 60 °C: Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

Drinking Water Source Assessment Information

Assessment Info

According to the Drinking Water Source Assessment and Protection Program's Source Water Assessments Public Access web page, the Public Water Sources WELL Q1 of the DENNISON PARK water system number 5601701, does not have a completed Source Water Assessment on file.

Discussion of Vulnerability

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Info

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

DENNISON PARK

Analytical Results By FGL - 2011

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%				50.0 %	0 - 1
DP-SS#3	SP 1113101-001					12/20/2011	Absent		
DP-WELL 01	SP 1113101-002					12/20/2011	<1.0		
DP-SS#3	SP 1112103-001					11/21/2011	Absent		
DP-WELL 01	SP 1112103-002					11/21/2011	<1.0		
DP-SS#3	SP 1111118-001					10/27/2011	Absent		
DP-WELL 01	SP 1111118-002					10/27/2011	<1.0		
Well	SP 1109719-001					09/22/2011	<1.0		
SS #3	SP 1109719-002					09/22/2011	Absent		
DP-SS#3	SP 1108286-001					08/16/2011	Absent		
DP-WELL 01	SP 1108286-002					08/16/2011	<1.0		
Dale - 8th & Sa	SP 1107546-001					07/29/2011	Absent		
3110 Loma Vista	SP 1107517-001					07/28/2011	Absent		
DP-SS#3	SP 1107101-001					07/15/2011	Absent		
DP-WELL 01	SP 1107101-002					07/15/2011	<1.0		
DP-SS#3	SP 1106272-001					06/23/2011	Absent		
DP-WELL 01	SP 1106272-002					06/23/2011	118.4		
DP-SS#3	SP 1104510-001					05/06/2011	Absent		
DP-WELL 01	SP 1104510-002					05/06/2011	9.9		
DP-WELL 01	SP 1104216-002					04/28/2011	25.4		
DP-SS#3	SP 1104137-001					04/26/2011	Absent		
DP-SS#3	SP 1102494-001					03/10/2011	Absent		
DP-WELL 01	SP 1102494-002					03/10/2011	59.1		
DP-SS#3	SP 1101516-001					02/11/2011	Absent		
DP-WELL 01	SP 1101516-002					02/11/2011	32.4		
DP-SS#3	SP 1100439-001					01/13/2011	Absent		
DP-WELL 01	SP 1100439-002					01/13/2011	>200.5		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			96	79 - 112
Well	SP 1012782-002	ppm				12/15/2010	112		
Well	SP 1003727-001	ppm				04/21/2010	79.0		
Hardness		ppm		none	none			278	242 - 313
Well	SP 1012782-002	ppm				12/15/2010	242		
Well	SP 1003727-001	ppm				04/21/2010	313		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Aluminum (Al)		ppm		1	0.6			0.035	0.00 - 0.07
Well	SP 1012782-002	ppm				12/15/2010	0.00		
Well	SP 1003727-001	ppm				04/21/2010	0.0700		
Arsenic (As)		ppb		10	n/a			4.0	0 - 8
Well	SP 1012782-002	ppb				12/15/2010	8.00		
Well	SP 1003727-001	ppb				04/21/2010	0.00		
Barium (Ba)		ppm	2	1	2			0.15	0.05 - 0.3
Well	SP 1012782-002	ppm				12/15/2010	0.255		
Well	SP 1003727-001	ppm				04/21/2010	0.0540		
Chromium (Total Cr)		ppb	100	50.0				5	0 - 10
Well	SP 1012782-002	ppb				12/15/2010	0.00		
Well	SP 1003727-001	ppb				04/21/2010	10.0		
Nitrate + Nitrite as N		ppm		10	10			4.5	0.0 - 9.0
Well	SP 1012782-002	ppm				12/15/2010	0.00		
Well	SP 1003727-001	ppm				04/21/2010	9.00		
Selenium (Se)		ppb	50	50	30			7.0	0 - 14
Well	SP 1012782-002	ppb				12/15/2010	0.00		
Well	SP 1003727-001	ppb				04/21/2010	14.0		

DENNISON PARK

Analytical Results By FGL - 2011

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Gross Alpha		pCi/L		15				6.7	7 - 7
Gross Alpha		pCi/L							
Well	SP 1003727-001	pCi/L				04/21/2010	6.73		
Uranium		pCi/L		20	0.5			5.6	6 - 6
Well	SP 1003727-001	pCi/L				04/21/2010	5.62		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500				50	21 - 78
Well	SP 1012782-002	ppm				12/15/2010	21.0		
Well	SP 1003727-001	ppm				04/21/2010	78.0		
Color (Unfiltered)		Units		15				4	0 - 7
Well	SP 1012782-002	Units				12/15/2010	0.00		
Well	SP 1003727-001	Units				04/21/2010	7.00		
Iron (Fe)		ppb		300				660	200 - 1200
Well	SP 1012782-002	ppb				12/15/2010	150		
Well	SP 1003727-001	ppb				04/21/2010	1170		
Manganese (Mn)		ppb		50	500			15	10 - 20
Well	SP 1012782-002	ppb				12/15/2010	20.0		
Well	SP 1003727-001	ppb				04/21/2010	10.0		
Odor Threshold at 60 °C		TON		3				2	0 - 4
Well	SP 1012782-002	TON				12/15/2010	4		
Well	SP 1003727-001	TON				04/21/2010	ND		
Specific Conductance		umhos/cm		1600				904	839 - 969
Well	SP 1012782-002	umhos/cm				12/15/2010	839		
Well	SP 1003727-001	umhos/cm				04/21/2010	969		
Sulfate (SO4)		ppm		500				74.5	26 - 123
Well	SP 1012782-002	ppm				12/15/2010	26.0		
Well	SP 1003727-001	ppm				04/21/2010	123		
TDS		ppm		1000				540	520 - 560
Well	SP 1012782-002	ppm				12/15/2010	520		
Well	SP 1003727-001	ppm				04/21/2010	560		
Zinc (Zn)		ppm		5				0.01	0.00 - 0.02
Well	SP 1012782-002	ppm				12/15/2010	0.0200		
Well	SP 1003727-001	ppm				04/21/2010	0.00		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		ppm		NS				0.3	0.2 - 0.3
Well	SP 1012782-002	ppm				12/15/2010	0.300		
Well	SP 1003727-001	ppm				04/21/2010	0.200		
Vanadium		ppm		NS				0.002	0 - 0.004
Well	SP 1012782-002	ppm				12/15/2010	0.00		
Well	SP 1003727-001	ppm				04/21/2010	0.00400		

DENNISON PARK CCR Login Linkage - 2011

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
3110 Loma Vista	07/28/2011	SP 1107517-001	Coliform	3110 Loma Vista	Dale - 3110 Loma Vista
Dale - 8th & Sa	07/29/2011	SP 1107546-001	Coliform	Dale - 8th & Santa Maria	Dale - 8th & Santa Maria
Dennison Park W	04/23/2008	SP 0804371-001	Metals, Total	Dennison Park Well	Dennison Park
DP-SS#3	01/13/2011	SP 1100439-001	Coliform	DP-Sample Station #3	Dennison Park
	02/11/2011	SP 1101516-001	Coliform	DP-Sample Station #3	Dennison Park
	03/10/2011	SP 1102494-001	Coliform	DP-Sample Station #3	Dennison Park
	04/26/2011	SP 1104137-001	Coliform	DP-Sample Station #3	Dennison Park Water Monitoring
	05/06/2011	SP 1104510-001	Coliform	DP-Sample Station #3	Dennison Park
	06/23/2011	SP 1106272-001	Coliform	DP-Sample Station #3	Dennison Park
	07/15/2011	SP 1107101-001	Coliform	DP-Sample Station #3	Dennison Park
	08/16/2011	SP 1108286-001	Coliform	DP-Sample Station #3	Dennison Park
	10/27/2011	SP 1111118-001	Coliform	DP-Sample Station #3	Dennison Park
	11/21/2011	SP 1112103-001	Coliform	DP-Sample Station #3	Dennison Park
12/20/2011	SP 1113101-001	Coliform	DP-Sample Station #3	Dennison Park	
DP-WELL 01	01/13/2011	SP 1100439-002	Coliform	WELL 01	Dennison Park
	02/11/2011	SP 1101516-002	Coliform	Well 01	Dennison Park
	03/10/2011	SP 1102494-002	Coliform	Well 01	Dennison Park
	04/28/2011	SP 1104216-002	Coliform	Well 01	Dennison Park
	05/06/2011	SP 1104510-002	Coliform	Well 01	Dennison Park
	06/23/2011	SP 1106272-002	Coliform	Well 01	Dennison Park
	07/15/2011	SP 1107101-002	Coliform	Well 01	Dennison Park
	08/16/2011	SP 1108286-002	Coliform	Well 01	Dennison Park
	10/27/2011	SP 1111118-002	Coliform	Well 01	Dennison Park
	11/21/2011	SP 1112103-002	Coliform	Well 01	Dennison Park
12/20/2011	SP 1113101-002	Coliform	Well 01	Dennison Park	
SS #3	09/22/2011	SP 1109719-002	Coliform	SS #3	Dennison Park
Tank	03/14/2008	SP 0802822-003	Metals, Total	Tank	Dennison Park
Well	02/20/2008	SP 0801931-006	Metals, Total	Well	Dennison Park
	04/21/2010	SP 1003727-001	Asbestos	Well	La Loma Mutual
	04/21/2010	SP 1003727-001	EPA 507	Well	La Loma Mutual
	04/21/2010	SP 1003727-001	EPA 524.2	Well	La Loma Mutual
	04/21/2010	SP 1003727-001	General Mineral	Well	La Loma Mutual
	04/21/2010	SP 1003727-001	Metals, Total	Well	La Loma Mutual
	04/21/2010	SP 1003727-001	Radio Chemistry	Well	La Loma Mutual
	04/21/2010	SP 1003727-001	Wet Chemistry	Well	La Loma Mutual
	12/15/2010	SP 1012782-002	EPA 524.2	WELL 01	Dennison Park Water Monitoring
	12/15/2010	SP 1012782-002	General Mineral	WELL 01	Dennison Park Water Monitoring
	12/15/2010	SP 1012782-002	Metals, Total	WELL 01	Dennison Park Water Monitoring
	12/15/2010	SP 1012782-002	Wet Chemistry	WELL 01	Dennison Park Water Monitoring
	09/22/2011	SP 1109719-001	Coliform	Well	Dennison Park
09/22/2011	SP 1109719-001	Wet Chemistry	Well	Dennison Park	
Well 01	12/29/2008	SP 0814109-001	Wet Chemistry	Well 01 - Inactive	Dennison Park
Well Q1	03/14/2008	SP 0802822-002	EPA 524.2	Well Q1	Dennison Park
	03/14/2008	SP 0802822-002	Metals, Total	Well Q1	Dennison Park
	12/14/2009	SP 0912637-001	Wet Chemistry	Well Q1	Dennison Park