

2011 Consumer Confidence Report

Water System Name: **VINEYARD MUTUAL WATER
COMPANY/INDUSTRIAL**

Report Date: April 2012

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2011

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water sources(s) in use: The Assessment was conducted by DHS District Office. According to DHS records, Well 1 and Well 2 are Groundwater. This Assessment was done using the Default Groundwater System Method. The VINEYARD MUTUAL WATER COMPANY system is located in Ventura County and serves the surrounding commercial and industrial areas. There are approximately 52 service connections serving a population of 140.

Your water comes from 2 sources: Well 1 and Well 2.

For more information about this report, or for any questions relating to your drinking water, please call (805) 654 - 1077 and ask for John Ferro.

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picograms per liter (pg/L)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2011 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Health Services (Department) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2,3,4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Typical Sources of Contaminant |
|--|----------------|-------------------|------------------------|---------------|---------------|--|
| Sodium (ppm) | 2010 | 118 | 114 - 121 | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 2010 | 716 | 708 - 723 | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

TABLE 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) [MRDLG] | Typical Sources of Contaminant |
|--|----------------|-------------------|------------------------|---------------|--------------------------|---|
| Barium (Ba) ppm | 2010 | 0.03 | 0.03 - 0.03 | 1 | 2 | Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits |
| Cadmium (Cd) ppb | 2010 | 0.1 | ND - 0.2 | 5.0 | 0.04 | Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories, and from metal refineries; runoff from waste batteries and paints |
| Chromium (Total Cr) ppb | 2010 | 1 | 1 - 1 | 50.0 | n/a | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits |

2011 Consumer Confidence Report

| TABLE 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|--|-------------|----------------|---------------------|------------|--------------------|--|
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) [MRDLG] | Typical Sources of Contaminant |
| Nitrate (NO3) ppm | 2011 | 11.4 | 10 - 12 | 45 | 45 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Nitrate + Nitrite as N ppm | 2010 | 2.35 | 2.3 - 2.4 | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Selenium (Se) ppb | 2010 | 6.0 | 6 - 6 | 50 | 30 | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive) |
| Gross Alpha pCi/L | 2008 | 4.8 | 3 - 7 | 15 | n/a | Erosion of natural deposits. |
| Uranium pCi/L | 2008 | 4.0 | 2 - 5 | 20 | 0.5 | Erosion of natural deposits |
| Total Radium 228 pCi/L | 2008 | 0.31 | 0.2 - 0.4 | 5 | n/a | Erosion of natural deposits |

| TABLE 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD | | | | | | |
|--|-------------|----------------|---------------------|------------|------------|---|
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Typical Sources of Contaminant |
| Chloride ppm | 2010 | 62 | 61 - 62 | 500 | n/a | Runoff/leaching from natural deposits; seawater influence |
| Color (Unfiltered) Units | 2010 | 3 | ND - 5 | 15 | n/a | Naturally-occurring organic materials |
| Iron (Fe) ppb | 2010 | 80 | 70 - 80 | 300 | n/a | Leaching from natural deposits; Industrial wastes |
| Specific Conductance umhos/cm | 2010 | 1660 | 1630 - 1680 | 1600 | n/a | Substances that form ions when in water; seawater influence |
| Sulfate (SO4) ppm | 2010 | 600.00 | 590 - 610 | 500 | n/a | Runoff/leaching from natural deposits; industrial wastes |
| TDS ppm | 2010 | 1240 | 1210 - 1280 | 1000 | n/a | Runoff/leaching from natural deposits |

Any violation of MCL, AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

| TABLE 4 - DETECTION OF UNREGULATED CONTAMINANTS | | | | | |
|--|-------------|----------------|---------------------|--------------------|---|
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects Language |
| Boron ppm | 2010 | 0.7 | 0.7 - 0.7 (2010) | 1 | The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals. |

2011 Consumer Confidence Report

| TABLE 5 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE | | | | | | |
|---|----------------|-------------------|------------------------|---------------|---------------|---|
| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Typical Sources of Contaminant |
| Total Trihalomethanes (TTHMs) ppb | 2011 | 22.1 | 22.1 - 22.1 | 80 | n/a | By-product of drinking water disinfection |
| Haloacetic Acids (five) ppb | 2011 | 3 | 3 - 3 | 60 | n/a | By-product of drinking water disinfection |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Citation: We (VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL) are required to collect Lead & Copper samples from 5 locations once every three years, during any of the summer months June, July, August, or September of 2010, however as that sampling was missed and a citation stating how to address the violation was issued March 22, 2012.

Correction: We have complied with the citation's directives which require us to; Notify the public of the failure to collect the Lead & Copper samples between June and September of 2010. We must issue a notice to each resident by direct mailing in their Consumer Confidence Report to be published in 2012. We will be sampling Lead & Copper this summer of 2012, further more we have ensured future Lead & Copper samples will be collected in a timely manor by utilizing a service provided by the laboratory we contract with.

2011 Consumer Confidence Report

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

About our Specific Conductance: The conductivity of your water was found at levels that exceed the secondary MCL. The secondary MCL's were set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.

About our Sulfate (SO4): Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic affects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

About our TDS: The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCL's was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

Drinking Water Source Assessment Information

Assessment Info

A source water assessment was conducted for the WELL 01 and the WELL 02 of the VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL water system in March, 2012.

Well 01 - The source is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Body shops
- Automobile - Repair shops
- Sewer collection systems

Well 02 - The source is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Body shops
- Automobile - Repair shops
- Sewer collection systems

Acquiring Info

A copy of the complete assessment may be viewed at:

DHS Drinking Water Field Operations Branch

1180 Eugenia Place

Suite 200

Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Kurt Souza

District Engineer

805 566 1326

VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL

Analytical Results By FGL - 2011

| SAMPLING RESULTS FOR SODIUM AND HARDNESS | | | | | | | | | |
|--|----------------|-------|------|--------|------|------------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Sodium | | ppm | | none | none | | | 118 | 114 - 121 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 121 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 114 | | |
| Hardness | | ppm | | none | none | | | 716 | 708 - 723 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 723 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 708 | | |

| PRIMARY DRINKING WATER STANDARDS (PDWS) | | | | | | | | | |
|---|----------------|-------|------|--------|------|------------|--------|----------------|-------------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
| Barium (Ba) | | ppm | 2 | 1 | 2 | | | 0.03 | 0.03 - 0.03 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 0.0282 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 0.0274 | | |
| Cadmium (Cd) | | ppb | | 5.0 | 0.04 | | | 0.1 | 0 - 0.2 |
| Well 1 | SP 1003669-001 | ppb | | | | 04/20/2010 | 0.00 | | |
| Well 2 | SP 1003669-002 | ppb | | | | 04/20/2010 | 0.200 | | |
| Chromium (Total Cr) | | ppb | 100 | 50.0 | | | | 1 | 1 - 1 |
| Well 1 | SP 1003669-001 | ppb | | | | 04/20/2010 | 1.00 | | |
| Well 2 | SP 1003669-002 | ppb | | | | 04/20/2010 | 1.00 | | |
| Nitrate (NO3) | | ppm | | 45 | 45 | | | 11.4 | 10 - 12 |
| Well 1 | SP 1104146-001 | ppm | | | | 04/27/2011 | 10.3 | | |
| Well 2 | SP 1104146-002 | ppm | | | | 04/27/2011 | 12.4 | | |
| Nitrate + Nitrite as N | | ppm | | 10 | 10 | | | 2.35 | 2.3 - 2.4 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 2.40 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 2.30 | | |
| Selenium (Se) | | ppb | 50 | 50 | 30 | | | 6.0 | 6 - 6 |
| Well 1 | SP 1003669-001 | ppb | | | | 04/20/2010 | 6.00 | | |
| Well 2 | SP 1003669-002 | ppb | | | | 04/20/2010 | 6.00 | | |
| Gross Alpha | | pCi/L | | 15 | | | | 4.8 | 3 - 7 |
| Well 1 | SP 0811923-001 | pCi/L | | | | 10/29/2008 | 6.77 | | |
| Well 2 | SP 0811923-002 | pCi/L | | | | 10/29/2008 | 2.92 | | |
| Well 1 | SP 0807957-001 | pCi/L | | | | 07/22/2008 | 5.90 | | |
| Well 2 | SP 0807957-002 | pCi/L | | | | 07/22/2008 | 6.32 | | |
| Well 1 | SP 0803649-001 | pCi/L | | | | 04/04/2008 | 5.27 | | |
| Well 1 | SP 0803649-001 | pCi/L | | | | 04/04/2008 | 5.27 | | |
| Well 2 | SP 0803649-002 | pCi/L | | | | 04/04/2008 | 3.51 | | |
| Well 2 | SP 0803649-002 | pCi/L | | | | 04/04/2008 | 3.51 | | |
| Well 1 | SP 0800691-001 | pCi/L | | | | 01/17/2008 | 4.87 | | |
| Well 1 | SP 0800691-001 | pCi/L | | | | 01/17/2008 | 4.87 | | |
| Well 2 | SP 0800691-002 | pCi/L | | | | 01/17/2008 | 2.52 | | |
| Well 2 | SP 0800691-002 | pCi/L | | | | 01/17/2008 | 2.52 | | |
| Uranium | | pCi/L | | 20 | 0.5 | | | 4.0 | 2 - 5 |
| Well 1 | SP 0811923-001 | pCi/L | | | | 10/29/2008 | 4.33 | | |
| Well 2 | SP 0811923-002 | pCi/L | | | | 10/29/2008 | 4.24 | | |
| Well 1 | SP 0807957-001 | pCi/L | | | | 07/22/2008 | 5.09 | | |
| Well 2 | SP 0807957-002 | pCi/L | | | | 07/22/2008 | 3.99 | | |
| Well 1 | SP 0803649-001 | pCi/L | | | | 04/04/2008 | 2.32 | | |
| Well 1 | SP 0803649-001 | pCi/L | | | | 04/04/2008 | 2.32 | | |
| Well 1 | SP 0800691-001 | pCi/L | | | | 01/17/2008 | 3.73 | | |
| Well 1 | SP 0800691-001 | pCi/L | | | | 01/17/2008 | 3.73 | | |
| Total Radium 228 | | pCi/L | | 5 | | | | 0.31 | 0.2 - 0.4 |
| Well 1 | SP 0802758-001 | pCi/L | | | | 03/13/2008 | 0.189 | | |
| Well 1 | SP 0802758-001 | pCi/L | | | | 03/13/2008 | 0.189 | | |
| Well 2 | SP 0802758-002 | pCi/L | | | | 03/13/2008 | 0.434 | | |
| Well 2 | SP 0802758-002 | pCi/L | | | | 03/13/2008 | 0.434 | | |

| SECONDARY DRINKING WATER STANDARDS (SDWS) | | | | | | | | | |
|---|--|-------|------|--------|-----|---------|--------|----------------|-----------|
| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |

VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL

Analytical Results By FGL - 2011

SECONDARY DRINKING WATER STANDARDS (SDWS)

| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|-----------------------------|----------------|----------|------|--------|-----|------------|--------|----------------|-------------|
| Chloride | | ppm | | 500 | | | | 62 | 61 - 62 |
| Chloride | | | | | | | | | |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 62.0 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 61.0 | | |
| Color (Unfiltered) | | Units | | 15 | | | | 3 | 0 - 5 |
| Well 1 | SP 1003669-001 | Units | | | | 04/20/2010 | 0.00 | | |
| Well 2 | SP 1003669-002 | Units | | | | 04/20/2010 | 5.00 | | |
| Iron (Fe) | | ppb | | 300 | | | | 80 | 70 - 80 |
| Well 1 | SP 1003669-001 | ppb | | | | 04/20/2010 | 80.0 | | |
| Well 2 | SP 1003669-002 | ppb | | | | 04/20/2010 | 70.0 | | |
| Specific Conductance | | umhos/cm | | 1600 | | | | 1660 | 1630 - 1680 |
| Well 1 | SP 1003669-001 | umhos/cm | | | | 04/20/2010 | 1680 | | |
| Well 2 | SP 1003669-002 | umhos/cm | | | | 04/20/2010 | 1630 | | |
| Sulfate (SO4) | | ppm | | 500 | | | | 600.00 | 590 - 610 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 610 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 590 | | |
| TDS | | ppm | | 1000 | | | | 1240 | 1210 - 1280 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 1280 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 1210 | | |

UNREGULATED CONTAMINANTS

| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|--------------|----------------|-------|------|--------|-----|------------|--------|----------------|-----------|
| Boron | | ppm | | NS | | | | 0.7 | 0.7 - 0.7 |
| Well 1 | SP 1003669-001 | ppm | | | | 04/20/2010 | 0.700 | | |
| Well 2 | SP 1003669-002 | ppm | | | | 04/20/2010 | 0.700 | | |

FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE

| | | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|--------------------------------------|----------------|-------|------|--------|-----|------------|--------|----------------|-------------|
| Total Trihalomethanes (TTHMs) | | ppb | | 80 | n/a | | | 22.1 | 22.1 - 22.1 |
| 162 Montgomery | SP 1107930-001 | ppb | | | | 08/08/2011 | 22.1 | | |
| 162 Montgomery | SP 1008264-001 | ppb | | | | 08/16/2010 | 31.4 | | |
| Haloacetic Acids (five) | | ppb | | 60 | n/a | | | 3 | 3 - 3 |
| 162 Montgomery | SP 1107930-001 | ppb | | | | 08/08/2011 | 3.00 | | |
| 162 Montgomery | SP 1008264-001 | ppb | | | | 08/16/2010 | 6.00 | | |

VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL CCR Login Linkage - 2011

| FGL CODE | DATE SAMPLED | LAB ID | METHOD | DESCRIPTION | PROPERTY |
|----------------|----------------|----------------|-----------------|----------------------|--------------------------|
| 162 Montgomery | 08/07/2009 | SP 0907882-001 | EPA 551.1 | 162 Montgomery | D/DBR - THMs/HAA5 |
| | 08/07/2009 | SP 0907882-001 | EPA 552.2 | 162 Montgomery | D/DBR - THMs/HAA5 |
| | 08/16/2010 | SP 1008264-001 | EPA 551.1 | 162 Montgomery | D/DBR - THMs/HAA5 |
| | 08/16/2010 | SP 1008264-001 | EPA 552.2 | 162 Montgomery | D/DBR - THMs/HAA5 |
| | 01/05/2011 | SP 1100138-001 | Coliform | 162 Montgomery | Water Monitoring-Odd |
| | 03/03/2011 | SP 1102206-001 | Coliform | 162 Montgomery | Water Monitoring-Odd |
| | 05/16/2011 | SP 1104769-001 | Coliform | 162 Montgomery | Water Monitoring-Odd |
| | 07/25/2011 | SP 1107375-001 | Coliform | 162 Montgomery | Water Monitoring-Odd |
| | 08/08/2011 | SP 1107930-001 | EPA 551.1 | 162 Montgomery | D/DBR - THMs/HAA5 |
| | 08/08/2011 | SP 1107930-001 | EPA 552.2 | 162 Montgomery | D/DBR - THMs/HAA5 |
| | 09/08/2011 | SP 1109162-001 | Coliform | 162 Montgomery | Water Monitoring-Odd |
| 11/10/2011 | SP 1111691-001 | Coliform | 162 Montgomery | Water Monitoring-Odd | |
| 183 Montgomery | 08/22/2008 | SP 0809161-001 | EPA 551.1 | 183 Montgomery | D/DBR - THMs/HAA5 |
| | 08/22/2008 | SP 0809161-001 | EPA 552.2 | 183 Montgomery | D/DBR - THMs/HAA5 |
| 301 Lambert | 02/04/2011 | SP 1101218-001 | Coliform | 301 Lambert | Water Monitoring-Even |
| | 04/27/2011 | SP 1104142-001 | Coliform | 301 Lambert | Water Monitoring-Even |
| | 06/09/2011 | SP 1105701-001 | Coliform | 301 Lambert | Water Monitoring-Even |
| | 08/08/2011 | SP 1107931-001 | Coliform | 301 Lambert | Water Monitoring-Even |
| | 10/10/2011 | SP 1110376-001 | Coliform | 301 Lambert | Water Monitoring-Even |
| | 12/08/2011 | SP 1112653-001 | Coliform | 301 Lambert | Water Monitoring-Even |
| Well 1 | 01/17/2008 | SP 0800691-001 | Radio Chemistry | Well 01 | Radiochem Monitoring |
| | 03/13/2008 | SP 0802758-001 | Radio Chemistry | Well 01 | Radium 228 Monitoring |
| | 04/04/2008 | SP 0803646-001 | Wet Chemistry | Well 01 | Water Quality Monitoring |
| | 04/04/2008 | SP 0803649-001 | Radio Chemistry | Well 01 | Radiochem Monitoring |
| | 07/22/2008 | SP 0807957-001 | Radio Chemistry | Well 01 | Radiochem Monitoring |
| | 10/29/2008 | SP 0811923-001 | Radio Chemistry | Well 01 | Radiochem Monitoring |
| | 04/21/2009 | SP 0903815-001 | Wet Chemistry | Well 01 | Water Quality Monitoring |
| | 04/20/2010 | SP 1003669-001 | General Mineral | Well 01 | Water Quality Monitoring |
| | 04/20/2010 | SP 1003669-001 | Metals, Total | Well 01 | Water Quality Monitoring |
| | 04/20/2010 | SP 1003669-001 | Wet Chemistry | Well 01 | Water Quality Monitoring |
| | 01/05/2011 | SP 1100139-001 | Coliform | Well 01 | Vineyard MWC |
| | 04/27/2011 | SP 1104144-001 | Coliform | Well 01 | Vineyard MWC |
| | 04/27/2011 | SP 1104146-001 | Wet Chemistry | Well 01 | Water Quality Monitoring |
| | 07/25/2011 | SP 1107376-001 | Coliform | Well 01 | Vineyard MWC |
| | 10/10/2011 | SP 1110375-001 | Coliform | Well 01 | Vineyard MWC |
| Well 2 | 01/17/2008 | SP 0800691-002 | Radio Chemistry | Well 02 | Radiochem Monitoring |
| | 03/13/2008 | SP 0802758-002 | Radio Chemistry | Well 02 | Radium 228 Monitoring |
| | 04/04/2008 | SP 0803646-002 | Wet Chemistry | Well 02 | Water Quality Monitoring |
| | 04/04/2008 | SP 0803649-002 | Radio Chemistry | Well 02 | Radiochem Monitoring |
| | 07/22/2008 | SP 0807957-002 | Radio Chemistry | Well 02 | Radiochem Monitoring |
| | 10/29/2008 | SP 0811923-002 | Radio Chemistry | Well 02 | Radiochem Monitoring |
| | 04/21/2009 | SP 0903815-002 | Wet Chemistry | Well 02 | Water Quality Monitoring |
| | 04/20/2010 | SP 1003669-002 | General Mineral | Well 02 | Water Quality Monitoring |
| | 04/20/2010 | SP 1003669-002 | Metals, Total | Well 02 | Water Quality Monitoring |
| | 04/20/2010 | SP 1003669-002 | Wet Chemistry | Well 02 | Water Quality Monitoring |
| | 01/05/2011 | SP 1100139-002 | Coliform | Well 02 | Vineyard MWC |
| | 04/27/2011 | SP 1104144-002 | Coliform | Well 02 | Vineyard MWC |
| | 04/27/2011 | SP 1104146-002 | Wet Chemistry | Well 02 | Water Quality Monitoring |
| | 07/25/2011 | SP 1107376-002 | Coliform | Well 02 | Vineyard MWC |
| | 10/10/2011 | SP 1110375-002 | Coliform | Well 02 | Vineyard MWC |