

2012 Annual Drinking Water Quality Report Laton Community Services District

*We test the drinking water quality for many constituents as required by State and Federal Regulations.
This report shows the results of our monitoring for the period of January 1 – December 31, 2012*

**Este informe contiene información muy importante sobre su agua de beber.
Tradúzcalo ó hable con alguien que lo entienda bien.**

We are pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide you with a safe and dependable supply of drinking water. Our water source comes from three active wells, Well No. 4, Well No. 5, and Well No. 6.

A source water assessment was conducted for the water supply wells of the Laton Community Services water supply wells in July, 2001. The sources are considered most vulnerable to the following activities not associated with any detected contaminants: sewer collection systems, historic gas stations and agricultural/irrigation wells. A copy of the complete assessment may be viewed at Laton Community Services District, 6501 E. Latonia Street, Laton CA. You may request a summary of the assessment be sent to you by contacting Russell Dill, Operator, (559) 923-4802.

If you have any questions about this report or concerning your water utility, please contact Mr. Russell Dill, Operator, at (559) 923-4802. You may also write to Mr. Dill at Laton Community Services District, P. O. Box 447, Laton, CA 93242. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Wednesday of every month at 6:00 p.m. at the District Office, 6501 E. Latonia Street, Laton, CA.

The following are definitions of some of the TERMS USED IN THIS REPORT:

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Primary Drinking Water Standards (PDWS): MCLs or MRDLs for contaminants that affect health, along with their monitoring and reporting requirements, and water treatment requirements

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of drinking water. Supplies with elevated SDWS do not affect the health at the MCL levels.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Variations and Exemptions: State Department of Public Health (Department) permission to exceed an MCL or not comply with a treatment technique under certain conditions.

NA: not applicable.

ND: not detectable at testing limit.

ppm: parts per million or milligrams per liter (mg/l).

ppb: parts per billion or micrograms per liter (ug/l).

ppt: parts per trillion or nanograms per liter (ng/l).

pCi/l: picocuries per liter (a measure of radiation).

In general, sources of drinking water (both tap water and bottled water) may include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Constituents that may be present in source water to contamination levels include:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants, that can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U. S. Environmental Protection Agency (USEPA) and the State Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Laton Community Service District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The tables on the next page list all the drinking water constituents that were detected during the most recent samplings for the constituent. The presence of these constituents in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain constituents less than once per year because the concentrations of these constituents are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are therefore more than one year old.

SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Contamination
Total Coliform Bacteria	4	1	More than 1 sample in a month with a detection	0	Naturally present in the environment
<p>Total Coliform: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.</p> <p>The new Federal Ground Water Rule requires that each groundwater source must be sampled when a routine distribution bacteriological sample shows the presence of coliform bacteria. Coliforms were found in more samples than allowed during May 2012, and this was a warning of potential problems. No reason for the detection could be found and subsequent testing indicated no presence of coliforms. The District's groundwater sources were also sampled at this time and no coliform bacteria was detected. The District believes that the Total Coliform found was due to sampling error, weather conditions, or samples being taken after a power outage. The violation is classified as a non-continuing violation and public notification was completed on May 18, 2012 and June 1, 2012.</p>					

TEST RESULTS (A)

Lead and Copper Rule	No. of samples collected	MCLG	Action Level	90th percentile level detected	No. Sites Exceeding Action Level	Typical Source of Contamination
Lead (ppb)	10	2	15	ND	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	10	0.3	1.3	ND	0	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

RADIOACTIVE CONTAMINANTS (B)

Chemical or Constituent (and reporting units)	MCL	PHG (MCLG)	Sample Date	Average Level Detected	Range (B)	Likely Source of Contamination
Gross Alpha Activity (pCi/L)	15	N/A	2004, 2005 & 2011	2.36	0.48 to 3.31	Erosion of natural deposits

SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	MCL	PHG [MCLG]	Sample Date	Average Level Detected	Range	Likely Source of Contamination
Hardness (ppm)	None	None	2010 & 2011	60	42 to 70	Generally found in ground and surface water
Sodium (ppm)	None	None	2010 & 2011	22	20 to 24	Generally found in ground and surface water

DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	MCL	PHG [MCLG]	Sample Date	Average Level Detected	Range	Likely Source of Contamination
Nitrate as NO ₃ (ppm)	45	45	2012	2.4	2.6 to 2.7	Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	MCL	Sample Date	Average Level Detected	Range	Likely Source of Contamination	
Chloride (ppm)	500	2010 & 2011	10.5	3.4 to 14	Runoff/leaching from natural deposits; seawater influence	
Color (Units)	15	2010 & 2011	< 1	< 1	Naturally-occurring organic materials	
Specific Conductance (µS/cm)	1600	2011	163	150 to 170	Substances that form ions when in water; seawater influence	
Sulfate (ppm)	500	2010 & 2011	9.5	6.5 to 11	Runoff/leaching from natural deposits; industrial wastes	
Total Dissolved Solids (TDS) (ppm)	1000	2010 & 2011	132	95 to 150	Runoff/leaching from natural deposits	
Turbidity (Units)	5	2010 & 2011	< 0.1	< 0.1 to < 0.1	Soil runoff	

(A) Results reported due to regulatory requirement or detection of a constituent.

(B) Results reported include amounts that are less than the State Department of Public Health required detection level for this constituent.

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of constituents does not necessarily indicate that the water poses a health risk. More information about constituents, contaminant levels and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791 or their website <http://www.epa.gov/safewater/hfacts.html>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders and some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

LATON COMMUNITY SERVICES DISTRICT
P. O. BOX 447
LATON, CA 93242