


# Consumer Confidence Report Certification Form

Water System Name: **GOLDEN SANDS MOBILE HOME PARK**

Water System Number: **1900649**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 04/29/2013 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name Pete Munoz

Signature 

Title Red-Tail GWS Operator

Phone Number ( 805 ) 797-0320 Date 04/25/2013

*To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:*

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: \_\_\_\_\_

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

Posted the CCR on the internet at www. \_\_\_\_\_

Mailed the CCR to postal patrons within the service area (attach zip codes used)

Advertised the availability of the CCR in news media (attach copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

Posted the CCR in public places (attach a list of locations) Recreation Hall, Park Office.

Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools

Delivery to community organizations (attach a list of organizations)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. \_\_\_\_\_

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2012 Consumer Confidence Report

Water System Name: **GOLDEN SANDS MOBILE HOME  
PARK**

Report Date: April 2013

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2012*

**Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water sources(s) in use:** According to CDPH records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

**Your water comes from 1 source:** Well 2.

For more information about this report, or for any questions relating to your drinking water, please call (661) 251 - 8075 and ask for L.D. Flickinger Co., LLC, or visit our website at [www.ldflickingerco.com](http://www.ldflickingerco.com)

## **TERMS USED IN THIS REPORT:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, order, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter ( $\mu\text{g/L}$ )

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picograms per liter (pg/L)

**pCi/l:** picocuries per liter (a measure of radioactivity)

**The sources of drinking water**(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

# 2012 Consumer Confidence Report

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

**In order to ensure that tap water is safe to drink**, the U.S. Environmental Protection Agency (USEPA) and the California Department of Health Services (Department) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**Tables 1,2,3,4,5,6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	2/mo. (2012)	1	no more than 1 positive monthly sample	0	Naturally present in the environment.

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in the last sample set)	No. of Samples Collected	90th Percentile Level	No. Site Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (Pb) (ppb)	10 (2012)	0.70	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	10 (2012)	0.001	0	1.3	.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	2012	30	30 - 30	none	none	Salt present in the water and is generally naturally occurring

## 2012 Consumer Confidence Report

**TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Hardness (ppm)	2012	144	144 - 144	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Barium (Ba) ppm	2012	0.09	0.09 - 0.09	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (Total Cr) ppb	2012	9	9 - 9	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nitrate (NO <sub>3</sub> ) ppm	2012	6.6	7 - 7	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N ppm	2012	1.5	1.5 - 1.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (Se) ppb	2012	4.0	4 - 4	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha pCi/L	2011	1.4	0.7 - 3	15	n/a	Erosion of natural deposits.
Carbon Tetrachloride ppt	2012	40000	40000 - 40000	500	n/a	Discharge from chemical plants and other industrial activities
Total Radium 228 pCi/L	2011	0.02	ND - 0.06	5	n/a	Erosion of natural deposits

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Chloride ppm	2012	41	41 - 41	500	n/a	Runoff/leaching from natural deposits; seawater influence
Corrosivity (Langlier Index)	2012	-0.02	-0.02 - -0.02	> 0	n/a	Natural or industrial-influenced balance of hydrogen, carbon and oxygen in the water, affected by temperature and other factors.
Specific Conductance umhos/cm	2012	446	446 - 446	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (SO <sub>4</sub> ) ppm	2012	61	61 - 61	500	n/a	Runoff/leaching from natural deposits; industrial wastes

## 2012 Consumer Confidence Report

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
TDS ppm	2012	260	260 - 260	1000	n/a	Runoff/leaching from natural deposits

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

**TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Vanadium ppm	2012	0.01	0.01 - 0.01 (2012)	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

**TABLE 7 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) ppb	2012	40	ND - 80	80	n/a	By-product of drinking water disinfection

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

**For Lead (Pb)**, If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *GOLDEN SANDS MOBILE HOME PARK* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

# 2012 Consumer Confidence Report

---

---

---

---

---

---

---

---

## Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

**About our Total Coliform Bacteria:** Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

**About our Carbon Tetrachloride:** Some people who use water containing carbon tetrachloride in excess of the MCL over many years may experience liver problems, and may have an increased risk of getting cancer.

**About our Corrosivity (Langlier Index):** Corrosivity less than 0 indicates your water may be corrosive to the plumbing and fixtures. The Corrosivity MCL was set to protect you against unpleasant aesthetic affects such as color, taste and odor. Violating this MCL does not pose a risk to public health.

## Drinking Water Source Assessment Information

### Assessment Info

A source water assessment was conducted for the WELL 02 of the GOLDEN SANDS MOBILE HOME PARK water system in January, 2002.

Well 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:

Above ground storage tanks

Housing - high density [>1 house/0.5 acres]

### Discussion of Vulnerability

Well 02 - has shown to be at most vulnerable to the chemicals: None

At this time, no chemicals have been detected that will affect the quality of the drinking water.

### Acquiring Info

A copy of the complete assessment may be viewed at:

Golden Sands Mobile Home Park

2059 East Avenue I

Lancaster, CA 93534

The Consumer Confidence Report is posted on a bulletin board in the Common Area Club House. Within this building it is accessible to the general public and all persons effected by ground water Well 02 water system number 1900649.

You may request a summary of the assessment be sent to you by contacting:

Vince Gallegos

Environmental Health Specialist III

County of Los Angeles Public Health Water Quality Program

5050 Commerce Drive

Baldwin Park, CA 91706

Tel (626) 430-5420

Fax(627) 813-3016