

RECEIVED

ATTACHMENT 7

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

JUL 26 2013

Drinking Water Program Santa Rosa Office

Water System Name: City of Fort Bragg

Water System Number: 2310001

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 2013 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the California Department of Public Health.

Certified by: Name: Heath Daniels
Signature: [Handwritten Signature]
Title: Lead Operator
Phone Number: (707)961-4141 Date: 7/17/13

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

[x] CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Was mailed to all water accounts in the June Water bill. Hand delivered to all addresses where customer does not pay for there own water

[x] "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- [x] Posting the CCR on the Internet at www. http://city.fortbragg.com/
[] Mailing the CCR to postal patrons within the service area (attach zip codes used)
[] Advertising the availability of the CCR in news media (attach copy of press release)
[] Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
[x] Posted the CCR in public places (attach a list of locations)
[x] Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
[x] Delivery to community organizations (attach a list of organizations)
[x] Other (attach a list of other methods used)

[] For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

[] For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

CITY OF FORT BRAGG
 416 N. FRANKLIN, FORT BRAGG, CA 95437
 PHONE 707/961-4141 FAX 707/961-2838

MEMORANDUM

DATE: July 17, 2013
TO: Yan Nusinovich, CDPH
FROM: Heath Daniels, Lead Treatment Operator Water
SUBJECT: **CCR Distribution List**

Quantity	Recipient	Distribution Method
2832	Those holding a water account with the City	Postal service
567	Residents of apartment complexes and mobile home parks that don't directly receive water bills from the City. (The property owners receive the water bills.)	By hand
10	Public library	By hand
1	Mendocino Co. Department of Public Health	By hand
On going	City Water Plant	By hand
On going	Department of Public Works (to be available upon request)	By hand
20	City Hall (in the Finance Department lobby public access display table)	By hand
10	Town Hall	By hand
1	Fort Bragg Dialysis	By Hand
1	Department of Health Services (Santa Rosa field office)	Postal service
On going	Anyone who requests a copy	Postal service / by hand
10	Chamber of Commerce	By Hand
Total	3452	

For additional information, contact Heath Daniels (707) 961-4141

RECEIVED

JUL 26 2013

**Drinking Water Program
 Santa Rosa Office**



Handwritten text at the top of the page, possibly a title or header.

Handwritten text on the right side of the page.

Main body of handwritten text, appearing to be a list or series of entries.

Large block of handwritten text, possibly a detailed list or a long paragraph.

Handwritten text at the bottom left of the page.

Handwritten text at the bottom center of the page.

Handwritten text at the bottom right of the page.

2012 Consumer Confidence Report

CCR

City of Fort Bragg
416 N. Franklin St.
Fort Bragg, Ca 95437

2012 Consumer Confidence Report

Water System Name: City of Fort Bragg Report Date: 5/7/2013

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2012 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Surface Water

Name & location of source(s): The City has three water sources- Noyo River located off Madsen Lane, Water Fall Gulch located off Simpson Lane, Newman Reservoir located off Summers Lane.

Drinking Water Source Assessment information: An assessment was conducted in April 2008 by a certified

Hydrologist. The City's raw water sources are of high quality due to the relative health of our watersheds compared to those in more populated or industrialized areas. All natural water contains dissolved minerals and organic matter. Our source waters contain naturally occurring inorganics and organic matter from native soils. The City's source waters remain vulnerable to the effects of urbanization, road construction, applied and stored chemicals and petroleum, septic systems, agriculture, and illegal dumping activity. A copy of this assessment is available at Fort Bragg City Hall, 416 N. Franklin St.

Time and place of regularly scheduled board meetings for public participation: 6:00 pm at Town Hall on the second and fourth Mondays of the month.

For more information, contact: Heath Daniels Phone: (707)961-4141

TERMS USED IN THIS REPORT

<p>Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p> <p>Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).</p> <p>Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p> <p>Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.</p> <p>Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.</p>	<p>Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p> <p>Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.</p> <p>Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.</p> <p>Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p> <p>Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.</p> <p>ND: not detectable at testing limit</p> <p>ppm: parts per million or milligrams per liter (mg/L)</p> <p>ppb: parts per billion or micrograms per liter (µg/L)</p> <p>ppt: parts per trillion or nanograms per liter (ng/L)</p> <p>ppq: parts per quadrillion or picogram per liter (pg/L)</p> <p>pCi/L: picocuries per liter (a measure of radiation)</p>
--	--

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.)	0	More than 1 sample in a month with a detection	0	Naturally present in the environment

Fecal Coliform or <i>E. coli</i>	(In the year)	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste
----------------------------------	---------------	---	--	---	------------------------------

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	20	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	20	0.16	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	8/28/2012	11.3	11 - 12	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	8/28/2012	26.6	9 - 62	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Aluminum (ppm)	8/28/2012	0.108	ND - 0.160	1.0	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Fluoride (ppm)	8/28/2012	0.15	ND - 0.14	2.0	1.0	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	9/6/2006	0.48	0.36 - 0.59	15.0	0	Erosion of natural deposits
Turbidity (NTU)	8/28/2012	1.46	0.68 - 2.3	TT	NA	Soil runoff
Haloacetic Acids (ppb)	2012	26.2	17.5 – 35.3	60	NA	Byproduct of drinking water disinfection
TTHMs (Total Trihalomethanes) (ppb)	2012	25.9	13.79 – 34.47	80	NA	Byproduct of drinking water disinfection

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ppb)	8/28/2012	108	ND - 160	200	NA	Erosion of natural deposits; residue from some surface water treatment processes
Chloride (ppm)	8/28/2012	12.6	8.7 - 15	500	NA	Runoff/leaching from natural deposits; seawater influence
Color (units)	8/28/2012	11	7.0 - 17	15	NA	Naturally-occurring organic materials
Iron (ppb)	8/28/2012	150	ND - 160	300	NA	Leaching from natural deposits; industrial wastes
Manganese (ppb)	8/28/2012	34	ND - 34	50	NA	Leaching from natural deposits; industrial wastes
Odor-Threshold (units)	8/28/2012	3.5	ND - 4.1	3	NA	Naturally occurring organic materials

Specific Conductance (uS/cm)	8/28/2012	113	79 - 170	1600	NA	Substances that form ions when in water; seawater influence
Sulfate (ppm)	8/28/2012	3.27	2.3 - 4.6	500	NA	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	8/28/2012	79	64 - 100	1000	NA	Runoff/leaching natural deposits
Turbidity (NTU)	8/28/2012	1.46	0.68 - 2.3	5	NA	Soil runoff

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing City of Fort Bragg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

For Systems Providing Surface Water as a Source of Drinking Water

Treatment Technique ^(a) (Type of approved filtration technology used)	
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 - Be less than or equal to <u>0.20</u> NTU in 95% of measurements in a month. 2 - Not exceed <u>0.20</u> NTU for more than eight consecutive hours. 3 - Not exceed <u>1.0</u> NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100%
Highest single turbidity measurement during the year	0.150
Number of violations of any surface water treatment requirements	0

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

* Any violation of a TT is marked with an asterisk. Additional information regarding the violation is provided below.