

# 2012 Consumer Confidence Report

## Creekbridge Mutual Water Company

### June 26, 2013

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2012.

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source:** The water used in Creekbridge Water Company consisted of one well located east of the Creekbridge subdivision.

**Drinking Water Source Assessment:** A source assessment was conducted for the Well 01 of the Creekbridge Mutual Water Company water system in August 2002. Well 01 is considered most vulnerable to high-density septic systems and storm drain discharge points. These activities are associated with the contaminate nitrate, which has been detected in the water supply. In addition, Well 01 is considered vulnerable to the following activity not associated with any detected contaminants: transportation corridors – roads/streets.

**For more information, contact:** MCSI Water Systems Management      Phone: (831) 659-5360  
Fax: (831) 659-3166

#### TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural activities and septic systems.
- *Radioactive contaminants*, that can be naturally occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the U.S. Environmental Protection Agency (USEPA) and California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Water Quality Data Tables**

**The tables below list all of the drinking water contaminants that we detected during the most recent sampling for the constituent.** The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Contaminant(s) (units)	Highest # Detected in a Month	# Of Months in Violation	MCL	MCLG	Typical Source
Total Coliform	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform/E coli	0	0	A routine sample and repeat sample detect total coliform and either sample also detects fecal coliform or E. coli	0	Human & animal fecal waste

SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Contaminant(s) (units)	Number of Site Collected	PHG	AL	90 <sup>th</sup> Percentile Level Detected	# of Samples > AL	Date	Typical Source
Copper (ppm)	5	0.17	1.3	0.125	0	8/2010	Erosion of natural deposits; leaching from wood preservatives; internal corrosion of household plumbing systems
Lead (ppb)	5	0.2	15	ND	0	8/2010	Internal corrosion of household plumbing systems; erosion of natural deposits

SAMPLE RESULTS SHOWING DISINFECTION BYPRODUCTS					
Contaminant(s) (units)	PHG/(MCLG)	MCL	Level Detected	Sample Date	Typical Source
Total Trihalomethanes (ppb)	N/A	80	1.2	8/2012	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Total Haloacetic Acids (ppb)	N/A	60	ND	8/2012	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits

<b>SAMPLING RESULTS SHOWING THE DETECTION OF RADIOACTIVITY</b>					
<b>Contaminant(s) (units)</b>	<b>PHG/ (MCLG)</b>	<b>MCL</b>	<b>Level Detected</b>	<b>Sample Date</b>	<b>Typical Source</b>
Gross Alpha (pCi/L)	(0)	15	5.88	6/2010	Erosion of natural deposits
Uranium (pCi/L)	0.43	20	4.91	2006	Erosion of natural deposits

<b>DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>					
<b>Contaminant(s) (units)</b>	<b>PHG/ (MCLG)</b>	<b>MCL</b>	<b>Level Detected AVG</b>	<b>Sample Date</b>	<b>Typical Source</b>
Arsenic (ppb)	0.004	10	1	6/2011	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	2	1	0.022	6/2011	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium –Total (ppb)	(100)	50	17	6/2011	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	1	2	0.30	6/2011	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (NO <sub>3</sub> ) (ppm)	45	45	9	5/2012	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ppb)	30	50	5	6/2011	Discharge from petroleum, glass and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Turbidity (NTU)	N/A	5	0.05	6/2011	Soil runoff

<b>DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b>					
<b>Contaminant(s) (units)</b>	<b>PHG/ (MCLG)</b>	<b>MCL</b>	<b>Level Detected</b>	<b>Sample Date</b>	<b>Typical Source</b>
Chloride (ppm)	N/A	500	110	6/2011	Runoff/leaching from natural deposits; sea water influence
Copper (ppm)	N/A	15	7	6/2011	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Iron (ppb)	N/A		28	6/2011	Leaching from natural deposits; industrial wastes
Odor (units)	N/A	3	2	6/2011	Naturally-occurring organic materials
Specific Conductivity	N/A	1600	1340	6/2011	Substances that form natural deposits; sea water influence
Sulfate (ppm)	N/A	500	260	6/2011	Runoff/leaching from natural deposits; industrial waste
Total Dissolved Solids (ppm)	N/A	1000	838	6/2011	Runoff/leaching from natural deposits

<b>OTHER SUBSTANCES OF INTEREST</b>					
<b>Chemical or Constituent (units)</b>	<b>PHG (MCLG)</b>	<b>MCL</b>	<b>Level Detected</b>	<b>Sample Date</b>	<b>Typical Source</b>
Alkalinity as CaCO <sub>3</sub> (ppm)	N/A	N/A	290	6/2011	Generally found in ground and surface water
Sodium (ppm)	N/A	N/A	130	6/2011	Salt present in the water and is generally naturally occurring
Total Hardness (ppm)	N/A	N/A	413	6/2011	Sum of polyvalent cations present in the water, generally magnesium and calcium and are usually naturally occurring
pH	N/A	N/A	7.6	6/2011	A measurement of acidity, 7.0 being neutral

SAMPLING RESULTS FOR UNREGULATED CONTAMINANTS				
Contaminant(s) (units)	AL	Level Detected	Sample Date	Typical Source
Chromium VI (ppb)	N/A	6.4	4/2003	Runoff/leaching from natural deposits

### Additional Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (1-800-426-4791).

Lead – Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Creekbridge Mutual Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### Monitoring and reporting violations:

- None

#### Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Violation of Ground Water TT

- None

#### For Systems Providing Surface Water as a Source of Drinking Water:

- The system does not provide surface water.

#### System Improvements and Updates:

- Maggiora Bros. Drilling is responsible for repairs daily operations. Please contact them at (831) 734-1338 for details.