

Consumer Confidence Report Certification Form

Water System Name: **Rio Plaza Water Co Inc**
Water System Number: **5610010**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name _____

Signature _____

Title _____

Phone Number (_____) _____ Date _____

=====

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

___ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: _____

___ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

___ Posted the CCR on the internet at www. _____

___ Mailed the CCR to postal patrons within the service area (attach zip codes used)

___ Advertised the availability of the CCR in news media (attach copy of press release)

___ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

___ Posted the CCR in public places (attach a list of locations)

___ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools

___ Delivery to community organizations (attach a list of organizations)

___ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. _____

___ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2012 Consumer Confidence Report

Water System Name: **Rio Plaza Water Co Inc**

Report Date: **March 2013**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2012

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water sources(s) in use: According to CDPH records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 sources: Well #2 and Well #3.

For more information about this report, or for any questions relating to your drinking water, please call (805)525-4200 and ask for Frank.

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picograms per liter (pg/L)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2012 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Health Services (Department) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2,3,4,5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in the last sample set)	No. of Samples Collected	90th Percentile Level	No. Site Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (Pb) (ppb)	12 (2010)	0.80	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	12 (2010)	0.275	0	1.3	.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	2010	97	97 - 97	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2010	568	568 - 568	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

2012 Consumer Confidence Report

TABLE 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Barium (Ba) ppm	2010	0.02	0.02 - 0.02	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Nitrate (NO3) ppm	2012	17.1	17 - 18	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N ppm	2010	4.7	4.7 - 4.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (Se) ppb	2010	7.0	7 - 7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha pCi/L	2008	7.2	7 - 7	15	n/a	Erosion of natural deposits.
Uranium pCi/L	2008	3.0	2 - 4	20	0.5	Erosion of natural deposits

TABLE 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Chloride ppm	2010	51	51 - 51	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Unfiltered) Units	2010	5	5 - 5	15	n/a	Naturally-occurring organic materials
Iron (Fe) ppb	2010	160	200 - 200	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance umhos/cm	2010	1360	1360 - 1360	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (SO4) ppm	2010	460	460 - 460	500	n/a	Runoff/leaching from natural deposits; industrial wastes
TDS ppm	2010	1000	1000 - 1000	1000	n/a	Runoff/leaching from natural deposits

TABLE 5 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Boron ppm	2010	0.7	0.7 - 0.7 (2010)	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

2012 Consumer Confidence Report

TABLE 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Chromium VI (Hexavalent Chromium) ppb	2011	0.2	0.2 - 0.2 (2011)	n/a	n/a
Vanadium ppm	2010	0.002	0.002 - 0.002 (2010)	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

TABLE 6 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Haloacetic Acids (five) ppb	2010	4	4 - 4	60	n/a	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *Rio Plaza Water Co Inc* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

2012 Consumer Confidence Report

Drinking Water Source Assessment Information

Assessment Info

A source water assessment was conducted for the WELL 02 and the WELL 03 of the RIO PLAZA WATER CO INC water system in August, 2001.

Well 02 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Septic systems - high density [$>1/\text{acre}$]

Well 03 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Septic systems - high density [$>1/\text{acre}$]

Acquiring info

A copy of the complete assessment may be viewed at:
DHS Drinking Water Field Operations Branch
1180 Eugenia Place
Suite 200
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
Kurt Souza
District Engineer
805 566 1326

Rio Plaza Water Co Inc

Analytical Results By FGL - 2012

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead (Pb)		ppb	0	15	0.2			0.80	12
STW-3	SP 1009095-001	ppb				09/03/2010	0.300		
1025 Will	SP 1008718-009	ppb				08/17/2010	0.400		
344 Helsam	SP 1008718-011	ppb				08/17/2010	0.500		
994 Helsam	SP 1008718-001	ppb				08/17/2010	0.00		
1017 Lemar	SP 1008718-007	ppb				08/16/2010	0.700		
1035 Salem	SP 1008718-005	ppb				08/16/2010	0.900		
3321 Citrus	SP 1008718-006	ppb				08/16/2010	0.300		
3411 Balboa	SP 1008718-010	ppb				08/16/2010	0.300		
3486 Cortey	SP 1008718-004	ppb				08/16/2010	0.00		
401 Will	SP 1008718-008	ppb				08/16/2010	0.800		
808 Simon	SP 1008718-003	ppb				08/16/2010	1.10		
971 Helsam	SP 1008718-002	ppb				08/16/2010	0.200		
Copper		ppm		1.3	.17			0.275	12
STW-3	SP 1009095-001	ppm				09/03/2010	0.00		
1025 Will	SP 1008718-009	ppm				08/17/2010	0.560		
344 Helsam	SP 1008718-011	ppm				08/17/2010	0.137		
994 Helsam	SP 1008718-001	ppm				08/17/2010	0.0290		
1017 Lemar	SP 1008718-007	ppm				08/16/2010	0.227		
1035 Salem	SP 1008718-005	ppm				08/16/2010	0.100		
3321 Citrus	SP 1008718-006	ppm				08/16/2010	0.275		
3411 Balboa	SP 1008718-010	ppm				08/16/2010	0.270		
3486 Cortey	SP 1008718-004	ppm				08/16/2010	0.0360		
401 Will	SP 1008718-008	ppm				08/16/2010	0.0870		
808 Simon	SP 1008718-003	ppm				08/16/2010	0.479		
971 Helsam	SP 1008718-002	ppm				08/16/2010	0.0670		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			97	97 - 97
STW-3	SP 1009095-001	ppm				09/03/2010	97.0		
Hardness		ppm		none	none			568	568 - 568
STW-3	SP 1009095-001	ppm				09/03/2010	568		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Barium (Ba)		ppm	2	1	2			0.02	0.02 - 0.02
STW-3	SP 1009095-001	ppm				09/03/2010	0.0235		
Nitrate (NO3)		ppm		45	45			17.1	17 - 18
STW-3	SP 1208364-001	ppm				08/17/2012	16.7		
STW-2	SP 1208365-001	ppm				08/17/2012	17.5		
Nitrate + Nitrite as N		ppm		10	10			4.7	4.7 - 4.7
STW-3	SP 1009095-001	ppm				09/03/2010	4.70		
Selenium (Se)		ppb	50	50	30			7.0	7 - 7
STW-3	SP 1009095-001	ppb				09/03/2010	7.00		
Gross Alpha		pCi/L		15				7.2	7 - 7
STW-2	SP 0809167-003	pCi/L				08/22/2008	6.85		
STW-3	SP 0809167-004	pCi/L				08/22/2008	7.45		
Uranium		pCi/L		20	0.5			3.0	2 - 4
STW-2	SP 0809167-003	pCi/L				08/22/2008	3.68		
STW-3	SP 0809167-004	pCi/L				08/22/2008	2.31		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500				51	51 - 51

Rio Plaza Water Co Inc

Analytical Results By FGL - 2012

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride									
STW-3	SP 1009095-001	ppm				09/03/2010	51.0		
Color (Unfiltered)		Units		15				5	5 - 5
STW-3	SP 1009095-001	Units				09/03/2010	5.00		
Iron (Fe)		ppb		300				160	200 - 200
STW-3	SP 1009095-001	ppb				09/03/2010	160		
Specific Conductance		umhos/cm		1600				1360	1360 - 1360
STW-3	SP 1009095-001	umhos/cm				09/03/2010	1360		
Sulfate (SO4)		ppm		500				460	460 - 460
STW-3	SP 1009095-001	ppm				09/03/2010	460		
TDS		ppm		1000				1000	1000 - 1000
STW-3	SP 1009095-001	ppm				09/03/2010	1000		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		ppm		NS				0.7	0.7 - 0.7
STW-3	SP 1009095-001	ppm				09/03/2010	0.700		
Chromium VI (Hexavalent Chromium)		ppb		NS				0.2	0.2 - 0.2
STW-2	SP 1104879-001	ppb				05/17/2011	0.210		
STW-3	SP 1104879-002	ppb				05/17/2011	0.180		
Vanadium		ppm		NS				0.002	0.002 - 0.002
STW-3	SP 1009095-001	ppm				09/03/2010	0.00200		

FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Haloacetic Acids (five)		ppb		60	n/a			4	4 - 4
3460 George	SP 1008710-002	ppb				08/26/2010	4.00		

Rio Plaza Water Co Inc CCR Login Linkage - 2012

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
10147 Lemar	11/06/2007	SP 0712597-003	Metals, Total	1017 Lemar	Drinking Water Monitoring
1017 Lemar	08/16/2010	SP 1008718-007	Metals, Total	1017 Lemar	EPA Lead & Copper Monitoring
1025 Will	11/06/2007	SP 0712597-002	Metals, Total	1025 Will	Drinking Water Monitoring
	08/17/2010	SP 1008718-009	Metals, Total	1025 Will	EPA Lead & Copper Monitoring
1035 Salem	11/02/2007	SP 0712290-003	Metals, Total	1035 Salem	Water Monitoring
	08/16/2010	SP 1008718-005	Metals, Total	1035 Salem	EPA Lead & Copper Monitoring
3321 Citrus	11/02/2007	SP 0712290-001	Metals, Total	3321 Citrus	Water Monitoring
	08/16/2010	SP 1008718-006	Metals, Total	3321 Citrus	EPA Lead & Copper Monitoring
3411 Balboa	11/06/2007	SP 0712597-001	Metals, Total	3411 Balboa	Drinking Water Monitoring
	08/16/2010	SP 1008718-010	Metals, Total	3411 Balboa	EPA Lead & Copper Monitoring
344 Helsam	08/17/2010	SP 1008718-011	Metals, Total	344 Helsam	EPA Lead & Copper Monitoring
3450 George	08/19/2004	SP 0408532-001	EPA 551.1	3450 George	Water Quality Monitoring
	08/20/2004	SP 0408571-001	EPA 552.2	3450 George	Drinking Water Monitoring
3460 George	08/17/2007	SP 0709261-002	EPA 551.1	3460 George	Drinking Water Monitoring
	08/17/2007	SP 0709261-002	EPA 552.2	3460 George	Drinking Water Monitoring
	08/26/2010	SP 1008710-002	EPA 551.1	3460 George	Drinking Water Monitoring
	08/26/2010	SP 1008710-002	EPA 552.2	3460 George	Drinking Water Monitoring
	03/13/2012	SP 1202562-001	Coliform	3460 George	Bacteriological Monitoring-George St.
	04/13/2012	SP 1203651-001	Coliform	3460 George	Bacteriological Monitoring
	05/17/2012	SP 1204918-001	Coliform	3460 George	Bacteriological Monitoring
	06/12/2012	SP 1205893-001	Coliform	3460 George	Bacteriological Monitoring
	07/18/2012	SP 1207164-001	Coliform	3460 George	Bacteriological Monitoring-St. George
	08/17/2012	SP 1208363-001	Coliform	3460 George	Bacteriological Monitoring
	09/13/2012	SP 1209361-001	Coliform	3460 George	Bacteriological Monitoring
	10/17/2012	SP 1210635-001	Coliform	3460 George	Bacteriological Monitoring
	11/13/2012	SP 1211631-001	Coliform	3460 George	Bacteriological Monitoring
12/12/2012	SP 1212675-001	Coliform	3460 George	Bacteriological Monitoring	
3460 George St.	01/11/2012	SP 1200357-001	Coliform	3460 George St.	Bacteriological Monitoring
	02/07/2012	SP 1201238-001	Coliform	3460 George	Bacteriological Monitoring
3475 Menna	01/11/2012	SP 1200357-002	Coliform	3475 Menna	Bacteriological Monitoring
	02/07/2012	SP 1201238-002	Coliform	3475 Menna	Bacteriological Monitoring
	03/13/2012	SP 1202562-002	Coliform	3475 Menna	Bacteriological Monitoring-George St.
	04/13/2012	SP 1203651-002	Coliform	3475 Menna	Bacteriological Monitoring
	05/17/2012	SP 1204918-002	Coliform	3475 Menna	Bacteriological Monitoring
	06/12/2012	SP 1205893-002	Coliform	3475 Menna	Bacteriological Monitoring
	07/18/2012	SP 1207164-002	Coliform	3475 Menna	Bacteriological Monitoring-St. George
	08/17/2012	SP 1208363-002	Coliform	3475 Menna	Bacteriological Monitoring
	09/14/2012	SP 1209361-002	Coliform	3475 Menna	Bacteriological Monitoring
	10/17/2012	SP 1210635-002	Coliform	3475 Menna	Bacteriological Monitoring
11/13/2012	SP 1211631-002	Coliform	3475 Menna	Bacteriological Monitoring	
12/12/2012	SP 1212675-002	Coliform	3475 Menna	Bacteriological Monitoring	
3486 Cortey	11/02/2007	SP 0712290-002	Metals, Total	3486 Cortey	Water Monitoring
	08/16/2010	SP 1008718-004	Metals, Total	3486 Cortey	EPA Lead & Copper Monitoring
3950	08/26/2005	SP 0508924-005	EPA 551.1	3950 George	Water Monitoring
3950 George	08/26/2005	SP 0508924-004	EPA 552.2	3950 George	Water Monitoring
401 Will	08/16/2010	SP 1008718-008	Metals, Total	401 Will	EPA Lead & Copper Monitoring
808 Simon	11/13/2007	SP 0712736-001	Metals, Total	808 Simon	Drinking Water Monitoring
	08/16/2010	SP 1008718-003	Metals, Total	808 Simon	EPA Lead & Copper Monitoring
971 Helsam	08/16/2010	SP 1008718-002	Metals, Total	971 Helsam	EPA Lead & Copper Monitoring
971 Helsom	11/02/2007	SP 0712290-004	Metals, Total	971 Helsom	Water Monitoring
994 Helsam	08/17/2010	SP 1008718-001	Metals, Total	994 Helsam	EPA Lead & Copper Monitoring
994 Helson	11/13/2007	SP 0712736-002	Metals, Total	994 Helson	Drinking Water Monitoring
Res. #1	03/11/2009	SP 0902396-002	EPA 524.2	Res. #1	Drinking Water Monitoring
STW-2	03/16/2007	SP 0702786-001	Metals, Total	Well 02	Well #2
	03/16/2007	SP 0702786-001	Wet Chemistry	Well 02	Well #2
	06/22/2007	SP 0707078-001	EPA 524.2	Well 02	Rio Plaza Water Co/Wells 02 + 03
	06/22/2007	SP 0707078-001	Radio Chemistry	Well 02	Rio Plaza Water Co/Wells 02 + 03
	06/22/2007	SP 0707078-001	Wet Chemistry	Well 02	Rio Plaza Water Co/Wells 02 + 03
	11/02/2007	SP 0712290-006	Wet Chemistry	Well 02	Water Monitoring

Rio Plaza Water Co Inc CCR Login Linkage - 2012

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
STW-2	11/16/2007	SP 0712872-003	General Mineral	Well 02	Drinking Water Monitoring
	08/22/2008	SP 0809167-003	Radio Chemistry	Well 02	Drinking Water Monitoring
	08/22/2008	SP 0809167-003	Wet Chemistry	Well 02	Drinking Water Monitoring
	08/12/2009	SP 0908077-003	Wet Chemistry	Well 02	RIO PLAZA WATER CO INC
	09/03/2010	SP 1009094-001	EPA 507	Well 02	Well 2 - Water Quality
	09/03/2010	SP 1009094-001	Wet Chemistry	Well 02	Well 2 - Water Quality
	05/17/2011	SP 1104879-001	Wet Chemistry	Well 02	Perchlorate Monitoring
	09/06/2011	SP 1109081-001	Wet Chemistry	Well 02	Well 2 - Water Quality
	01/11/2012	SP 1200356-001	Coliform	Well 02	Well 2 - Bacteriological
	04/13/2012	SP 1203652-001	Coliform	Well 02	Well 2 - Bacteriological
	07/18/2012	SP 1207163-001	Coliform	Well 02	Well 2 - Bacteriological
	08/17/2012	SP 1208365-001	Wet Chemistry	Well 02	Well 2 - Water Quality
10/17/2012	SP 1210636-001	Coliform	Well 02	Well 2 - Bacteriological	
STW-3	06/22/2007	SP 0707078-002	Radio Chemistry	Well 03 (1B)	Rio Plaza Water Co/Wells 02 + 03
	11/02/2007	SP 0712290-007	Wet Chemistry	Well 03 (1B)	Water Monitoring
	08/22/2008	SP 0809167-004	EPA 507	Well 03 (1B)	Drinking Water Monitoring
	08/22/2008	SP 0809167-004	Radio Chemistry	Well 03 (1B)	Drinking Water Monitoring
	08/22/2008	SP 0809167-004	Wet Chemistry	Well 03 (1B)	Drinking Water Monitoring
	08/13/2009	SP 0908077-004	Wet Chemistry	Well 03 (1B)	RIO PLAZA WATER CO INC
	09/03/2010	SP 1009095-001	EPA 524.2	Well 03 (1B)	Well 3 - Water Quality
	09/03/2010	SP 1009095-001	General Mineral	Well 03 (1B)	Well 3 - Water Quality
	09/03/2010	SP 1009095-001	Metals, Total	Well 03 (1B)	Well 3 - Water Quality
	09/03/2010	SP 1009095-001	Radio Chemistry	Well 03 (1B)	Well 3 - Water Quality
	09/03/2010	SP 1009095-001	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality
	05/17/2011	SP 1104879-002	Wet Chemistry	Well 03 (1B)	Perchlorate Monitoring
	08/18/2011	SP 1108354-001	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality
	01/11/2012	SP 1200355-001	Coliform	Well 03 (1B)	Well 3 - Bacteriological
	04/13/2012	SP 1203653-001	Coliform	Well 03 (1B)	Well 3 - Bacteriological
	07/18/2012	SP 1207167-001	Coliform	Well 03 (1B)	Well 3 - Bacteriological
	08/17/2012	SP 1208364-001	Radio Chemistry	Well 03 (1B)	Well 3 - Water Quality
	08/17/2012	SP 1208364-001	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality
10/17/2012	SP 1210640-001	Coliform	Well 03 (1B)	Well 3 - Bacteriological	
Well #2	08/25/2006	SP 0608610-002	Wet Chemistry	Well #2	Water Monitoring
Well #3	08/25/2006	SP 0608610-001	Wet Chemistry	Well #3	Water Monitoring