Angler's Ranch Water Company #3
P.O. Box 854
Bethel Island, California 94511
925-301-9883

July 23, 2013

Subject: FY2013 Consumer Confidence Report
Dear Members,

In accordance with Title 22 of the California Code of Regulations, we are required to provide our members with a yearly Consumer Confidence Report delineating the details of our water quality. The revised requirements of Title 22 states that we need only report and comment on any constituent which exceeds the Maximum Contaminant Level (MCL).

I am please to report that test results indicate we have not exceeded the MCL for any Primary Drinking Water Standards (PDWS), which affect health. The only MCL exceeded was for the Secondary Drinking Water Standards (SDWS) for Manganese, however SDWS do not affect health, but only the taste, odor, and appearance of the water.

Please see the attached test results.

Sincerely,

Dennis Eisenbeis
Secretary-Treasurer

attachment

California State Certified Laboratory No. 2153

CERCO analytical
1100 Willow Pass Court, Suite A
Concord, CA 94520-1006
925 462 2771 Fax. 925 462 2775
www.cercoanalytical.com

Mr. Dennis Eisenbeis
Angler's Ranch Wtr Co. #3
P.O. Box 854
Bethel Island, CA 94511-0854

Sample Source:
Angler's Ranch Wtr Co.#3
2118 Taylor Rd.
Bethel Island, CA
Matrix: Drinking Water
Date Sampled: 06/25/2013

June 28, 2013
Job No.: 1306188
LabNo.: 001
Cust. No.: 15
Schedule: Monthly

Analyte	Results	Detection Limit	Method	Date Analyzed
LabNo.: 001				
Sample I.D.: Upper Hosebib at Pumphouse				
Total Coliform Bacteria*	Absent	--	Colilert™	06/25-26/13
E. coli*	Absent	--	Colilert™	06/25-26/13

* 40 CFR Part 141 ; Chromogenic/Fluorogenic Substrate - Coliforms per 100 mL

Cheryl McMillen
Laboratory Director

Quality Control Summary - All laboratory quality control parameters were found to be within established limits.

cc: CCC Health Services

anglersranch3@yahoo.com
d_eisenbeis@yahoo.com

CERCO Analytical, Inc. EDT
1100 Willow Pass Court, Suite A
Concord, CA 94520-1006

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

Date of Report: 13/06/28 Sample ID No.1306188-001
Laboratory Signature Lab
Name: CERCO ANALYTICAL Director:
Name of Sampler:R. Langford Employed By: CERCO Analytical, Inc.
Date/Time Sample Collected:13/06/25/1045 Date/Time Sample Received @ Lab:13/06/25/1550 Date Analyses Completed:13/06/25

System Name:ANGLER S RANCH #3 System Number: 0707501
Name or Number of Sample Source:WELL 02

User ID: 07C Station Number: 0707501-001
Date/Time of Sample: |13|06|25|1045| Laboratory Code: 1675
YY MM DD TTTT YY MM DD
Date Analysis completed: |13|06|25|
Submitted by: Phone #: 462-2771

MCL	REPORTING UNITS	CHEMICAL	ENTRY #	ANALYSES RESULTS	DLR
	mg/L	Total Hardness (as CaCO3) (mg/L)	00900		
	mg/L	Calcium (Ca) (mg/L)	00916		
	mg/L	Magnesium (Mg) (mg/L)	00927		
	mg/L	Sodium (NA) (mg/L)	00929		
	mg/L	Potassium (K) (mg/L)	00937		
Total Cations		Meq/L Value:			
	mg/L	Total Alkalinity (AS CaCO3) (mg/L)	00410		
	mg/L	Hydroxide (OH) (mg/L)	71830		
	mg/L	Carbonate (CO3) (mg/L)	00445		
	mg/L	Bicarbonate (HCO3) (mg/L)	00440		
*	mg/L+	Sulfate (SO4) (mg/L)	00945		.5
*	mg/L+	Chloride (Cl) (mg/L)	00940		
45	mg/L	Nitrate (as NO3) (mg/L)	71850	ND	2.0
2 .	mg/L	Fluoride (F) (Natural-Source)	00951		.1
Total Anions		Meq/L Value: 0.00			
	Std.Units+	PH (Laboratory) (Std.Units)	00403		
***	umho/cm+	Specific Conductance (E.C.) (umhos/cm)	00095		
****	mg/L+	Total Filterable Residue@180C(TDS)(mg/L)	70300		
15	Units	Apparent Color (Unfiltered) (Units)	00081		
3	TON	Odor Threshold at 60 C (TON)	00086		1.
5	NTU	Lab Turbidity (NTU)	82079		
0.5	mg/L+	MBAS (mg/L)	38260		

* 250-500-600 ** 0.6-1.7 *** 900-1600-2200 **** 500-1000-1500