

# 2013 Consumer Confidence Report

Branding Iron Mutual Water Company & Public Water System Number 1700542

July 1, 2014

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

## Branding Iron MWC Source Information:

Type of Water Source in Use: Groundwater  
Name & Location of Source: Well 01, Located in Kelseyville, CA

### Drinking Water Source Assessment Information:

An assessment of the drinking water source for Branding Iron MWC was conducted by the State Health Department in December, 2002. The well was determined to be located within 30 feet of a flowing creek, although not associated with any detected contaminants. The source is considered most vulnerable to the presence of certain transportation corridors, including state highways/freeways. A copy of the complete assessment is available at the California Dept of Health Services, 50 D St, Rm 200, Santa Rosa, CA 95404. The phone number is (707) 576-2145.

Branding Iron MWC  
Holds Quarterly Board Meetings

\* ~ \*

For More Information About Meetings, This  
Report or Water Quality at Branding Iron  
MWC

Contact Water Master

Water Master:  
Mr. Franz Waltenspuhl  
Phone: (707) 279-2244

## ➔ General Drinking Water Source Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

**Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

**Radioactive contaminants**, that can be naturally-occurring or be the result of oil and gas production and mining activities.


In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Wasting Water is**

**SO Not Cool!**

**2013:**

**California's Driest Year  
Yet**

- 
- Irrigate in the morning or evening, NOT mid-day!
  - Wash your veggies in a bowl, not under running water
  - Water less frequently, yet deeply for stronger landscapes
  - Check into rebates for new water saving appliances
  - Use dishwasher and washing machine with FULL loads
  - Check for leaks in pipes and toilets
  - Wash car with a bucket and sponge, use nozzle on hose
  - Use a broom, not a hose to clean driveways and walkways

**\*\*\*TERMS USED IN THIS REPORT\*\*\***

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**Tables 1, 2, 3, 4 AND 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1—SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

Microbiological Contaminants	Highest # of Detections	# of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment

**TABLE 2—SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

*\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

Lead and Copper	# of Samples Collected	90th Percentile Level Detected	# of Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	5	9.1	0	15	0.2	Internal Corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	5	0.17	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3—SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	11/2012	12	-	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	11/2012	29.0	-	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

*\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Fluoride (ppm)	11/2012	0.31	-	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Chlorine (ppm)	2013	0.03	<0.10 – 0.20	[MRDL=4.0 (as Cl <sub>2</sub> )]	[MRDLG=4 (as Cl <sub>2</sub> )]	Drinking water disinfectant added for treatment
Gross Alpha (PCi/L)	6/2007	0.45	-	15	(0)	Erosion of natural deposits
TTHM's [Total Trihalomethanes](ppb)	2011	2	-	80	n/a	By-product of drinking water disinfection
-Bromodichloromethane	2011	0.69	-			
-Dibromochloromethane	2011	0.78	-			
-Chloroform (Trichloromethane)	2011	0.53	-			

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

*\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report*

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Chloride (ppm)	11/2012	3.5	-	500	-	Runoff/leaching from natural deposits; seawater influence
<b>Iron (ppb)</b>	<b>11/2012</b>	<b>*1500</b>	-	<b>300</b>	-	<b>Leaching from natural deposits; industrial wastes</b>
Manganese (ppb)	11/2012	88	-	50	-	Leaching from natural deposits
Specific Conductance (uMho)	11/2012	130	-	1,600	-	Substances that form ions when in water; seawater influence
Sulfate (ppm)	11/2012	0.52	-	500	-	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	11/2012	160	-	1000	-	Runoff/leaching from natural deposits
Turbidity (units)	11/2012	0.56	-	5	-	Soil Runoff

**\*\*Important Lead and Copper Information For All Community Water Systems\*\***

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Branding Iron Mutual Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



#### Leak Check!

- Around the house, even a little leak means **BIG** water loss.
- 70 gallons of water can be lost in a single day to a small drip!
- A steady leak can mean daily water waste of 1000+ gallons!
- It's easy to check for toilet leaks: Put a few drops of food coloring in your tank, wait 20 minutes. If you see the color in your bowl, you've got a leak. Simple tools and a DIY manual means no more leak.
- Many faucet leaks are due to worn washers. If your faucet is off and you hear water running you probably have a leak.
- Fixing hot water leaks means water savings **AND** energy savings too!

### **Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

**Summary Information for Secondary Contaminant Exceeding an MCL:** \*Iron was found at levels that exceed the secondary MCL of 300 ug/L. The iron MCL was set to protect you against unpleasant aesthetic effects (e.g., color, taste and odor) and the staining of plumbing fixtures (e.g., tubs and sinks) and clothing while washing. The high iron levels are due to leaching of natural deposits.

#### **Summary Information for Monitoring Violation:**

Monitoring for our 2013 Disinfection By-Products, Total Trihalomethanes and Haloacetic Acids, was conducted during the month of November which is outside the required timeframe. Monitoring for DBP's should be conducted during the warmest month of the year, typically August. Branding Iron MWC is scheduled to conduct this monitoring in August, 2014.

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).



**Branding Iron  
Mutual Water Company  
2013  
Consumer Confidence Report**