

2013 Consumer Confidence Report

Water System Name: Shorelands Road & Water Report Date: May 11, 2014

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: ground water

Name & general location of source(s): Well 01 (south side of water storage tank #1) Well 02 (west side of Lot #22) Well 03 (N.W. corner of Lot #17) Well 04 (west side of Lot #30) Well 06 (N.W. side of Lot #29)

Drinking Water Source Assessment information: C.D.P.H. May 2003 assessment, no contaminants but wells considered vulnerable to septic systems. All wells are greater than 150 ft. from septic systems.

Time and place of regularly scheduled board meetings for public participation: Annual meeting at Catholic Church Hall, 2nd Saturday in July 10:00 a.m. Monthly meetings 2nd Friday of each month. Location rotates among board members.

For more information, contact: Peter Braudrick Phone: (707) 937-1336

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	(0)	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	(0)	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	8/24/12	5	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	8/24/12	5	1.03	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	Well 01 9/27/11	42	29 - 47	none	none	Salt present in the water and is generally naturally occurring
	Well 02 9/27/12	47				
	Well 03 9/27/11	29				
	Well 04 9/27/12	37				

	Well 06	1/23/12	35				
Hardness (ppm)	Well 01	9/27/11	68	10 - 68	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
	Well 02	9/27/12	63				
	Well 03	9/27/11	41				
	Well 04	9/27/12	53				
	Well 06	1/23/12	10				

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant	
Fluoride (ppm)	Well 01	9/27/11	0.10 – 0.11	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
	Well 06	1/23/12					0.10
Nitrate as N03 (ppm)	Well 01	8/13/13	3.4 - 15	45	45	Runoff and leaching of fertilizer; leaching from septic tanks and sewage; erosion of natural deposits	
	Well 02	8/13/13					3.4
	Well 03	8/13/13					4.8
	Well 04	8/13/13					15
	Well 06	8/13/13					5.9
Gross Alpha Particle Activity (pCi/L)	Well 01	7/31/07	0.48 – 1.44	15	(0)	Erosion of natural deposits	
	Well 02	7/31/07					0.50
	Well 03	7/31/07					0.92
	Well 04	7/31/07					0.54
	Well 06	9/13/10					1.44
Total Trihalomethanes (ppb)	9/26/11	20.89		80	n/a	Byproduct of drinking water disinfection	
Haloacetic Acids (ppb)	9/26/11	3.9		60	n/a	Byproduct of drinking water disinfection	
Radium 228 (pCi/L)	Well 01	9/29/10	0.18 – 1.93	5	0.019	Erosion of natural deposits	
	Well 02	9/29/10					1.15
	Well 03	9/29/10					0.18
	Well 04	9/29/10					0.68
Chlorine (ppm) Quarterly Average		3/31/13	0.3 – 0.5	4.0	4.0	Drinking water disinfectant added for treatment	
		6/30/13					0.5
		9/30/13					0.3
		12/31/13					0.3
Asbestos (MFL)	3/6/12	0.1		7	7	Internal corrosion of asbestos cement water mains; erosion of natural deposits	
Lead (ppb)	Well 02	8/13/13	9.5	15	0.2	Internal corrosion of water plumbing systems; erosion of natural deposits	

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant	
Chloride (ppm)	Well 01	9/27/11	40 - 58	500	n/a	Runoff/leaching from natural deposits; seawater influence	
	Well 02	9/3/09					40
	Well 03	9/27/11					56
	Well 04	9/3/09					48
	Well 06	1/23/12					55
Sulfate (ppm)	Well 01	9/27/11	7.4 - 14	500	n/a	Runoff/leaching from natural deposits; industrial wastes	
	Well 02	9/3/09					13
	Well 03	9/27/11					13
	Well 04	9/3/09					14
	Well 06	1/23/12					12

Foaming Agents (MBAS) (ppb)	Well 02	9/3/09	92		500	n/a	Municipal and industrial waste discharges
Specific Conductance (uS/cm)	Well 01	6/18/12	310	220 - 310	1600	n/a	Substances that form ions when in water; seawater influence
	Well 02	6/18/12	300				
	Well 03	6/18/12	220				
	Well 04	6/18/12	310				
	Well 06	6/18/12	300				
Ph, Lab (units)	Well 01	9/27/11	6.7	6.6 – 6.61		n/a	Acidity, or low pH of drinking water, is usually a result of natural geological conditions. 7.0 indicates the theoretical neutral point.
	Well 02	9/3/09	6.8				
	Well 03	9/27/11	6.7				
	Well 04	9/3/09	6.6				
	Well 06	1/23/12	6.61				

TABLE 6 –PCI/L) DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Chromium VI (ppb)Well 06	1/30/09	3.9		n/a	Some people who use water containing chromium in excess of the MCL over many years may experience allergic dermatitis.

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Shorelands Road & Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
NONE				

For Water Systems Providing Ground Water as a Source of Drinking Water

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	0		0	(0)	Human and animal fecal waste
Enterococci	0		TT	n/a	Human and animal fecal waste
Coliphage	0		TT	n/a	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Ground Water Source Samples,
Uncorrected Significant Deficiencies, or Ground Water TT**

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLE				
N/A				
SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES				
N/A				
VIOLATION OF GROUND WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
NONE				

