# Consumer Confidence Report
# Certification Form

*(To be submitted with a copy of the CCR)*

Water System Name: Cole Road Mutual Water Association

Water System Number: 3500577

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (*date*) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the California Department of Public Health.

Certified by: Name: Peter Alesandro

Signature: Peter Alesandro

Title: president

Phone Number: (831) 726-3328 Date: 5/23/14

---

*To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:*

- ☒ CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- ☐ CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- ☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - ☐ Posting the CCR at the following URL: www._____
  - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
  - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - ☐ Posted the CCR in public places (attach a list of locations)
  - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - ☐ Delivery to community organizations (attach a list of organizations)
  - ☐ Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
  - ☐ Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
  - ☐ Other (attach a list of other methods used)
- ☐ *For systems serving at least 100,000 persons*: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- ☐ *For privately-owned utilities*: Delivered the CCR to the California Public Utilities Commission



MAY 3 1 2014

**WATER QUALITY EMERGENCY NOTIFICATION PLAN:**

Please describe your water system's plan for emergency notification to all water users:

Small Community.
Hand delivery
We are Close Together all can be
reached in less than 1 Hour

Date 5/23/14

Report prepared by: Peter Alexandro president

Name of utility or water system:

# 2013 Consumer Confidence Report

Water System Name: Cole Road Mutual Water Assn. Report Date: 5/19/14

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Ground

Name & general location of source(s): well A 3500577-001
well B 3500577-003

Drinking Water Source Assessment information:

Time and place of regularly scheduled board meetings for public participation: NONE; WE ARE TOO SMALL
Any member can invogue a meeting

For more information, contact: PETER ALESANDRO Phone: (831) 7263328

**TERMS USED IN THIS REPORT**

**Maximum Contaminant Level (MCL)**: The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)**: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS)**: MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS)**: MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT)**: A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL)**: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions**: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND**: not detectable at testing limit

**ppm**: parts per million or milligrams per liter (mg/L)

**ppb**: parts per billion or micrograms per liter (µg/L)

**ppt**: parts per trillion or nanograms per liter (ng/L)

**ppq**: parts per quadrillion or picogram per liter (pg/L)

**pCi/L**: picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

MAY 3 1 2014

| TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD | | | | | | |
|---|---|---|---|---|---|---|
| **Chemical or Constituent** (and reporting units) | **Sample Date** | **Level Detected** | **Range of Detections** | **MCL [MRDL]** | **PHG (MCLG) [MRDLG]** | **Typical Source of Contaminant** |
| ASBESTOS | 4-16-14 | .1980 | | 7.0 | | EROSION OF NAT. DEPOSITS |
| FLUORIDE | 4-16-14 | .24 | | .10 | | NATURAL SOURCE |
| NITRATE | 4-16-14 | 05.0 | | 45 | | RUNOFF FROM FERTILIZERS |

| TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD | | | | | | |
|---|---|---|---|---|---|---|
| **Chemical or Constituent** (and reporting units) | **Sample Date** | **Level Detected** | **Range of Detections** | **MCL** | **PHG (MCLG)** | **Typical Source of Contaminant** |
| SPECIFIC conductance | | 220. | | 1600 | | SEAWATER |
| chloride | | 34. | | 500 | | NATURAL deposits/SEA WATER |
| Total Disolved Solids | | 180. | | 1000 | | LEACHING FROM NATURAL DEPOSITS |
| sulfate | | 6.5 | | 500 | | And OR INDUSTRIAL WASTE |

| TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS | | | | | |
|---|---|---|---|---|---|
| **Chemical or Constituent** (and reporting units) | **Sample Date** | **Level Detected** | **Range of Detections** | **Notification Level** | **Health Effects Language** |
| | | | | | |

**Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [INSERT NAME OF UTILITY] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

## For Systems Providing Surface Water as a Source of Drinking Water

| TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES | |
|---|---|
| Treatment Technique [(a)]<br>(Type of approved filtration technology used) | |
| Turbidity Performance Standards [(b)]<br>(that must be met through the water treatment process) | Turbidity of the filtered water must:<br>1 – Be less than or equal to _____ NTU in 95% of measurements in a month.<br>2 – Not exceed _____ NTU for more than eight consecutive hours.<br>3 – Not exceed ____ NTU at any time. |
| Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1. | |
| Highest single turbidity measurement during the year | |
| Number of violations of any surface water treatment requirements | |

(a) A required process intended to reduce the level of a contaminant in drinking water.
(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.
** Any violation of a TT is marked with an asterisk. Additional information regarding the violation is provided below.*

## Summary Information for Violation of a Surface Water TT

| VIOLATION OF A SURFACE WATER TT | | | | |
|---|---|---|---|---|
| **TT Violation** | **Explanation** | **Duration** | **Actions Taken to Correct the Violation** | **Health Effects Language** |
| | | | | |
| | | | | |
| | | | | |

## Summary Information for Operating Under a Variance or Exemption