



June 18, 2014

Mr. Frank Girardi
San Joaquin County Environmental Health Department
1868 E. Hazleton Ave.
Stockton, CA 95205

RE: BJJ Company, LLC – 2013 CCR

Dear Mr. Girardi,

Please find attached an original signed copy of the 2013 Consumer Confidence Report (CCR). This report was distributed to our tenants and has been posted in three public locations on the property.

Also attached is a signed copy of the arsenic public notification form, which has also been distributed to our tenants and posted.

Please let me know if you have any questions about these submittals or need additional information.
Thank you.

Sincerely,

A handwritten signature in cursive script that reads "Janet Blincoe". The signature is written in dark ink and is positioned above the printed name.

Janet Blincoe
Water System Owner

Consumer Confidence Report Certification Form

Water System Name: **BJJ COMPANY LLC**
Water System Number: **3901334**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/30/14 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name Greg Smith, for Janet Blincor
Signature [Handwritten Signature]
Title Controller
Phone Number (209) 941-8361 Date 6/30/14

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: _____

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

Posted the CCR on the internet at www. _____

Mailed the CCR to postal patrons within the service area (attach zip codes used)

Advertised the availability of the CCR in news media (attach copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

Posted the CCR in public places (attach a list of locations)

- Terrel Trucking
- Foodliner's Main Office
- Foodliner's Drivers Room

Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools

Delivery to community organizations (attach a list of organizations)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. _____

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2013 Consumer Confidence Report

Water System Name: BJJ COMPANY LLC

Report Date: June 2014

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to DHS records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source: Well 02.

For more information about this report, or for any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

umhos/cm: micromhos per centimeter (a measure of conductivity)

TON: threshold odor numbers (a measure of odor)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2013 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2,3 and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in the last sample set)	No. of Samples Collected	90th Percentile Level	No. Site Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ppb)	5 (2013)	0.60	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits

TABLE 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2009)	27	27 - 27	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2009)	52.1	52 - 52	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

2013 Consumer Confidence Report

TABLE 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ppb)	(2013)	17	16 - 18	10	n/a	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (ppm)	(2011)	0.12	0.1 - 0.1	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2009)	9	9 - 9	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2009)	120	120 - 120	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	(2009)	140	140 - 140	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2009)	217	217 - 217	1600	n/a	Substances that form ions when in water; seawater influence
Total Dissolved Solids (ppm)	(2009)	130	130 - 130	1000	n/a	Runoff/leaching from natural deposits

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *BJJ COMPANY LLC* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

2013 Consumer Confidence Report

To address elevated Arsenic and Manganese in the water system, the water system owner, Janet Blincoe has taken the following action:

1. Posted warning signs in restrooms & break rooms
2. Provided bottled water dispensers for tenants and visitors
3. Initiated the process of moving to an alternative water supply source.

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

About our Arsenic: Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

Drinking Water Source Assessment Information

Assessment Info

A source water assessment was conducted for the WELL 02 of the BJJ COMPANY INC water system in August, 2002.

Well 02 - The source is considered most vulnerable to the following activities not associated with any detected contaminants:

- Chemical/petroleum processing/storage
- Septic systems - high density [$>1/\text{acre}$]

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Info

A copy of the complete assessment may be viewed at:

San Joaquin County
Environmental Health Department
304 E. Weber Ave, 3rd Floor
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
SJ Co Environmental Health Department
(209) 468-3420

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

BJJ Company Inc. Water System Has Levels of Arsenic Above the Drinking Water Standard

June 18, 2014

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Averaged water sample results from 4 sample reports from 2006 showed an averaged arsenic level of 0.012 milligrams per liter. This is above the maximum contaminant level (MCL) of 0.010 milligrams per liter.

What should I do?

- You do not need to use an alternative water supply (e.g., bottled water).
- This is not an emergency. If it had been, you would have been notified immediately. However, some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk to getting cancer.
- If you have other health issues concerning the consumption of this water, you may wish to consult you doctor.

What happened? What is being done?

All options are being evaluated at this time.

We anticipate resolving the problem within: Unknown at this time.

For more information, please contact Quality Service, Inc. at (209)838-7842.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property

This notice is being sent to you by BJJ Company INC. Water System

State Water System ID#: 3901334 Date distributed: June 18, 2014

I (We) declare under penalty of perjury that the statements on this application are correct to my (our) knowledge and the actions taken to notify the users of this water system are in compliance with California Code of Regulations (CCR), for exceeding the Maximum Contaminant Level for arsenic. Signature: John M. Tanaka
Fax completed form to EHD- SPWS Program at 468-0341.