


Consumer Confidence Report Certification Form

Water System Name: WASTEQUIP
Water System Number: 3901414

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/27/14 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name Mike Nelson
Signature 
Title Plant Manager
Phone Number (209) 333-4414 Date _____

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: Posted on Bulletin Board and reviewed with all personnel on site.

___ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- ___ Posted the CCR on the internet at www. _____
- ___ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- ___ Advertised the availability of the CCR in news media (attach copy of press release)
- ___ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- ___ Posted the CCR in public places (attach a list of locations)
- ___ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools
- ___ Delivery to community organizations (attach a list of organizations)
- ___ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. _____
- ___ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2013 Consumer Confidence Report

Water System Name: WASTEQUIP

Report Date: June 2014

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to CDPH records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source: WELL 01.

For more information about this report, or for any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service Inc.

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, order, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

umhos/cm: micromhos per centimeter (a measure of conductivity)

TON: threshold odor numbers (a measure of odor)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2013 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2 and 3 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of Samples Collected	90th Percentile Level	No. Site Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ppb)	5 (2011)	5.40	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	5 (2011)	0.132	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate (ppm)	(2013)	12.5	12 - 12	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2006 - 2007)	0.7	ND - 2	15	(0)	Erosion of natural deposits.

2013 Consumer Confidence Report

TABLE 3 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Vanadium (ppm)	(2013)	0.01	0.01 - 0.01	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *WASTEQUIP* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Drinking Water Source Assessment Information

Assessment Info

A source water assessment was conducted for the WELL of the MCLAUGHLIN REFUSE EQUIP, INC water system in December, 2002.

Well - is considered most vulnerable to the following activities not associated with any detected contaminants:

Transportation corridors - Railroads

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Info

A copy of the complete assessment may be viewed at:

San Joaquin County
Environmental Health Department
304 E. Weber Ave, 3rd Floor
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

Small Public Water Systems
SJ Co Environmental Health Department
(209) 468-3420

WASTEQUIP Analytical Results By FGL - 2013

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ppb	0	15	0.2			5.40	5
Handicap	STK1135104-005	ppb				06/10/2011	2.80		
Mens Room	STK1135104-001	ppb				06/10/2011	4.80		
Water Tub #1	STK1135104-003	ppb				06/10/2011	0.00		
Water Tub #2	STK1135104-004	ppb				06/10/2011	0.00		
Womens Room	STK1135104-002	ppb				06/10/2011	6.00		
Copper		ppm		1.3	.3			0.132	5
Handicap	STK1135104-005	ppm				06/10/2011	0.246		
Mens Room	STK1135104-001	ppm				06/10/2011	0.0180		
Water Tub #1	STK1135104-003	ppm				06/10/2011	0.00		
Water Tub #2	STK1135104-004	ppm				06/10/2011	0.00		
Womens Room	STK1135104-002	ppm				06/10/2011	0.00500		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Nitrate		ppm		45	45			12.5	12 - 12
Well	STK1333240-001	ppm				04/10/2013	12.5		
Gross Alpha		pCi/L		15	(0)			0.7	0 - 2
Well	STK0735806-001	pCi/L				06/29/2007	1.27		
Well	STK0732298-001	pCi/L				03/09/2007	0.861		
Well	STK0650544-001	pCi/L				12/08/2006	0.768		
Well	STK0638285-001	pCi/L				09/27/2006	1.66		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ppm		NS				0.01	0.01 - 0.01
Well	STK1333240-001	ppm				04/10/2013	0.0120		

WASTEQUIP CCR Login Linkage - 2013

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
Handicap	06/10/2011	STK1135104-005	Metals, Total	Handicap	Copper & Lead Monitoring
Mens Room	06/10/2011	STK1135104-001	Metals, Total	Mens Room	Copper & Lead Monitoring
North Hose Bib	01/14/2013	STK1330379-001	Coliform	North Hose Bib	Bacti Monitoring - Odd
	03/13/2013	STK1332218-001	Coliform	North Hose Bib	Bacti Monitoring - Odd
	05/16/2013	STK1334744-001	Coliform	North Hose Bib	Bacti Monitoring - Odd
	07/10/2013	STK1336812-001	Coliform	North Hose Bib	Bacti Monitoring - Odd
	09/11/2013	STK1339028-001	Coliform	North Hose Bib	Bacti Monitoring - Odd
	11/13/2013	STK1351081-001	Coliform	North Hose Bib	Bacti Monitoring - Odd
Northwest Hose	02/13/2013	STK1331226-001	Coliform	Northwest Hose Bib	Bacti Monitoring - Even
	04/10/2013	STK1333241-001	Coliform	Northwest Hose Bib	Bacti Monitoring - Even
	06/13/2013	STK1335762-001	Coliform	Northwest Hose Bib	Bacti Monitoring - Even
	08/13/2013	STK1338047-001	Coliform	Northwest Hose Bib	Bacti Monitoring - Even
	10/14/2013	STK1350085-001	Coliform	Northwest Hose Bib	Bacti Monitoring - Even
	12/11/2013	STK1351932-001	Coliform	Northwest Hose Bib	Bacti Monitoring - Even
Water Tub #1	06/10/2011	STK1135104-003	Metals, Total	Water Tub #1	Copper & Lead Monitoring
Water Tub #2	06/10/2011	STK1135104-004	Metals, Total	Water Tub #2	Copper & Lead Monitoring
Well	09/27/2006	STK0638285-001	Radio Chemistry	Well	Drinking Water Monitoring
	12/08/2006	STK0650544-001	Radio Chemistry	Well	Radio Monitoring
	03/09/2007	STK0732298-001	Radio Chemistry	Well	Radio Monitoring
	06/29/2007	STK0735806-001	Radio Chemistry	Well	Radio Monitoring
	04/18/2008	STK0833910-001	EPA 524.2	Well	VOC Monitoring
	04/10/2013	STK1333239-001	Wet Chemistry	Well	Nitrite Monitoring
	04/10/2013	STK1333240-001	EPA 504.1	Well	Water Quality Monitoring
	04/10/2013	STK1333240-001	Metals, Total	Well	Water Quality Monitoring
	04/10/2013	STK1333240-001	Wet Chemistry	Well	Water Quality Monitoring
WELL 01	05/03/2011	STK1133669-001	Wet Chemistry	Well	Perchlorate Monitoring
Womens Room	06/10/2011	STK1135104-002	Metals, Total	Womens Room	Copper & Lead Monitoring