Consumer Confidence Report
Certification Form

(To be submitted with a copy of the CCR)

Water System Name: Port San Luis Harbor

Water System Number: 4000800

The water system named above hereby certifies that its Consumer Confidence Report was distributed on **June 30th, 2014** to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the California Department of Public Health.

Certified by:
- Name: Jenny Struthers
- Signature: JStruthers
- Title: Compliance Specialist
- Phone Number: (805) 597-7100 Date: June 6, 2014

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- [x] CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used).
- [ ] CCR was distributed using electronic delivery methods described in the Guidance for Electronic Delivery of the Consumer Confidence Report (water systems utilizing electronic delivery methods must complete the second page).
- [ ] "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
  - [ ] Posting the CCR at the following URL: www._____
  - [ ] Mailing the CCR to postal patrons within the service area (attach zip codes used)
  - [ ] Advertising the availability of the CCR in news media (attach copy of press release)
  - [ ] Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
  - [ ] Posted the CCR in public places (attach a list of locations)
  - [ ] Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
  - [ ] Delivery to community organizations (attach a list of organizations)
  - [ ] Publication of the CCR in the electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
  - [ ] Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
  - [ ] Other (attach a list of other methods used)
- [ ] *For systems serving at least 100,000 persons*: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- [ ] *For privately-owned utilities*: Delivered the CCR to the California Public Utilities Commission

2013 Consumer Confidence Report

Water System Name: **Port San Luis Harbor District** Report Date: May 15, 2014

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: **Lopez Lake Water Supply Project**

Name & general location of source(s): **Lopez Water Treatment Plant**

Drinking Water Source Assessment information: **A Source water assessment was completed for the Lopez Water Treatment Plant in June 2001. A copy of the assessment is available at: County Of San Luis Obispo, Department of Public Works, County Government Center, Room 207, San Luis Obispo, CA 93408**

Time and place of regularly scheduled board meetings for public participation: **Fourth Tuesday of every month 6 pm, Coastal Gateway Bldg. 3900 Avila Beach Drive**

For more information, contact: **Port San Luis Harbor District Office** Phone: **(805) 595-5400**

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.)	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or *E. coli*	(In the year)	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or *E. coli*	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2011	5	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2011	5	.06	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Source of Contaminant**
Sodium (ppm)	NA			none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	NA			none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.*

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL [MRDL]**	**PHG (MCLG) [MRDLG]**	**Typical Source of Contaminant**
Total Trihalomethanes (TTHM's) (ppb)	2013	20		80	NA	By-product of drinking water disinfection.
Haloacetic Acids (ppb)	2013	2.5		60	NA	By-product of drinking water disinfection.

**Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).