

# 2013 Consumer Confidence Report

Water System Name: **VINEYARD MUTUAL WATER  
COMPANY/INDUSTRIAL**

Report Date: June 2014

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2013*

**Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water sources(s) in use:** The Assessment was conducted by CDPH District Office. According to CDPH records, Well 1 and Well 2 are Groundwater. This Assessment was done using the Default Groundwater System Method. The VINEYARD MUTUAL WATER COMPANY system is located in Ventura County and serves the surrounding commercial and industrial areas. There are approximately 52 service connections serving a population of 140.

**Your water comes from 2 sources:** Well 1 and Well 2.

For more information about this report, or for any questions relating to your drinking water, please call (805) 654 - 1077 and ask for John Ferro.

## **TERMS USED IN THIS REPORT:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter ( $\mu\text{g/L}$ )

**umhos/cm:**

**TON:** threshold odor numbers

**pCi/l:** picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

# 2013 Consumer Confidence Report

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2,3,4,5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

| Lead and Copper<br>(complete if lead or copper detected in the last sample set) | No. of Samples Collected | 90th Percentile Level | No. Site Exceeding AL | AL  | PHG | Typical Sources of Contaminant  |
|---|--------------------------|-----------------------|-----------------------|-----|-----|---|
| Lead (ppb)  | 5<br>(2012)              | 2.30                  | 0                     | 15  | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits |
| Copper (ppm)  | 5<br>(2012)              | 0.179                 | 0                     | 1.3 | .3  | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives               |

**TABLE 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Typical Sources of Contaminant   |
|--|-------------|----------------|---------------------|------------|------------|--|
| Sodium (ppm)                                     | (2013)      | 109            | 106 - 112           | none       | none       | Salt present in the water and is generally naturally occurring   |
| Hardness (ppm)                                   | (2013)      | 601            | 601 - 601           | none       | none       | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

## 2013 Consumer Confidence Report

| TABLE 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD |             |                |                     |            |                    |  |
|--|-------------|----------------|---------------------|------------|--------------------|--|
| Chemical or Constituent<br>(and reporting units)                           | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) (MRDLG) | Typical Sources of Contaminant   |
| Fluoride (ppm)   | (2013)      | 0.5            | 0.5 - 0.5           | 2          | 1                  | Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.  |
| Nitrate (ppm)  | (2013)      | 10.4           | 8 - 12              | 45         | 45                 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits  |
| Nitrate + Nitrite as N (ppm)   | (2013)      | 2.35           | 1.9 - 2.8           | 10         | 10                 | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits  |
| Selenium (ppb)   | (2013)      | 6.0            | 6 - 6               | 50         | 30                 | Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive) |
| Gross Alpha (pCi/L)  | (2012)      | 4.2            | 2 - 6               | 15         | (0)                | Erosion of natural deposits.   |
| Uranium (pCi/L)  | (2012)      | 1.2            | ND - 2              | 20         | 0.43               | Erosion of natural deposits  |

| TABLE 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD |             |                |                     |            |            |   |
|--|-------------|----------------|---------------------|------------|------------|---|
| Chemical or Constituent<br>(and reporting units)                             | Sample Date | Level Detected | Range of Detections | MCL (MRDL) | PHG (MCLG) | Typical Sources of Contaminant                              |
| Chloride (ppm)   | (2013)      | 52             | 50 - 54             | 500        | n/a        | Runoff/leaching from natural deposits; seawater influence   |
| Iron (ppb)   | (2013)      | 120            | 70 - 170            | 300        | n/a        | Leaching from natural deposits; Industrial wastes           |
| Specific Conductance (umhos/cm)  | (2013)      | 1500           | 1480 - 1520         | 1600       | n/a        | Substances that form ions when in water; seawater influence |
| Sulfate (ppm)  | (2013)      | 475            | 470 - 480           | 500        | n/a        | Runoff/leaching from natural deposits; industrial wastes    |
| Total Dissolved Solids (ppm)   | (2013)      | 1080           | 1070 - 1100         | 1000       | n/a        | Runoff/leaching from natural deposits                       |

Any violation of MCL,AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

| TABLE 5 - DETECTION OF UNREGULATED CONTAMINANTS  |             |                |                     |                    |   |
|--|-------------|----------------|---------------------|--------------------|---|
| Chemical or Constituent<br>(and reporting units) | Sample Date | Level Detected | Range of Detections | Notification Level | Health Effects Language   |
| Boron (ppm)                                      | (2013)      | 0.6            | 0.5 - 0.6 ((2013))  | 1                  | The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals. |

## 2013 Consumer Confidence Report

| TABLE 6 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE |                |                   |                        |               |               |   |
|---|----------------|-------------------|------------------------|---------------|---------------|---|
| Chemical or Constituent<br>(and reporting units)                        | Sample<br>Date | Level<br>Detected | Range of<br>Detections | MCL<br>(MRDL) | PHG<br>(MCLG) | Typical Sources of Contaminant            |
| Total Trihalomethanes (TTHMs) (ppb)                                     | 2013           | 15.4              | ND - 30.8              | 80            | n/a           | By-product of drinking water disinfection |
| Haloacetic Acids (five) (ppb)   | (2013)         | 5                 | 5 - 5                  | 60            | n/a           | By-product of drinking water disinfection |

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

**For Lead (Pb),** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

---



---



---



---



---



---



---

### Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

**About our Total Dissolved Solids:** The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCL's was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

# 2013 Consumer Confidence Report

## Drinking Water Source Assessment Information

### Assessment Info

A source water assessment was conducted for the WELL 01 and the WELL 02 of the VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL water system in March, 2012.

Well 01 - The source is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Body shops
- Automobile - Repair shops
- Sewer collection systems

Well 02 - The source is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile - Body shops
- Automobile - Repair shops
- Sewer collection systems

### Acquiring Info

A copy of the complete assessment may be viewed at:

DHS Drinking Water Field Operations Branch  
1180 Eugenia Place  
Suite 200  
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:

Kurt Souza  
District Engineer  
805 566 1326

# VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL

## Analytical Results By FGL - 2013

| LEAD AND COPPER RULE |                |       |      |        |     |            |        |                 |           |
|----------------------|----------------|-------|------|--------|-----|------------|--------|-----------------|-----------|
|                      |                | Units | MCLG | CA-MCL | PHG | Sampled    | Result | 90th Percentile | # Samples |
| <b>Lead</b>          |                | ppb   | 0    | 15     | 0.2 |            |        | 2.30            | 5         |
| 162 MTG              | SP 1205836-001 | ppb   |      |        |     | 06/12/2012 | 2.50   |                 |           |
| 249 MTG              | SP 1205836-002 | ppb   |      |        |     | 06/12/2012 | 1.10   |                 |           |
| 319 A LBT            | SP 1205836-004 | ppb   |      |        |     | 06/12/2012 | 2.10   |                 |           |
| 3897 NSB PE          | SP 1205836-005 | ppb   |      |        |     | 06/12/2012 | 1.00   |                 |           |
| 4121 NSB             | SP 1205836-003 | ppb   |      |        |     | 06/12/2012 | 0.900  |                 |           |
| <b>Copper</b>        |                | ppm   |      | 1.3    | .3  |            |        | 0.179           | 5         |
| 162 MTG              | SP 1205836-001 | ppm   |      |        |     | 06/12/2012 | 0.126  |                 |           |
| 249 MTG              | SP 1205836-002 | ppm   |      |        |     | 06/12/2012 | 0.116  |                 |           |
| 319 A LBT            | SP 1205836-004 | ppm   |      |        |     | 06/12/2012 | 0.227  |                 |           |
| 3897 NSB PE          | SP 1205836-005 | ppm   |      |        |     | 06/12/2012 | 0.130  |                 |           |
| 4121 NSB             | SP 1205836-003 | ppm   |      |        |     | 06/12/2012 | 0.104  |                 |           |

| SAMPLING RESULTS FOR SODIUM AND HARDNESS |                |       |      |        |      |            |        |                |           |
|--|----------------|-------|------|--------|------|------------|--------|----------------|-----------|
|  |                | Units | MCLG | CA-MCL | PHG  | Sampled    | Result | Avg. Result(a) | Range (b) |
| <b>Sodium</b>                            |                | ppm   |      | none   | none |            |        | 109            | 106 - 112 |
| Well 1                                   | SP 1304140-001 | ppm   |      |        |      | 04/25/2013 | 112    |                |           |
| Well 2                                   | SP 1304140-002 | ppm   |      |        |      | 04/25/2013 | 106    |                |           |
| <b>Hardness</b>                          |                | ppm   |      | none   | none |            |        | 601            | 601 - 601 |
| Well 1                                   | SP 1304140-001 | ppm   |      |        |      | 04/25/2013 | 601    |                |           |
| Well 2                                   | SP 1304140-002 | ppm   |      |        |      | 04/25/2013 | 601    |                |           |

| PRIMARY DRINKING WATER STANDARDS (PDWS) |                |       |      |        |      |            |        |                |           |
|---|----------------|-------|------|--------|------|------------|--------|----------------|-----------|
|   |                | Units | MCLG | CA-MCL | PHG  | Sampled    | Result | Avg. Result(a) | Range (b) |
| <b>Fluoride</b>                         |                | ppm   |      | 2      | 1    |            |        | 0.5            | 0.5 - 0.5 |
| Well 1                                  | SP 1304140-001 | ppm   |      |        |      | 04/25/2013 | 0.500  |                |           |
| Well 2                                  | SP 1304140-002 | ppm   |      |        |      | 04/25/2013 | 0.500  |                |           |
| <b>Nitrate</b>                          |                | ppm   |      | 45     | 45   |            |        | 10.4           | 8 - 12    |
| Well 1                                  | SP 1304140-001 | ppm   |      |        |      | 04/25/2013 | 8.40   |                |           |
| Well 2                                  | SP 1304140-002 | ppm   |      |        |      | 04/25/2013 | 12.5   |                |           |
| <b>Nitrate + Nitrite as N</b>           |                | ppm   |      | 10     | 10   |            |        | 2.35           | 1.9 - 2.8 |
| Well 1                                  | SP 1304140-001 | ppm   |      |        |      | 04/25/2013 | 1.90   |                |           |
| Well 2                                  | SP 1304140-002 | ppm   |      |        |      | 04/25/2013 | 2.80   |                |           |
| <b>Selenium</b>                         |                | ppb   | 50   | 50     | 30   |            |        | 6.0            | 6 - 6     |
| Well 1                                  | SP 1304140-001 | ppb   |      |        |      | 04/25/2013 | 6.00   |                |           |
| Well 2                                  | SP 1304140-002 | ppb   |      |        |      | 04/25/2013 | 6.00   |                |           |
| <b>Gross Alpha</b>                      |                | pCi/L |      | 15     | (0)  |            |        | 4.2            | 2 - 6     |
| Well 1                                  | SP 1204024-001 | pCi/L |      |        |      | 04/24/2012 | 2.25   |                |           |
| Well 2                                  | SP 1204024-002 | pCi/L |      |        |      | 04/24/2012 | 4.31   |                |           |
| Well 1                                  | SP 1200238-001 | pCi/L |      |        |      | 01/06/2012 | 3.90   |                |           |
| Well 2                                  | SP 1200238-002 | pCi/L |      |        |      | 01/06/2012 | 6.44   |                |           |
| <b>Uranium</b>                          |                | pCi/L |      | 20     | 0.43 |            |        | 1.2            | 0 - 2     |
| Well 1                                  | SP 1200238-001 | pCi/L |      |        |      | 01/06/2012 | 2.34   |                |           |
| Well 2                                  | SP 1200238-002 | pCi/L |      |        |      | 01/06/2012 | 1.38   |                |           |

| SECONDARY DRINKING WATER STANDARDS (SDWS) |                |          |      |        |     |            |        |                |             |
|---|----------------|----------|------|--------|-----|------------|--------|----------------|-------------|
|   |                | Units    | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b)   |
| <b>Chloride</b>                           |                | ppm      |      | 500    |     |            |        | 52             | 50 - 54     |
| Well 1                                    | SP 1304140-001 | ppm      |      |        |     | 04/25/2013 | 50.0   |                |             |
| Well 2                                    | SP 1304140-002 | ppm      |      |        |     | 04/25/2013 | 54.0   |                |             |
| <b>Iron</b>                               |                | ppb      |      | 300    |     |            |        | 120            | 70 - 170    |
| Well 1                                    | SP 1304140-001 | ppb      |      |        |     | 04/25/2013 | 170    |                |             |
| Well 2                                    | SP 1304140-002 | ppb      |      |        |     | 04/25/2013 | 70.0   |                |             |
| <b>Specific Conductance</b>               |                | umhos/cm |      | 1600   |     |            |        | 1500           | 1480 - 1520 |

# VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL

## Analytical Results By FGL - 2013

| SECONDARY DRINKING WATER STANDARDS (SDWS) |                |          |      |        |     |            |        |                |           |
|---|----------------|----------|------|--------|-----|------------|--------|----------------|-----------|
|   |                | Units    | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b) |
| <b>Specific Conductance</b>               |                |          |      |        |     |            |        |                |           |
| Well 1                                    | SP 1304140-001 | umhos/cm |      |        |     | 04/25/2013 | 1520   |                |           |
| Well 2                                    | SP 1304140-002 | umhos/cm |      |        |     | 04/25/2013 | 1480   |                |           |
| <b>Sulfate</b>                            |                |          |      |        |     |            |        |                |           |
| Well 1                                    | SP 1304140-001 | ppm      |      | 500    |     | 04/25/2013 | 480    | 475            | 470 - 480 |
| Well 2                                    | SP 1304140-002 | ppm      |      |        |     | 04/25/2013 | 470    |                |           |
| <b>Total Dissolved Solids</b>             |                |          |      |        |     |            |        |                |           |
| Well 1                                    | SP 1304140-001 | ppm      |      | 1000   |     | 04/25/2013 | 1100   |                |           |
| Well 2                                    | SP 1304140-002 | ppm      |      |        |     | 04/25/2013 | 1070   |                |           |

| UNREGULATED CONTAMINANTS |                |       |      |        |     |            |        |                |           |
|--------------------------|----------------|-------|------|--------|-----|------------|--------|----------------|-----------|
|                          |                | Units | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b) |
| <b>Boron</b>             |                |       |      |        |     |            |        |                |           |
| Well 1                   | SP 1304140-001 | ppm   |      | NS     |     | 04/25/2013 | 0.600  | 0.6            | 0.5 - 0.6 |
| Well 2                   | SP 1304140-002 | ppm   |      |        |     | 04/25/2013 | 0.500  |                |           |

| FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE |                |       |      |        |     |            |        |                |           |
|--|----------------|-------|------|--------|-----|------------|--------|----------------|-----------|
|  |                | Units | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b) |
| <b>Total Trihalomethanes (TTHMs)</b>             |                |       |      |        |     |            |        |                |           |
| DBP2 162MONTGOM                                  | SP 1308985-001 | ppb   |      | 80     | n/a | 08/29/2013 | 30.8   | 15.4           | 0 - 30.8  |
| Well 1   | SP 1304140-001 | ppb   |      |        |     | 04/25/2013 | 0.00   |                |           |
| Well 2   | SP 1304140-002 | ppb   |      |        |     | 04/25/2013 | 0.00   |                |           |
| <b>Haloacetic Acids (five)</b>                   |                |       |      |        |     |            |        |                |           |
| DBP2 162MONTGOM                                  | SP 1308985-001 | ppb   |      | 60     | n/a | 08/29/2013 | 5.00   | 5              | 5 - 5     |

## VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL CCR Login Linkage - 2013


| FGL CODE           | DATE SAMPLED | LAB ID         | METHOD          | DESCRIPTION                    | PROPERTY                         |
|--------------------|--------------|----------------|-----------------|--------------------------------|----------------------------------|
| 162 Montgomery     | 01/22/2013   | SP 1300688-001 | Coliform        | 162 Montgomery                 | Water Monitoring-Odd             |
|                    | 03/21/2013   | SP 1302922-001 | Coliform        | 162 Montgomery                 | Water Monitoring-Odd             |
|                    | 05/09/2013   | SP 1304651-001 | Coliform        | 162 Montgomery                 | Water Monitoring-Odd             |
|                    | 07/18/2013   | SP 1307275-001 | Coliform        | 162 Montgomery                 | Water Monitoring-Odd             |
|                    | 09/24/2013   | SP 1309979-001 | Coliform        | 162 Montgomery                 | Water Monitoring-Odd             |
|                    | 11/07/2013   | SP 1311831-001 | Coliform        | 162 Montgomery                 | Water Monitoring-Odd             |
| 162 MTG            | 06/12/2012   | SP 1205836-001 | Metals, Total   | 162 MTG                        | Copper & Lead Monitoring         |
| 249 MTG            | 06/12/2012   | SP 1205836-002 | Metals, Total   | 249 MTG                        | Copper & Lead Monitoring         |
| 301 Lambert        | 02/12/2013   | SP 1301423-001 | Coliform        | 301 Lambert                    | Water Monitoring-Even            |
|                    | 04/25/2013   | SP 1304142-001 | Coliform        | 301 Lambert                    | Water Monitoring-Even            |
|                    | 06/11/2013   | SP 1305832-001 | Coliform        | 301 Lambert                    | Water Monitoring-Even            |
|                    | 08/29/2013   | SP 1308986-001 | Coliform        | 301 Lambert                    | Water Monitoring-Even            |
|                    | 10/18/2013   | SP 1311091-001 | Coliform        | 301 Lambert                    | Water Monitoring-Even            |
|                    | 12/18/2013   | SP 1313503-001 | Coliform        | 301 Lambert                    | Water Monitoring-Even            |
| 319 A LBT          | 06/12/2012   | SP 1205836-004 | Metals, Total   | 319 A LBT                      | Copper & Lead Monitoring         |
| 3897 NSB PE        | 06/12/2012   | SP 1205836-005 | Metals, Total   | 3897 NSB Pacific Equip         | Copper & Lead Monitoring         |
| 4121 NSB           | 06/12/2012   | SP 1205836-003 | Metals, Total   | 4121 NSB                       | Copper & Lead Monitoring         |
| DBP2<br>162MONTGOM | 08/29/2013   | SP 1308985-001 | EPA 551.1       | 162 MONTOMERY AVENUE - STG 2 D | D/DBR - THMs/HAA5                |
|                    | 08/29/2013   | SP 1308985-001 | EPA 552.2       | 162 MONTOMERY AVENUE - STG 2 D | D/DBR - THMs/HAA5                |
| Well 1             | 06/29/2007   | SP 0707364-001 | Radio Chemistry | Well 01                        | Wells Monitoring                 |
|                    | 09/12/2007   | SP 0710121-001 | Radio Chemistry | Well 01                        | Radium 228 Monitoring            |
|                    | 12/14/2007   | SP 0713902-001 | Radio Chemistry | Well 01                        | Radium 228 Monitoring            |
|                    | 03/13/2008   | SP 0802758-001 | Radio Chemistry | Well 01                        | Radium 228 Monitoring            |
|                    | 01/06/2012   | SP 1200238-001 | Radio Chemistry | Well 01                        | Radiochem Monitoring             |
|                    | 04/24/2012   | SP 1204024-001 | Radio Chemistry | Well 01                        | Radiochem Monitoring             |
|                    | 05/15/2012   | SP 1204788-001 | Asbestos        | Well 01                        | Vulnerability Assessments - Req. |
|                    | 05/15/2012   | SP 1204788-001 | Wet Chemistry   | Well 01                        | Vulnerability Assessments - Req. |
|                    | 01/22/2013   | SP 1300690-001 | Coliform        | Well 01                        | Vineyard MWC                     |
|                    | 04/25/2013   | SP 1304140-001 | EPA 524.2       | Well 01                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304140-001 | General Mineral | Well 01                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304140-001 | Metals, Total   | Well 01                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304140-001 | Wet Chemistry   | Well 01                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304141-001 | Coliform        | Well 01                        | Vineyard MWC                     |
|                    | 07/18/2013   | SP 1307276-001 | Coliform        | Well 01                        | Quarterly Water Monitoring       |
|                    | 10/18/2013   | SP 1311092-001 | Coliform        | Well 01                        | Vineyard MWC                     |
| Well 2             | 06/29/2007   | SP 0707364-002 | Radio Chemistry | Well 02                        | Wells Monitoring                 |
|                    | 09/12/2007   | SP 0710121-002 | Radio Chemistry | Well 02                        | Radium 228 Monitoring            |
|                    | 12/14/2007   | SP 0713902-002 | Radio Chemistry | Well 02                        | Radium 228 Monitoring            |
|                    | 03/13/2008   | SP 0802758-002 | Radio Chemistry | Well 02                        | Radium 228 Monitoring            |
|                    | 01/06/2012   | SP 1200238-002 | Radio Chemistry | Well 02                        | Radiochem Monitoring             |
|                    | 04/24/2012   | SP 1204024-002 | Radio Chemistry | Well 02                        | Radiochem Monitoring             |
|                    | 05/15/2012   | SP 1204788-002 | Asbestos        | Well 02                        | Vulnerability Assessments - Req. |
|                    | 05/17/2012   | SP 1204890-001 | Wet Chemistry   | Well 02                        | Vulnerability Assesment Req      |
|                    | 01/22/2013   | SP 1300690-002 | Coliform        | Well 02                        | Vineyard MWC                     |
|                    | 04/25/2013   | SP 1304140-002 | EPA 524.2       | Well 02                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304140-002 | General Mineral | Well 02                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304140-002 | Metals, Total   | Well 02                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304140-002 | Wet Chemistry   | Well 02                        | Water Quality Monitoring         |
|                    | 04/25/2013   | SP 1304141-002 | Coliform        | Well 02                        | Vineyard MWC                     |
|                    | 07/18/2013   | SP 1307276-002 | Coliform        | Well 02                        | Quarterly Water Monitoring       |
|                    | 10/18/2013   | SP 1311092-002 | Coliform        | Well 02                        | Vineyard MWC                     |

# Consumer Confidence Report Certification Form

Water System Name: **VINEYARD MUTUAL WATER COMPANY/INDUSTRIAL**  
Water System Number: **5602120**

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/24/14 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified By: Name Tammy Terra

Signature 

Title Bookkeeper

Phone Number (805 ) 654-1077 Date 6/24/14

=====

*To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:*

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery method used: Distributed by mail.

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

Posted the CCR on the internet at www.

Mailed the CCR to postal patrons within the service area (attach zip codes used)

Advertised the availability of the CCR in news media (attach copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

Posted the CCR in public places (attach a list of locations)

Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses and schools

Delivery to community organizations (attach a list of organizations)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission