

2014 Drinking Water Consumer Confidence Report



Trusted life source for generations

Featuring Calendar Year 2013 Water Quality Results

Dear Valued Ventura Water Customer,

We are pleased to present important information to you about Ventura's drinking water quality for 2014. This report contains 2013 water quality testing results, explanation of our 100% local water sources, and specific information for sensitive persons. Ventura Water, a member of the City's family of services, has been providing essential around-the-clock water services since 1923 to keep our community strong and vital. On behalf of the entire staff, we thank you for taking the time to read this report that explains where your water comes from, how we treat it and what you can do to safeguard our local water sources. We proudly look forward to serving you, your family, and business today as well as future generations to come.



Sincerely,

Shana Epstein, General Manager

Our Continuing Commitment to You

Ventura Water's trained, State-licensed water professionals are committed to:

- High-quality drinking water meeting or exceeding all regulatory standards.
- A proactively maintained and reliable water system.
- A customer-focused organization that anticipates future community needs.

We know that our customers value their tap water. We appreciate your support and investment that is critical to achieving our service, operations and capital improvement goals.

For More Information

If you would like more information regarding Ventura's water quality, facility improvements, or studies, please contact Omar Castro, Water Utility Manager at (805) 652-4581. This Drinking Water Consumer Confidence Report is available in Spanish and on the City's website at www.cityofventura.net/water/ccr.

You are also invited to express your opinions at City Council meetings held most Monday evenings in the Council Chambers at Ventura City Hall, 501 Poli Street. Please visit the City Council link at www.cityofventura.net for a complete schedule.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien. Para más información o para obtener copias del informe de agua en español llame (805) 677-6500.

Water Quality Report Highlights

This year's Drinking Water Consumer Confidence Report shows:

- Ventura's drinking water quality met all State and Federal regulatory standards.
- Our staff conducts many routine tests beyond those presented in this report to monitor and optimize water quality.
- We actively monitor the quality of our water supplies and collaborate with others to maintain and improve them.
- Ventura Water's drinking water treatment systems employ multiple barriers to protect our water from disease-causing microorganisms and other constituents.
- Vulnerable populations should pursue additional information about their drinking water because no municipal or bottled drinking water is 100% "pure".



Ventura City Council

Cheryl Heitmann, Mayor
Erik Nasarenko, Deputy Mayor
Neal Andrews, Councilmember
James L. Monahan, Councilmember
Carl E. Morehouse, Councilmember
Mike Tracy, Councilmember
Christy Weir, Councilmember

Trusted life source for generations


Ventura's Water Sources & Treatment



	Ventura River	Casitas	Groundwater Wells
Supply Type	Surface Water & Groundwater	Surface Water	Groundwater
Fraction of Total Supply	10-30%	35%	35-55%
Location	At Foster Park	Lake Casitas	Victoria & Saticoy
General Service Area	West & Midtown	West	Midtown & East


Ventura is one of the largest cities in California that relies exclusively on local water supplies. We manage our water portfolio of three distinct sources based on the flow of our Ventura River supply. When more river water is available, less groundwater is used and during dryer conditions, groundwater or Lake Casitas supplies a greater percentage of your drinking water (based on your service area).

Dry Year




■ Ventura River	10%
■ Groundwater Wells	55%
■ Lake Casitas	35%

Normal Year



■ Ventura River	20%
■ Groundwater Wells	45%
■ Lake Casitas	35%

Wet Year



■ Ventura River	30%
■ Groundwater Wells	35%
■ Lake Casitas	35%

Ventura River

Ventura's oldest water supply is provided from the Ventura River at Foster Park, pumped from four shallow wells and a subsurface collector. This water drains from a 51,000-acre lower watershed in the Ojai and Ventura River Valleys that includes the tributaries of the San Antonio and the Coyote Creeks. In 2007, the Avenue Water Treatment Facility was modernized to treat this water source with membrane ultrafiltration (UF). An effective and reliable process, thousands of UF hollow fiber filtration membranes create a physical barrier to remove pathogens and particles larger than the 0.02 micron pore size, including bacteria, viruses, Giardia, and Cryptosporidium. Chloramines are added for disinfection prior to delivery into the water distribution system as well as a corrosion inhibitor to help protect the plumbing in your home and the distribution pipes.



Casitas

Treated water is purchased from the Casitas Municipal Water District (Casitas), the operator of Lake Casitas. Lake Casitas' water drains from the upper watershed and is federally protected to limit contamination of the lake. Casitas treats the water from Lake Casitas with direct media filtration and with chloramines for disinfection prior to delivery into the City's distribution system. Ventura Water works closely with Casitas through a purchase agreement of approximately 5,000 acre-feet (about 1.6 billion gallons) per year to supply in-district demand.



Groundwater Wells

Water is also pumped from deep groundwater wells located in the east side near Victoria Avenue and in Saticoy. Water quality from the aquifers in the Oxnard Plain, Mound, and Santa Paula groundwater basins are similar. Compared to water from the Ventura River or Lake Casitas, this groundwater contains about two times the amount of total dissolved solids (TDS) or minerals (hardness). The groundwater sources are treated at either the Bailey or Saticoy Plants with prechlorination and direct media filtration to remove iron, manganese, and turbidity particles, and disinfected with chloramines. A corrosion inhibitor is also added to protect the plumbing in your home and the distribution pipes.



Trusted life source for generations

Important Water Treatment Information



Ventura Water and Casitas use chloramines -- chemicals that contain chlorine and ammonia -- for continuous disinfection of the drinking water. Chloramines are preferred because of their ability to provide disinfection over a longer period of time, and improve taste and odor as compared to using chlorine alone. Chloramines have been proven to effectively kill microorganisms while producing lower levels of disinfection byproducts such as trihalomethanes (THMs) and haloacetic acids (HAAs), which are potentially harmful constituents. Drinking water containing these byproducts in excess of the regulated maximum contaminant level (MCL) may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of cancer. Starting in 2012, large water agencies were required to meet more stringent standards for these byproducts by maintaining and reporting levels at all site specific locations instead of averaging test results system wide. Ventura Water continues to successfully meet these requirements through effective management of water treatment, reservoir and distribution system operations.

Water treatment plants are continuously monitored for specific water constituents by special automated instrumentation to ensure that the process is always producing water of high quality. Turbidity is a measure of the cloudiness of the water and both Ventura Water and Casitas measure turbidity every 15 minutes as a good indicator of the effectiveness of the filtration processes, especially for surface waters. High turbidity can hinder the effectiveness of disinfectants and may indicate the presence of contaminants.

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agriculture and livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals that may be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides from a variety of sources, such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.

- Radioactive contaminants that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Water System



Since the early days of the Mission, Ventura's water system infrastructure has continually evolved, with major pipeline expansion in the 1950s and 60s with the purchase of the Saticoy and Mound Water Companies. Today, with three different water supplies, the inter-related infrastructure system is categorized by the California Department of Public Health as a "grade 5," indicating the highest degree of treatment and distribution complexity.

Booster Pump Stations	23
Storage Reservoirs	31
Valves	16,000
Meters	32,000
Fire Hydrants	3,700
Groundwater Wells	11
Lake Casitas Connections	2
Water Treatment Facilities	3
Pressure Zones	14



Connect With Us

Customer Care (805) 667-6500 myvtawater@cityofventura.net

 facebook.com/venturawater

 twitter.com/venturawaterCA

 youtube.com/venturawater

 [venturawater.org](http://www.venturawater.org)

Sign-up for *Pipeline*, our E-Newsletter at www.venturawater.net

Trusted life source for generations

Water Quality Monitoring



Ventura owns and operates a full-scale, State-certified laboratory and also uses outside State-certified labs to monitor water quality. Ventura Water submits monthly, quarterly and annual reports to the State for review that summarize treatment and distribution operations and drinking water quality. Water quality constituents that were detected by the laboratories during 2013 are listed on the Water Quality Summary Table. As reflected, our drinking water met all State and Federal water quality requirements.

The State regularly inspects the City's water system and reported in April 2013 that the City's water sources, facilities, and operations are capable of producing safe and reliable water quality. In 2011, Ventura Water met the triennial lead and copper corrosion monitoring requirements by sampling 50 locations to test consumers' tap water. The test results, provided in the Water Quality Summary Table, indicated that no additional corrosion control treatment is required. The next testing will be conducted in summer 2014.



Early detection of threats from potential contaminants is important to sustaining a healthy water supply. The five-year update to the Sanitary Survey of the Lower Ventura River Watershed was completed in 2010 (www.cityofventura.net/water/drinking). The purpose of the survey is to identify potential sources of water contamination to reduce risks to the water supply. While no

new issues were identified, the study recommends continued collaboration with stakeholders to protect the watershed. In addition, the City has voluntarily tested for specific contaminants along the Ventura River and San Antonio Creek since 2002 to aid in early identification of emerging water quality concerns.

The 1996 Safe Drinking Water Act amendments require the Environmental Protection Agency (EPA) to issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems, such as Ventura Water, once every five years. The first Unregulated Contaminant Monitoring Rule (UCMR 1) was published in 1999, the second (UCMR 2) in 2007, and the third (UCMR 3) in 2012 (<http://water.epa.gov/lawsregs/rulesregs/sdwa/ucmr/>). In accordance, Ventura Water conducted assessment monitoring of 24 unregulated contaminants for UCMR 2 and reported the results in 2010. Ventura Water will conduct testing for UCMR 3 during a 12-month period before December 2015.

The UCMR program benefits the environment and public health by providing EPA and other interested parties with scientifically valid data on the occurrence of these contaminants in drinking water. EPA uses this data to develop regulatory decisions for emerging contaminants to protect public health.

Water Supply Status



For more than a century, the City has invested in its water sources and systems to maintain a stable water supply, recognizing the importance of clean water to the health of a thriving community. The current drought highlights the importance of working together to achieve our long-term goals. As detailed in the 2014 Comprehensive Water Resources Report (www.cityofventura.net/water/supply), our collective ability to find solutions to meet the following supply and quality challenges will be essential to our water future.



Climate Change and Drought

Continued years of drought and potential impacts of climate change will require more flexibility and resiliency planning.

Environmental

Due to concerns for the health of the Ventura River ecosystem, pumping restrictions are limiting how much water and what time of year this water supply is available. Also, as a major supplier of our water, environmental challenges facing Casitas could result in both supply restrictions and higher costs to Ventura Water.

Groundwater Supply

Water allocations from groundwater basins which are shared regionally are increasingly regulated and monitored. Our quantity is limited from groundwater sources, especially during the current drought conditions.

Groundwater Quality

Water from groundwater wells contains higher levels of dissolved solids, minerals and sulfur than Ventura's other water sources. While treated groundwater meets all health requirements, its mineralized content results in deposits on plumbing fixtures and less aesthetically pleasing water quality. A program to blend water sources to reduce these levels has been in operation while more permanent options are being studied. A Groundwater Treatment Study report was completed in March 2011 that included preliminary evaluations of treatment alternatives including lime-soda chemical precipitation, ion-exchange, and reverse osmosis (RO) membrane treatment processes at the Bailey and Saticoy Treatment Plans. The study concluded that RO treatment was the preferred alternative but that more evaluation was needed to select a disposal method for the concentrate that would be generated by this process. To determine if there is community support to improve the quality of this water supply, Ventura Water will be developing a public outreach strategy and program.

Trusted life source for generations

Potential Concerns For Vulnerable Populations



Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).



If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Ventura Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in residential or commercial property plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Ventura Water and Casitas use chloramines for continuous disinfection of the drinking water and its presence requires additional precautions for some water uses. If a member of your household requires dialysis, you should contact your physician or dialysis service provider to assure proper protective equipment is used during the treatment. If you use tap water for fish or other aquatic animals that use gills for breathing, you need to test and be sure the chloramines are completely removed before use. Setting water in an open container for 24 hours prior to use will not remove all chloramines in the water. Your local pet store can provide information and products for the proper removal of chloramines.

Public Health Goals Reporting



As a water supplier, the City must evaluate its drinking water supply every three years with respect to Public Health Goals (PHG). The goals are advisory only and are not mandatory limits, but do require public notification. To fulfill this requirement, a public meeting was held in July 2013 to review the Triennial Public Health Goals Report (www.cityofventura.net/water/drinking). The next Triennial Public Health Goals Report is scheduled to be prepared and presented by July 2016.

Water Efficiency



Since our community relies 100% on local water sources, we live, work and play within the watersheds that supply us and our surrounding natural ecosystems with vital water resources. It is our collective responsibility to safeguard our water and use water efficiently in all ways, especially during dry conditions. Here are some quick tips (www.cityofventura.net/water/efficiency) to help you be a good water steward:

- Use lawn and garden fertilizers and pesticides sparingly – they contain hazardous chemicals that can reach your drinking water source.
- Always pick up after your pets – even in your own yard.
- Dispose of chemicals properly at a Household Hazardous Waste event (www.cityofventura.net/HHW).
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and early in the mornings to reduce evaporation.
- Fix leaking toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Take short showers and use a water-efficient showerhead. They are inexpensive, easy to install, and can save up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full to save up to 1,000 gallons a month.
- Teach your children about water conservation so that the next generation learns to use water wisely. Make it a family effort to reduce next month's water usage!

Trusted life source for generations

Water Quality Terminology



The Water Quality Summary shows constituents measured in Ventura's water and reported to the State Department of Health Services, and in some cases the USEPA. Some of the terminology used is described below:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary (health related) MCLs are set as close to the Public Health Goals (PHGs) or Maximum Contaminant Level Goals (MCLGs) as is economically and technologically feasible. Secondary (aesthetically related) MCLs are set to protect the odor, taste and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of contaminant in drinking water below which there is no known or expected risk to one's health. MCLGs are set by the USEPA.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to one's health. The California Environmental Protection Agency sets PHGs.

Maximum Residual Disinfectant Level (MRDL): The maximum level of a disinfectant added for water treatment that may not exceed at the customer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standard (SDWS): MCLs for contaminants that affect taste, odor, or appearance of drinking water. Secondary contaminants are not based on health effects at MCL levels.

Regulatory Action Level (RAL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

Notification Level (NL): Notification levels are health-based levels established by CDPH for chemicals in drinking water that lack MCLs.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Footnotes



- 1 Process and source variations.
 - 2 Erosion of natural deposits.
 - 3 Erosion of natural deposits; runoff from orchards; glass and electronics production waste.
 - 4 Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
 - 5 Discharge from refineries or manufacturers; erosion of natural deposits.
 - 6 Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.
 - 7 Leaching from ore-processing sites, discharge from electronics and glass factories.
 - 8 Internal corrosion of household plumbing systems.
- (a) Average is maximum reading. Avenue Plant Surface Filtration (TT) = 95% of samples equal or below 0.1 NTU.
 - (b) Average is maximum reading. CMWD Direct Filtration (TT) = 100% of samples equal or below 0.2 NTU.
 - (c) Highest running average cannot exceed the MCL.
 - (d) Samples were taken at selected households on a first draw in August 2011.
 - (e) Monitoring completed in 2012.

Legend



ppm	Parts per million or milligrams per liter.
ppb	Parts per billion or micrograms per liter.
pCi/l	Picocuries per liter, a measure of radioactivity in water.
CMWD	Casitas Municipal Water District
UMHOS	Micro Ohms per Centimeter
<	Less than
TT	A required treatment technique intended to reduce the level of contaminant in drinking water
NA	Not applicable
ND	Not detectable
NS	No standard
NTU	Turbidity, a measure of the clarity or cloudiness of the water.

Trusted life source for generations

Trusted life source for generations

Using Data Collected in 2013 Unless Noted

PRIMARY STANDARDS (PDWS)	Units	Maximum Level MCL	State Goal PHG (MCLG)	Ventura River Average	Ventura River Range	Ground Water Average	Ground Water Range	CMWD Average	CMWD Range	Major Sources of Contamination in Drinking Water (Footnotes)
Water Clarity Treated Turbidity	NTU	TT	NA	0.06(a)	.03-.30	0.24	0.1 - 1.1	0.09(b)	0.09	1
Radioactive Contaminants (e) Gross Alpha particle activity	pCi/l	15	(0)	3.81	.39-10	7.2	4.34 - 9.35	ND	ND	2
Radium 226	pCi/l	5	0.05	0.1	ND-0.3	0.463	ND - 0.9	NA	NA	2
Uranium (c)	pCi/l	20	0.43	3.16	1.5 - 4.9	5.58	3.39 - 9.81	NA	NA	2
Inorganic Contaminants Fluoride	ppm	2	1	0.51	.48-.54	0.55	.44-.65	0.5	0.5	4
Selenium	ppb	50	50	ND	ND-3	7.8	ND-25	ND	ND	5
Nitrate (as Nitrogen)	ppm	10	10	0.87	.6-1.0	1.7	ND-4.8	0.5	0.5	6
Thalium	ppb	2	0.1	ND	ND	ND	ND	NA	NA	7
Lead and Copper Samples	Units	RAL	PHG	Samples Collected	Above RAL	90th Percentile	Major Sources of Contamination in Drinking Water			
Lead	ppb	15	0.2	51(d)	0	1	8			
Copper	ppb	1300	300	51(d)	1	1054	8			
PRIMARY STANDARDS for Distribution System	Units	MCL (MRDL)	PHG (MRDLG)	Distribution System Average	Distribution System Range	Major Sources of Contamination in Drinking Water				
Disinfection Chloramine Residual	ppm	(MRDL) 4	(MRDLG) 4	(MRDL) 2.6	(MRDL) 2.36-2.80	Drinking water disinfectant added for treatment.				
Disinfection By Products Total Trihalomethanes	ppb	80	NA	55.8(c)	22-90	By-product of drinking water chlorination.				
Total Haloacetic Acids	ppb	60	NA	42.5(c)	13-56	By-product of drinking water chlorination.				
Microbiological Contaminant Samples		No more than								
Total Coliform Bacteria	NA	5%	0	0	0	Naturally present in the environment.				
Fecal Coliform Bacteria	NA	0	0	0	0	Human and animal fecal waste.				
SECONDARY STANDARDS	Units	Maximum Contaminant Level	Ventura River Average	Ventura River Range	Ground Water Average	Ground Water Range	CMWD Average	CMWD Range		
Aesthetic Standards Color	Color	15	ND	ND	5	ND-10	ND	ND		
Odor	Threshold	3	ND	ND	ND	ND	ND	ND		
Chloride	ppm	500	53	46-61	69	54-95	18	18		
Manganese	ppb	50	ND	ND	ND	ND-.15	ND	ND		
Iron	ppb	300	ND	ND	ND	ND-760	ND	ND		
Total Dissolved Solids	ppm	1000	754	681-821	1296	969-1662	340	340		
Specific Conductance	umhos	1600	1038	939-1078	1699	1166-2000	547	547		
Sulfate	ppm	500	244	238-254	559	449-741	135	135		
Zinc	ppm	5	0.06	.06-.08	0.16	.13-.22	ND	ND		
Additional Constituents pH	pH units	NS	NS	7.6-7.9	7.3	7.1-7.5	7.3	7.3		
Hardness	ppm	NS	446	407-504	671	517-939	224	224		
Calcium	ppm	NS	124	114-138	182	132-244	52	52		
Magnesium	ppm	NS	29	28-30	49	42-59	22	22		
Corrosivity	ppb	Non Corrosive(+)	0.74	.63-.94	0.41	.24-.74	-0.4	-0.4		
Sodium	ppm	NS	51	48-54	140	101-235	52	52		
Phosphate	ppm	NS	ND	ND	0.07	ND-.17	ND	ND		
Potassium	ppm	NS	2.2	2.1-2.4	4.97	4.0-7.0	3	3		
Total Alkalinity	ppm	NS	241	227-262	265	250-293	120	120		



The official 2014 California car

We're going to extremes because
Californians Don't Waste.



The official 2014 California shower

Take five and no more because
Californians Don't Waste.



The official 2014 California sprinkler

Use more efficient watering systems because
Californians Don't Waste.



In compliance with the Americans with Disabilities Act, this document is available in alternate formats by calling 805-677-6500 or by contacting the California Relay Service.

De acuerdo con el Acto de Americanos con Incapacidades, este documento está disponible en formatos alternativos llamando al 805-677-6500 o el Servicio de Retransmisión de California.

