

2014 Consumer Confidence Report

Water System Name: Big Valley Primary School Report Date: May 14, 2015.

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2011.

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Underground Well

Name & location of source(s): Well Number 2, located at the Big Valley Primary School. South of the main building on the grass play area. In Adin, California.

Drinking Water Source Assessment information: Completed April 2002. Copies available at District Office or call number below.

Time and place of regularly scheduled board meetings for public participation: School board meetings Held on the third Wednesday of every month at 6:00 pm, in the Big Valley High School building.

For more information, contact Mike Williams Phone: (530) 294-5266

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

pCi/L: picocuries per liter (a measure of radiation)

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

| Microbiological Contaminants | Highest No. of detections | No. of months in violation | MCL | MCLG | Typical Source of Bacteria |
|------------------------------|---------------------------|----------------------------|---|------|--------------------------------------|
| Total Coliform Bacteria | 0 | 0 | More than 1 sample in a month with a detection | 0 | Naturally present in the environment |
| Fecal Coliform or E. coli | 0 | 0 | A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or E. coli | 0 | Human and animal fecal waste |

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

| Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set) | No. of samples collected | 90 th percentile level detected | No. Sites exceeding AL | AL | MCLG | Typical Source of Contaminant |
|---|--------------------------|--|------------------------|------|------|--|
| Lead (ppb) 7/28/2014 | 5 | 1.4 | 0 | 15 | 2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits. |
| Copper (ppb) 7/28/2014 | 5 | 103 | 0 | 1300 | 170 | Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives. |

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|-------------|----------------|---------------------|------|---------------|---|
| Sodium (ppm) | 12/27/01 | 11.6 | N/A | none | none | Generally found in ground and surface water |
| Hardness (ppm) | 12/27/01 | 76.3 | N/A | none | none | Generally found in ground and surface water |

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|-------------|----------------|---------------------|------|---------------|--|
| Nitrate, as NO ₃ (ppm) | 7/10/14 | 10.1 | N/A | 45 | 45 | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits. |
| Nitrate, as N (ppm) | 3/13/08 | 3.2 | N/A | 10 | 10 | Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits. |
| Fluoride (ppm) | 7/8/10 | 0.3 | N/A | 2 | 1 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Barium (ppb) | 7/8/10 | 48.4 | N/A | 1000 | 2000 | Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits. |
| Chromium (ppb) | 7/8/10 | 2 | N/A | 50 | | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits. |
| Mercury (ppb) | 7/8/10 | 0.06 | N/A | 2 | 1.2 | Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and croplands. |

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|--|-------------|----------------|---------------------|------|---------------|--|
| Total Dissolved Solids TDS (ppm) | 12/27/01 | 181 | N/A | 1000 | N/A | Runoff/leaching from natural deposits. |
| Specific Conductance (micromhos) | 12/27/01 | 199 | N/A | 1600 | N/A | Substances that form ions when in water; seawater influence. |
| Sulfate (ppm) | 12/27/01 | 3.9 | N/A | 500 | N/A | Runoff/leaching from natural deposits; industrial wastes. |
| Chloride (ppm) | 12/27/01 | 3.3 | N/A | 500 | N/A | Runoff/leaching from natural deposits; seawater influence |

| | | | | | | |
|------------|----------|------|-----|------|-----|---|
| Zinc (ppb) | 12/27/01 | 14.9 | N/A | 5000 | N/A | Runoff/leaching from natural deposits; industrial wastes. |
|------------|----------|------|-----|------|-----|---|

TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS

| Chemical or Constituent | Sample Date | Level Detected | Action Level | Health Effects Language |
|-------------------------|-------------|----------------|--------------|--|
| Vanadium (ppb) | 12/27/01 | 29.1 | 50 | The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals. |

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).