

ATTACHMENT 7

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certific/drinkingwater/CCR.shtml)

Water System Name: Rancho Pauma Mutual Water Company

Water System Number: 3710012

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 5/1/2015 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Melinda Houser
Signature: Melinda Houser
Title: Administrator
Phone Number: (760) 742 - 1909 Date: 4.1.15

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: A notice will be mailed to all bill paying consumers, referring them to the URL where the Consumer Confidence Report is located.
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - Posting the CCR on the Internet at www.
 - Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - Advertising the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - Posted the CCR in public places (attach a list of locations)
 - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

Rancho Pauma Mutual Water Company

2014 Consumer Confidence Report

The Consumer Confidence Report, or CCR, is an annual water quality report that the Safe Drinking Water Act (SDWA) requires Rancho Pauma MWC to provide you with. The purpose of the CCR is to raise customers' awareness of the quality of their drinking water, where their drinking water comes from and the importance of protecting drinking water sources.

In past years, Rancho Pauma MWC has mailed its customers a printed copy of the CCR to comply with the SDWA.

On February 21, 2013, the California Department of Public Health expanded its interpretation of the SDWA to allow for electronic delivery of the CCR. The electronic delivery method will allow Rancho Pauma MWC to reduce the consumption of paper, printing and mailing costs.

This notice contains instructions for you to obtain important information about your drinking water.

Translate it, or speak with someone who understands it.

Este reporte contiene las instrucciones mas recientes para obtener informacion importante sobre su agua potable. Traducir, o hablar con alguien que lo entienda.

To view your 2014 Consumer Confidence Report and to learn more about your drinking water, please visit the following URL:

<http://paumavalleycsd.com/pdfs/2014ConsumerConfidenceReport.pdf>

If you would like a paper copy of the 2014 CCR mailed to you, or would like to speak with someone about the report, please call (760) 742-1909.

WATER QUALITY REPORT: 2014 RANCHO PAUMA MUTUAL WATER CO.

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water sources in use: RPMWC relies on local groundwater.

Name & location of source: RPMWC receives all of its water from 7 domestic wells.

Drinking Water Source Assessment information: Drinking Water Source Assessments have been completed for your drinking water in 2002, 2007 and in 2013. The sources are considered most vulnerable to the following activities not associated with any detected contaminants: Sewer collection systems, agricultural/irrigation wells, paved roads, pesticide/fertilizer/petroleum storage, wastewater treatment plants, an airstrip, and maintenance/fueling areas. For more information regarding the Drinking Water Source Assessments please contact the Division of Drinking Water (DDW) at (619) 525-4159.

Time and place of regularly scheduled board meetings: Board meetings are held quarterly in the Company's boardroom, located at 33129 Cole Grade Road, Pauma Valley, CA. Meetings are open to the shareholders.

For more information, contact: Mindy Houser, Administrator, phone: (760) 742-1909

TERMS USED IN THIS REPORT:

• **Maximum Contaminant Level (MCL):** The highest level of a contaminant allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

• **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to one's health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

• **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to one's health. PHGs are set by the California Environmental Protection Agency.

• **Maximum Residual disinfectant Level (MRDL):** The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

• **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. These are set by the U.S. Environmental Protection Agency.

1 part per million (mg/L) is: **1 part per billion (ug/L) is:**

- 1 minute in 2 years
- 1 inch in 16 miles
- 1 drop in 10 gallons
- 1 minute in 2000 years
- 1 inch in 16,000 miles
- 1 drop in 10000 gallons

• **N/A:** Not applicable.

• **Notification Level (NL):** Notification levels are health-based advisory levels for contaminants without a MCL.

• **Primary Drinking Water Standards (PDWS):** MCLs or MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

• **Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

• **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

• **Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements, that a water system must follow.

• **Variances and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

• **ppm or mg/L:** Part per million or milligrams per liter.

• **ppb or ug/L:** Part per billion or micrograms per liter.

• **RAA:** Running Annual Average: The highest RAA is the highest of all Running Annual Averages. It is calculated as an average of all the samples collected within a 12-month period.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, that may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1,2,3,4 & 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (completed if bacteria detected)	Highest No. of detections	No. of Months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a month) 0	0	More than 1 sample in a given month with detection	0	Naturally present in the environment
Fecal Coliform or <i>e. coli</i>	0	0	A routine sample and a repeat sample detect total coliform, and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION LEAD AND COPPER

Lead and Copper (Tested every 3 years. Data is from 2013)	Sample Date	No. of samples collected	90 th percentile level detected	No. of sites exceeding Action Level	Action Level	PHG	Typical Source of Contaminant
Lead (ug/L)	7/2013	10	ND	0	15	0.2	Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (mg/L)	7/2013	10	0.56	0	1.3	0.3	Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural deposits

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample date	Level Detected (average)	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (mg/L)	2014	66	52 - 130	NA	NA	Salt present in the water is generally naturally occurring
Hardness (mg/L)	2014	389	250 - 710	NA	NA	Sum of polyvalent cations present in the water, generally magnesium and calcium are naturally occurring
Magnesium (ppm)	2014	34	22-67	NA	NA	A mineral involved in many processes in the body including nerve signaling, the building of healthy bones, and normal muscle contractions

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample date	Level Detected (average)	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Gross Alpha (pCi/L)	2014	2.16	1.13 - 3.19	15	(0)	Erosion of natural deposits
Barium (mg/L)	2014	1	1 - 2	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (mg/L)	2014	.2	.1 - .2	2	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as nitrate, NO ₃) (mg/L)	2014	14	4.3 - 45	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ug/L)	2014	2.2	5.5 - 10	50	30	Discharge from petroleum, glass, and metal refineries ; erosion of natural deposits; discharge from mines and chemical manufactures; runoff from livestock lots (feed additive)

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample date	Level Detected (average)	Range of Detections	MCL	PHG	Typical Source of Contaminant
Total Dissolved Solids (mg/L)	2014	671	450 - 1250	1000	NA	Runoff/leaching from natural deposits
Chloride (mg/L)	2014	101	59 - 175	500	NA	Runoff/leaching from natural deposits; seawater influence
pH (units)	2014	7.2	6.9 – 7.5	NA	NA	Naturally occurring
Potassium (mg/L)	2014	4.7	4.0 – 5.8	NA	NA	Runoff/leaching from natural deposits
Sulfate (ppm)	2014	420	71-178	500	NA	Runoff/leaching from natural deposits; industrial wastes
Specific Conductance	2014	1000	730-1700	1600	NA	Substances that form ions when in water; seawater influence

Additional General Information on Drinking Water

Drinking water, included bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rancho Pauma Mutual Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.