

# 2014 Consumer Confidence Report

Water System Name: SJ COUNTY HOUSING AUTHORITY

Report Date: June 2015

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** This info is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

**Your water comes from 1 source(s):** Well #2

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (209) 838 - 7842 and ask for Quality Service, Inc..

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA</b>					
<b>Microbiological Contaminants</b> (complete if bacteria detected)	<b>Highest No. of Detections</b>	<b>No. of Months in Violation</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Sources of Contaminant</b>
Total Coliform Bacteria	5/mo. (2014)	5	no more than 1 positive monthly sample	0	Naturally present in the environment.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>						
<b>Lead and Copper</b> (complete if lead or copper detected in last sample set)	<b>Sample Date</b>	<b>90th percentile level detected</b>	<b>No. Sites Exceeding AL</b>	<b>AL</b>	<b>PHG</b>	<b>Typical Sources of Contaminant</b>
Copper (ppm)	5 (2012)	0.05	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

<b>Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Sodium (ppm)	(2013)	15	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2013)	67.8	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

<b>Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>

Hexavalent Chromium (ppb)	(2014)	2.8	N/A	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Fluoride (ppm)	(2013)	0.1	N/A	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (ppm)	(2014)	3.8	N/A	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2013)	0.9	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

**Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2013)	6	N/A	500	n/a	Runoff/leaching from natural deposits; seawater influence
Odor Threshold at 60 °C (TON)	(2013)	1	N/A	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2013)	225	N/A	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2013)	6	N/A	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2013)	180	N/A	1000	n/a	Runoff/leaching from natural deposits

**Table 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Vanadium (ppm)	(2013)	0.02	N/A	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Quality Service-SJCo Housing Authority* is

responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## **Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement**

**About our Total Coliform Bacteria:** Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

## **2014 Consumer Confidence Report Drinking Water Assessment Information**

### **Assessment Information**

According to the Drinking Water Source Assessment and Protection Program`s Source Water Assessments Public Access web page, the Public Water Sources WELL #2 of the S J COUNTY HOUSING AUTHORITY water system number 3900581, does not have a completed Source Water Assessment on file.

Well #2 - This info is not available, as this water system does not have a completed assessment on file.

### **Discussion of Vulnerability**

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

### **Acquiring Information**

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

## Quality Service-SJCo Housing Authority Analytical Results By FGL - 2014

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Total Coliform Bacteria</b>			0	5%	n/a			5	1 - 47.8
Inlet to Storage	STK1450495-1					2014-10-10	<1.0		
Office	STK1438847-1					2014-08-29	<1.0		
Office	STK1438847-5					2014-08-29	<1.0		
Pressure Tank	STK1450836-4					2014-10-27	<1.0		
Pressure Tank	STK1450741-2					2014-10-16	<1.0		
Pressure Tank	STK1439821-2					2014-09-24	34.4		
Pressure Tank	STK1439655-3					2014-09-19	<1.0		
Pressure Tank	STK1438847-2					2014-08-29	<1.0		
Pressure Tank	STK1437484-1					2014-07-24	5.3		
Pressure Tank	STK1435996-4					2014-06-19	<1.0		
Pressure Tank	STK1435185-3					2014-05-29	<1.0		
Pressure Tank	STK1435080-3					2014-05-27	<1.0		
Pressure Tank	STK1434926-3					2014-05-22	1		
Pressure Tank	STK1432628-4					2014-03-27	<1.0		
Pressure Tank	STK1432304-3					2014-03-14	<1.0		
Pressure Tank	STK1431571-4					2014-02-18	2		
Rear of Shop	STK1450741-1					2014-10-16	<1.0		
Rear of Shop	STK1439821-1					2014-09-24	40.6		
Rear of Shop	STK1439655-1					2014-09-19	<1.0		
Rear of Shop	STK1437484-2					2014-07-24	8.7		
Rear of Shop	STK1435185-1					2014-05-29	<1.0		
Rear of Shop	STK1435080-2					2014-05-27	<1.0		
Rear of Shop	STK1434926-1					2014-05-22	<1.0		
Rear of Shop	STK1432628-3					2014-03-27	<1.0		
Rear of Shop	STK1432304-1					2014-03-14	<1.0		
Rear of Shop	STK1431571-2					2014-02-18	5.3		
Routine 1 @ 14320 Harney Lane	STK1451695-1					2014-11-18	Absent		
Routine 1 @ 14320 Harney Lane	STK1450836-3					2014-10-27	<1.0		
Routine 1 @ 14320 Harney Lane	STK1439596-1					2014-09-17	Present		
Routine 1 @ 14320 Harney Lane	STK1437305-1					2014-07-22	Present		
Routine 1 @ 14320 Harney Lane	STK1435996-3					2014-06-19	<1.0		
Routine 1 @ 14320 Harney Lane	STK1434784-1					2014-05-21	Present		
Routine 1 @ 14320 Harney Lane	STK1432628-1					2014-03-27	<1.0		
Routine 1 @ 14320 Harney Lane	STK1432628-2					2014-03-27	<1.0		
Routine 1 @ 14320 Harney Lane	STK1430641-1					2014-01-21	Absent		
Routine 2 @14320 Harney Lane	STK1452593-1					2014-12-12	Absent		
Routine 2 @14320 Harney Lane	STK1450836-1					2014-10-27	<1.0		
Routine 2 @14320 Harney Lane	STK1450836-2					2014-10-27	<1.0		
Routine 2 @14320 Harney Lane	STK1435996-2					2014-06-19	<1.0		
Routine 2 @14320 Harney Lane	STK1435996-1					2014-06-19	<1.0		
Routine 2 @14320 Harney Lane	STK1433730-1					2014-04-23	Absent		
Routine 2 @14320 Harney Lane	STK1431422-1					2014-02-17	Present		
Sample Tap @ 75/76	STK1450741-3					2014-10-16	<1.0		
Sample Tap @ 75/76	STK1439821-3					2014-09-24	47.8		
Sample Tap @ 75/76	STK1439655-2					2014-09-19	1		
Sample Tap @ 75/76	STK1438847-4					2014-08-29	<1.0		
Sample Tap @ 75/76	STK1437484-3					2014-07-24	8.7		
Sample Tap @ 75/76	STK1435185-2					2014-05-29	<1.0		
Sample Tap @ 75/76	STK1435080-1					2014-05-27	1		
Sample Tap @ 75/76	STK1434926-2					2014-05-22	<1.0		
Sample Tap @ 75/76	STK1432304-2					2014-03-14	<1.0		
Sample Tap @ 75/76	STK1431571-3					2014-02-18	4.2		

Tank #1 Eff	STK1450495-2					2014-10-10	1		
Tank #2 Eff	STK1450495-3					2014-10-10	1		
Tank #3 Eff	STK1450495-4					2014-10-10	2		

**LEAD AND COPPER RULE**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Copper</b>		ppm		1.3	.3			0.05	5
Unit A17	STK1236459-3	ppm				2012-07-06	0.05		
Unit A23	STK1236459-2	ppm				2012-07-06	0.05		
Unit B42	STK1236459-1	ppm				2012-07-06	ND		
Unit C61	STK1236459-5	ppm				2012-07-06	ND		
Unit D78	STK1236459-4	ppm				2012-07-06	ND		

**SAMPLING RESULTS FOR SODIUM AND HARDNESS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		ppm		none	none			15	15 - 15
Well #2	STK1332386-1	ppm				2013-03-19	15		
<b>Hardness</b>		ppm		none	none			67.8	67.8 - 67.8
Well #2	STK1332386-1	ppm				2013-03-19	67.8		

**PRIMARY DRINKING WATER STANDARDS (PDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Hexavalent Chromium</b>		ppb		10	0.02			2.8	2.8 - 2.8
Well #2	STK1451694-1	ppb				2014-11-18	2.8		
<b>Fluoride</b>		ppm		2	1			0.1	0.1 - 0.1
Well #2	STK1332386-1	ppm				2013-03-19	0.1		
<b>Nitrate</b>		ppm		45	45			3.8	3.8 - 3.8
Well #2	STK1432629-1	ppm				2014-03-27	3.8		
<b>Nitrate + Nitrite as N</b>		ppm		10	10			0.9	0.9 - 0.9
Well #2	STK1332386-1	ppm				2013-03-19	0.9		

**SECONDARY DRINKING WATER STANDARDS (SDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>		ppm		500	n/a			6	6 - 6
Well #2	STK1332386-1	ppm				2013-03-19	6		
<b>Odor Threshold at 60 °C</b>		TON		3	n/a			1	1 - 1
Well #2	STK1332386-1	TON				2013-03-19	1		
<b>Specific Conductance</b>		umhos/cm		1600	n/a			225	225 - 225
Well #2	STK1332386-1	umhos/cm				2013-03-19	225		
<b>Sulfate</b>		ppm		500	n/a			6	6 - 6
Well #2	STK1332386-1	ppm				2013-03-19	6		
<b>Total Dissolved Solids</b>		ppm		1000	n/a			180	180 - 180
Well #2	STK1332386-1	ppm				2013-03-19	180		

**UNREGULATED CONTAMINANTS**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Vanadium</b>		ppm		NS	n/a			0.02	0.02 - 0.02
Well #2	STK1332386-1	ppm				2013-03-19	0.02		

## Quality Service-SJCo Housing Authority CCR Login Linkage - 2014

FGL Code	Lab ID	Date Sampled	Method	Description	Property
INLET to STRGE	STK1450495-1	2014-10-10	Coliform	Inlet to Storage	Bacteriological Sampling
OFFICE	STK1438847-1	2014-08-29	Coliform	Office	Water Monitoring
	STK1438847-5	2014-08-29	Coliform	Office	Water Monitoring
Press. Tank	STK1431571-4	2014-02-18	Coliform	Pressure Tank	Water Monitoring
PT	STK1432304-3	2014-03-14	Coliform	Pressure Tank	Water Monitoring
	STK1432628-4	2014-03-27	Coliform	Pressure Tank	Water Monitoring
	STK1434926-3	2014-05-22	Coliform	Pressure Tank	Water Monitoring
	STK1435080-3	2014-05-27	Coliform	Pressure Tank	Water Monitoring
	STK1435185-3	2014-05-29	Coliform	Pressure Tank	Water Monitoring
	STK1435996-4	2014-06-19	Coliform	Pressure Tank	Water Monitoring
	STK1437484-1	2014-07-24	Coliform	Pressure Tank	Water Monitoring
	STK1438847-2	2014-08-29	Coliform	Pressure Tank	Water Monitoring
	STK1439655-3	2014-09-19	Coliform	Pressure Tank	Water Monitoring
	STK1439821-2	2014-09-24	Coliform	Pressure Tank	Water Monitoring
	STK1450741-2	2014-10-16	Coliform	Pressure Tank	Water Monitoring
	STK1450836-4	2014-10-27	Coliform	Pressure Tank	Water Monitoring
Rear of Shop	STK1431571-2	2014-02-18	Coliform	Rear of Shop	Water Monitoring
REAR OF SHOP	STK1432304-1	2014-03-14	Coliform	Rear of Shop	Water Monitoring
	STK1432628-3	2014-03-27	Coliform	Rear of Shop	Water Monitoring
	STK1434926-1	2014-05-22	Coliform	Rear of Shop	Water Monitoring
	STK1435080-2	2014-05-27	Coliform	Rear of Shop	Water Monitoring
	STK1435185-1	2014-05-29	Coliform	Rear of Shop	Water Monitoring
	STK1437484-2	2014-07-24	Coliform	Rear of Shop	Water Monitoring
	STK1439655-1	2014-09-19	Coliform	Rear of Shop	Water Monitoring
	STK1439821-1	2014-09-24	Coliform	Rear of Shop	Water Monitoring
	STK1450741-1	2014-10-16	Coliform	Rear of Shop	Water Monitoring
ROUTINE 1@143	STK1430641-1	2014-01-21	Coliform	Routine 1 @ 14320 Harney Lane	Bacteriological Sampling-Odd
	STK1432628-1	2014-03-27	Coliform	Routine 1 @ 14320 Harney Lane	Bacteriological Sampling-Odd
	STK1432628-2	2014-03-27	Coliform	Routine 1 @ 14320 Harney Lane	Water Monitoring
	STK1434784-1	2014-05-21	Coliform	Routine 1 @ 14320 Harney Lane	Bacteriological Sampling-Odd
	STK1435996-3	2014-06-19	Coliform	Routine 1 @ 14320 Harney Lane	Water Monitoring
	STK1437305-1	2014-07-22	Coliform	Routine 1 @ 14320 Harney Lane	Bacteriological Sampling-Odd
	STK1439596-1	2014-09-17	Coliform	Routine 1 @ 14320 Harney Lane	Bacteriological Sampling-Odd
	STK1450836-3	2014-10-27	Coliform	Routine 1 @ 14320 Harney Lane	Water Monitoring
	STK1451695-1	2014-11-18	Coliform	Routine 1 @ 14320 Harney Lane	Bacteriological Sampling-Odd
ROUTINE 2	STK1431422-1	2014-02-17	Coliform	Routine 2 @14320 Harney Lane	Bacteriological Sampling-Even
	STK1433730-1	2014-04-23	Coliform	Routine 2 @14320 Harney Lane	Bacteriological Sampling-Even
	STK1435996-1	2014-06-19	Coliform	Routine 2 @14320 Harney Lane	Bacteriological Sampling-Even
	STK1435996-2	2014-06-19	Coliform	Routine 2 @14320 Harney Lane	Water Monitoring
	STK1450836-1	2014-10-27	Coliform	Routine 2 @14320 Harney Lane	Water Monitoring
	STK1450836-2	2014-10-27	Coliform	Routine 2 @14320 Harney Lane	Water Monitoring
	STK1452593-1	2014-12-12	Coliform	Routine 2 @14320 Harney Lane	Bacteriological Sampling-Even
STap@75/76	STK1431571-3	2014-02-18	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1432304-2	2014-03-14	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1434926-2	2014-05-22	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1435080-1	2014-05-27	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1435185-2	2014-05-29	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1437484-3	2014-07-24	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1438847-4	2014-08-29	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1439655-2	2014-09-19	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1439821-3	2014-09-24	Coliform	Sample Tap @ 75/76	Water Monitoring
	STK1450741-3	2014-10-16	Coliform	Sample Tap @ 75/76	Water Monitoring
TANK #1 EFF	STK1450495-2	2014-10-10	Coliform	Tank #1 Eff	Bacteriological Sampling
Tank #2 Eff	STK1450495-3	2014-10-10	Coliform	Tank #2 Eff	Bacteriological Sampling
TANK #3 EFF	STK1450495-4	2014-10-10	Coliform	Tank #3 Eff	Bacteriological Sampling

Unit A17	STK1236459-3	2012-07-06	Metals, Total	Unit A17	Copper & Lead Monitoring
Unit A23	STK1236459-2	2012-07-06	Metals, Total	Unit A23	Copper & Lead Monitoring
Unit B42	STK1236459-1	2012-07-06	Metals, Total	Unit B42	Copper & Lead Monitoring
Unit C61	STK1236459-5	2012-07-06	Metals, Total	Unit C61	Copper & Lead Monitoring
Unit D78	STK1236459-4	2012-07-06	Metals, Total	Unit D78	Copper & Lead Monitoring
Well #2	STK1332386-1	2013-03-19	Metals, Total	Well #2	Harney Lane - Well #2
	STK1332386-1	2013-03-19	Wet Chemistry	Well #2	Harney Lane - Well #2
	STK1332386-1	2013-03-19	General Mineral	Well #2	Harney Lane - Well #2
	STK1432629-1	2014-03-27	Wet Chemistry	Well #2	Harney Lane - Well #2
WELL #2	STK1451694-1	2014-11-18	Wet Chemistry	Well #2	Chrome 6 Monitoring