2014 Consumer Confidence Report

Water System Name: BROOKSIDE MEADOWS ESTATE Report Date: June 2015

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alquien que lo entienda bien.

Type of water source(s) in use: According to CDPH records, this Source is Groundwater.

Your water comes from 1 source(s): Well #1

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held at 1613 Gary Wy, Carmichael, CA 95608 every December 30th at 11:00a.m.

For more information about this report, or any questions relating to your drinking water, please call (209) 838-7842 and ask for Quality Service, Inc..

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system mush follow.

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants,* such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants,* such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides,* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants,* including synthetic and volatile organic chemicals, that are by-products if industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants,* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	15/mo. (2014)	6	no more than 1 positive monthly sample	0	Naturally present in the environment.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (ppm)	5 (2013)	0.33	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2013)	18	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2013)	175	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL [MRDL]**	**PHG (MCLG) [MRDLG]**	**Typical Sources of Contaminant**
Arsenic (ppb)	(2013)	2	N/A	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (ppm)	(2013)	0.11	N/A	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	(2013)	0.1	N/A	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Hexavalent Chromium (ppb)	(2014)	4.2	N/A	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate (ppm)	(2014)	16.7	N/A	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2013)	3.2	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2013)	2.91	N/A	15	(0)	Erosion of natural deposits.

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Sources of Contaminant**
Chloride (ppm)	(2013)	24	N/A	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2013)	150	N/A	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	(2013)	20	N/A	50	n/a	Leaching from natural deposits
Odor Threshold at 60 °C (TON)	(2013)	1	N/A	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2013)	430	N/A	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2013)	10	N/A	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2013)	310	N/A	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2013)	1.8	N/A	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**Notification Level**	**Typical Sources of Contaminant**
Vanadium (ppm)	(2013)	0.02	N/A	0.05	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Brookside Meadows Estate* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Total Coliform Bacteria: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

2014 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information
Vulnerability Summary Page of the Drinking Water Source Assessment for the Well Head Source is on file at County of San Joaquin Environmental Health Department

Brookside Meadows Estate

Analytical Results By FGL - 2014

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			6	1 - 40.6
After Pressure Tank	STK1451063-4					2014-10-30	1		
After Pressure Tank	STK1450166-3					2014-10-03	<1.0		
After Pressure Tank	STK1439558-3					2014-09-16	1		
After Pressure Tank	STK1435459-3					2014-06-04	<1.0		
HB Middle East Wall	STK1453044-4					2014-12-29	1		
HB Middle West Wall	STK1453044-1					2014-12-29	2		
HB West Courtyard	STK1453044-2					2014-12-29	<1.0		
HB West of Entrance	STK1453082-3					2014-12-30	<1.0		
HB West of Entrance	STK1453043-1					2014-12-29	5.3		
HB West of Entrance	STK1453043-2					2014-12-29	1		
HB West of Entrance	STK1452940-1					2014-12-22	15		
HB West of Entrance	STK1452775-1					2014-12-16	15		
HB West of Entrance	STK1452364-1					2014-12-04	1		
HB West of Entrance	STK1451818-1					2014-11-18	22.2		
HB West of Entrance	STK1451688-1					2014-11-17	34.4		
HB West of Entrance	STK1451688-2					2014-11-17	25.4		
HB West of Entrance	STK1451126-1					2014-10-31	<1.0		
HB West of Entrance	STK1451063-3					2014-10-30	6.4		
HB West of Entrance	STK1450166-1					2014-10-03	<1.0		
HB West of Entrance	STK1439558-2					2014-09-16	2		
HB West of Entrance	STK1438641-1					2014-08-26	Absent		
HB West of Entrance	STK1436371-3					2014-06-26	<1.0		
HB West of Entrance	STK1436371-4					2014-06-26	<1.0		
HB West of Entrance	STK1435459-2					2014-06-04	1		
HB West of Entrance	STK1435211-3					2014-05-30	1		
HB West of Entrance	STK1433792-1					2014-04-24	Absent		
HB West of Entrance	STK1431639-1					2014-02-25	Absent		
N.E. End HB	STK1453044-3					2014-12-29	2		
NW End Hose Bib	STK1453082-4					2014-12-30	<1.0		
NW End Hose Bib	STK1453043-3					2014-12-29	4.2		
NW End Hose Bib	STK1452940-2					2014-12-22	7.5		
NW End Hose Bib	STK1452775-2					2014-12-16	11.1		
NW End Hose Bib	STK1452364-2					2014-12-04	3.1		
NW End Hose Bib	STK1451818-2					2014-11-18	19.2		
NW End Hose Bib	STK1451688-3					2014-11-17	40.6		
NW End Hose Bib	STK1451126-2					2014-10-31	<1.0		
NW End Hose Bib	STK1451126-3					2014-10-31	<1.0		
NW End Hose Bib	STK1451063-1					2014-10-30	2		
NW End Hose Bib	STK1451063-2					2014-10-30	1		
NW End Hose Bib	STK1450166-2					2014-10-03	<1.0		
NW End Hose Bib	STK1439558-1					2014-09-16	3.1		
NW End Hose Bib	STK1439451-1					2014-09-15	Present		
NW End Hose Bib	STK1437515-1					2014-07-29	Absent		
NW End Hose Bib	STK1436371-5					2014-06-26	<1.0		
NW End Hose Bib	STK1435459-1					2014-06-04	2		
NW End Hose Bib	STK1435211-4					2014-05-30	12.4		
NW End Hose Bib	STK1435124-1					2014-05-29	Present		
NW End Hose Bib	STK1432417-1					2014-03-19	Absent		
NW End Hose Bib	STK1430699-1					2014-01-22	Absent		
P. Tank	STK1453082-2					2014-12-30	<1.0		
P. Tank	STK1453043-4					2014-12-29	1		
P. Tank	STK1452940-3					2014-12-22	<1.0		

P. Tank	STK1452775-3					2014-12-16	4.2		
P. Tank	STK1452364-3					2014-12-04	1		
P. Tank	STK1451818-3					2014-11-18	4.2		
P. Tank	STK1451688-4					2014-11-17	20.7		
P. Tank	STK1451126-4					2014-10-31	<1.0		
P. Tank	STK1436371-2					2014-06-26	<1.0		
Pressure Tank	STK1435211-2					2014-05-30	<1.0		
Well #1	STK1435459-4					2014-06-04	<1.0		
Well #1	STK1435211-1					2014-05-30	<1.0		
Well Head	STK1453082-1					2014-12-30	<1.0		
Well Head	STK1453043-5					2014-12-29	<1.0		
Well Head	STK1452940-4					2014-12-22	<1.0		
Well Head	STK1452775-4					2014-12-16	<1.0		
Well Head	STK1452364-4					2014-12-04	<1.0		
Well Head	STK1451818-4					2014-11-18	<1.0		
Well Head	STK1451688-5					2014-11-17	25.4		
Well Head	STK1451126-5					2014-10-31	<1.0		
Well Head	STK1451063-5					2014-10-30	2		
Well Head	STK1450166-4					2014-10-03	<1.0		
Well Head	STK1439558-4					2014-09-16	<1.0		
Well Head	STK1436371-1					2014-06-26	<1.0		

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		ppm		1.3	.3			0.33	5
E.W. ADA North Wall Sink	STK1339174-3	ppm				2013-09-13	0.34		
Front ADA Toilet Room	STK1339174-2	ppm				2013-09-13	ND		
Kitchen Dual Sink	STK1339174-1	ppm				2013-09-13	0.06		
Laundry Room Dual Sink	STK1339174-5	ppm				2013-09-13	0.07		
Room #25 Bath Sink	STK1339174-4	ppm				2013-09-13	0.32		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			18	18 - 18
Well #1	STK1337203-1	ppm				2013-07-17	18		
Hardness		ppm		none	none			175	175 - 175
Well #1	STK1337203-1	ppm				2013-07-17	175		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ppb		10	0.004			2	2 - 2
Well #1	STK1337203-1	ppb				2013-07-17	2		
Barium		ppm	2	1	2			0.11	0.11 - 0.11
Well #1	STK1337203-1	ppm				2013-07-17	0.11		
Fluoride		ppm		2	1			0.1	0.1 - 0.1
Well #1	STK1337203-1	ppm				2013-07-17	0.1		
Hexavalent Chromium		ppb		10	0.02			4.2	4.2 - 4.2
Well Head	STK1451062-1	ppb				2014-10-30	4.2		
Nitrate		ppm		45	45			16.7	16.7 - 16.7
Well Head	STK1439450-1	ppm				2014-09-15	16.7		
Nitrate + Nitrite as N		ppm		10	10			3.2	3.2 - 3.2
Well #1	STK1337203-1	ppm				2013-07-17	3.2		
Gross Alpha		pCi/L		15	(0)			2.91	2.91 - 2.91
Well #1	STK1337203-1	pCi/L				2013-07-17	2.91		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500	n/a			24	24 - 24
Well #1	STK1337203-1	ppm				2013-07-17	24		
Iron		ppb		300	n/a			150	150 - 150
Well #1	STK1337203-1	ppb				2013-07-17	150		
Manganese		ppb		50	n/a			20	20 - 20
Well #1	STK1337203-1	ppb				2013-07-17	20		
Odor Threshold at 60 °C		TON		3	n/a			1	1 - 1
Well #1	STK1337203-1	TON				2013-07-17	1		
Specific Conductance		umhos/cm		1600	n/a			430	430 - 430
Well #1	STK1337203-1	umhos/cm				2013-07-17	430		
Sulfate		ppm		500	n/a			10	10 - 10
Well #1	STK1337203-1	ppm				2013-07-17	10		
Total Dissolved Solids		ppm		1000	n/a			310	310 - 310
Well #1	STK1337203-1	ppm				2013-07-17	310		
Turbidity		NTU		5	n/a			1.8	1.8 - 1.8
Well #1	STK1337203-1	NTU				2013-07-17	1.8		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ppm		NS	n/a			0.02	0.02 - 0.02
Well #1	STK1337203-1	ppm				2013-07-17	0.02		

Brookside Meadows Estate

CCR Login Linkage - 2014

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
AFTER PT	STK1435459-3	2014-06-04	Coliform	After Pressure Tank	Water Monitoring
	STK1439558-3	2014-09-16	Coliform	After Pressure Tank	Water Monitoring
	STK1450166-3	2014-10-03	Coliform	After Pressure Tank	Water Monitoring
	STK1451063-4	2014-10-30	Coliform	After Pressure Tank	Water Monitoring
E.W. ADA North	STK1339174-3	2013-09-13	Metals, Total	E.W. ADA North Wall Sink	Copper & Lead Monitoring
Front ADA Toile	STK1339174-2	2013-09-13	Metals, Total	Front ADA Toilet Room	Copper & Lead Monitoring
HB Mid EWall	STK1453044-4	2014-12-29	Coliform	HB Middle East Wall	Brookside Meadows
HB Mid. W.Wall	STK1453044-1	2014-12-29	Coliform	HB Middle West Wall	Brookside Meadows
HB W.Courtyard	STK1453044-2	2014-12-29	Coliform	HB West Courtyard	Brookside Meadows
HB W of ENTRANC	STK1431639-1	2014-02-25	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1433792-1	2014-04-24	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1435211-3	2014-05-30	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1435459-2	2014-06-04	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1436371-3	2014-06-26	Coliform	HB West of Entrance	Bacteriological Sampling
	STK1436371-4	2014-06-26	Coliform	HB West of Entrance	Bacteriological Sampling
	STK1438641-1	2014-08-26	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1439558-2	2014-09-16	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1450166-1	2014-10-03	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1451063-3	2014-10-30	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1451126-1	2014-10-31	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1451688-1	2014-11-17	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1451688-2	2014-11-17	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1451818-1	2014-11-18	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1452364-1	2014-12-04	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1452775-1	2014-12-16	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1452940-1	2014-12-22	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1453043-1	2014-12-29	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1453043-2	2014-12-29	Coliform	HB West of Entrance	Water Monitoring - Routine #2
	STK1453082-3	2014-12-30	Coliform	HB West of Entrance	Water Monitoring - Routine #2
Kitchen Dual Si	STK1339174-1	2013-09-13	Metals, Total	Kitchen Dual Sink	Copper & Lead Monitoring
Laundry Room Du	STK1339174-5	2013-09-13	Metals, Total	Laundry Room Dual Sink	Copper & Lead Monitoring
N.E.EndHB	STK1453044-3	2014-12-29	Coliform	N.E. End HB	Brookside Meadows
NW END HB	STK1430699-1	2014-01-22	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1432417-1	2014-03-19	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1435124-1	2014-05-29	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1435211-4	2014-05-30	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1435459-1	2014-06-04	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1436371-5	2014-06-26	Coliform	NW End Hose Bib	Bacteriological Sampling
	STK1437515-1	2014-07-29	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1439451-1	2014-09-15	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1439558-1	2014-09-16	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1450166-2	2014-10-03	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1451063-1	2014-10-30	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1451063-2	2014-10-30	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1451126-2	2014-10-31	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1451126-3	2014-10-31	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1451688-3	2014-11-17	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1451818-2	2014-11-18	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1452364-2	2014-12-04	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1452775-2	2014-12-16	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1452940-2	2014-12-22	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1453043-3	2014-12-29	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
	STK1453082-4	2014-12-30	Coliform	NW End Hose Bib	Water Monitoring - Routine #1
P.Tank	STK1436371-2	2014-06-26	Coliform	P. Tank	Bacteriological Sampling

	STK1451126-4	2014-10-31	Coliform	P. Tank	Water Monitoring
	STK1451688-4	2014-11-17	Coliform	P. Tank	Water Monitoring
	STK1451818-3	2014-11-18	Coliform	P. Tank	Water Monitoring
	STK1452364-3	2014-12-04	Coliform	P. Tank	Water Monitoring
	STK1452775-3	2014-12-16	Coliform	P. Tank	Water Monitoring
	STK1452940-3	2014-12-22	Coliform	P. Tank	Water Monitoring
	STK1453043-4	2014-12-29	Coliform	P. Tank	Water Monitoring
	STK1453082-2	2014-12-30	Coliform	P. Tank	Water Monitoring
Pressure Tank	STK1435211-2	2014-05-30	Coliform	Pressure Tank	Water Monitoring
Room #25 Bath S	STK1339174-4	2013-09-13	Metals, Total	Room #25 Bath Sink	Copper & Lead Monitoring
WELL #1	STK1337203-1	2013-07-17	Radio Chemistry	Well #1	Water Quality Monitoring
	STK1337203-1	2013-07-17	General Mineral	Well #1	Water Quality Monitoring
	STK1337203-1	2013-07-17	Metals, Total	Well #1	Water Quality Monitoring
	STK1337203-1	2013-07-17	Wet Chemistry	Well #1	Water Quality Monitoring
	STK1435211-1	2014-05-30	Coliform	Well #1	Brookside Meadows Estate - Not in SWDB 7/15/13
	STK1435459-4	2014-06-04	Coliform	Well #1	Brookside Meadows Estate - Not in SWDB 7/15/13
	STK1436371-1	2014-06-26	Coliform	Well Head	Bacteriological Sampling
	STK1439450-1	2014-09-15	Wet Chemistry	Well Head	Water Quality Monitoring
	STK1439558-4	2014-09-16	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1450166-4	2014-10-03	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1451062-1	2014-10-30	Wet Chemistry	Well Head	Chrome 6 Monitoring
	STK1451063-5	2014-10-30	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1451126-5	2014-10-31	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1451688-5	2014-11-17	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1451818-4	2014-11-18	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1452364-4	2014-12-04	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1452775-4	2014-12-16	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1452940-4	2014-12-22	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1453043-5	2014-12-29	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE
	STK1453082-1	2014-12-30	Coliform	Well Head	BROOKSIDE MEADOWS ESTATE