


# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name: **RED BLUFF FISH & WILDLIFE OFFICE**  
Water System Number: **5205009**

The water system above hereby certifies that its Consumer Confidence Report was distributed on July 28, 2015 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name James G. Smith  
Signature   
Title Project Leader, Red Bluff Fish and Wildlife Office  
Phone Number (530) 527-3042 ext 222 Date 7-28-2015

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:  
Email to all station employees on 7/28/2015

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at http:// \_\_\_\_\_
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations) one report in each of 4 on-station buildings with water taps
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// \_\_\_\_\_

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2014 Consumer Confidence Report

Water System Name: RED BLUFF FISH & WILDLIFE OFFICE

Report Date: July 2015

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** Information regarding the type of water source in use is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

**Your water comes from 1 source(s):** Well 03

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held. Meetings are held on an as needed basis and are announced by word of mouth.

For more information about this report, or any questions relating to your drinking water, please call (530) 527 - 3043 and ask for Rob Emge or visit our website at [www.fws.gov/red bluff](http://www.fws.gov/red bluff).

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

| <b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>         |                    |                                       |                               |           |            |   |
|--|--------------------|---------------------------------------|-------------------------------|-----------|------------|---|
| <b>Lead and Copper</b><br>(complete if lead or copper detected in last sample set) | <b>Sample Date</b> | <b>90th percentile level detected</b> | <b>No. Sites Exceeding AL</b> | <b>AL</b> | <b>PHG</b> | <b>Typical Sources of Contaminant</b>   |
| Copper (ppm)   | 5<br>(2014)        | 0.04                                  | 0                             | 1.3       | .3         | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

| <b>Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b> |                    |                       |                            |            |                   |  |
|---|--------------------|-----------------------|----------------------------|------------|-------------------|--|
| <b>Chemical or Constituent</b><br>(and reporting units)   | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL</b> | <b>PHG (MCLG)</b> | <b>Typical Sources of Contaminant</b>  |
| Sodium (ppm)  | (2007)             | 18                    | N/A                        | none       | none              | Salt present in the water and is generally naturally occurring   |
| Hardness (ppm)  | (2007)             | 142                   | N/A                        | none       | none              | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

| <b>Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b> |                    |                       |                            |                   |                           |   |
|---|--------------------|-----------------------|----------------------------|-------------------|---------------------------|---|
| <b>Chemical or Constituent</b><br>(and reporting units)                           | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL [MRDL]</b> | <b>PHG (MCLG) [MRDLG]</b> | <b>Typical Sources of Contaminant</b>   |
| Aluminum (ppm)  | (2012)             | 0.06                  | N/A                        | 1                 | 0.6                       | Erosion of natural deposits; residue from some surface water treatment processes                            |
| Nitrate (ppm)   | (2014)             | 10.4                  | N/A                        | 45                | 45                        | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits |
| Gross Alpha (pCi/L)   | (2012)             | ND                    | ND - 1.91                  | 15                | (0)                       | Erosion of natural deposits.  |

| <b>Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD</b> |                    |                       |                            |            |                   |   |
|---|--------------------|-----------------------|----------------------------|------------|-------------------|---|
| <b>Chemical or Constituent</b><br>(and reporting units)                             | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL</b> | <b>PHG (MCLG)</b> | <b>Typical Sources of Contaminant</b>                       |
| Chloride (ppm)  | (2007)             | 35                    | N/A                        | 500        | n/a               | Runoff/leaching from natural deposits; seawater influence   |
| Iron (ppb)  | (2007)             | 160                   | N/A                        | 300        | n/a               | Leaching from natural deposits; Industrial wastes           |
| Specific Conductance (umhos/cm)   | (2007)             | 377                   | N/A                        | 1600       | n/a               | Substances that form ions when in water; seawater influence |
| Sulfate (ppm)   | (2007)             | 12                    | N/A                        | 500        | n/a               | Runoff/leaching from natural deposits; industrial wastes    |
| Total Dissolved Solids (ppm)  | (2007)             | 250                   | N/A                        | 1000       | n/a               | Runoff/leaching from natural deposits                       |

| <b>Table 5 - DETECTION OF UNREGULATED CONTAMINANTS</b>  |                    |                       |                            |                           |   |
|---|--------------------|-----------------------|----------------------------|---------------------------|---|
| <b>Chemical or Constituent</b><br>(and reporting units) | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>Notification Level</b> | <b>Typical Sources of Contaminant</b>   |
| Boron (ppm)   | (2007)             | 0.3                   | N/A                        | 1                         | The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals. |
| Vanadium (ppm)  | (2012)             | 0.01                  | N/A                        | 0.05                      | The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.    |

| <b>Table 6 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE</b> |                    |                       |                            |                   |                   |   |
|--|--------------------|-----------------------|----------------------------|-------------------|-------------------|---|
| <b>Chemical or Constituent</b><br>(and reporting units)                        | <b>Sample Date</b> | <b>Level Detected</b> | <b>Range of Detections</b> | <b>MCL (MRDL)</b> | <b>PHG (MCLG)</b> | <b>Typical Sources of Contaminant</b>     |
| Total Trihalomethanes (TTHMs) (ppb)  | (2014)             | 8.6                   | N/A                        | 80                | n/a               | By-product of drinking water disinfection |
| Haloacetic Acids (five) (ppb)  | (2014)             | 3                     | N/A                        | 60                | n/a               | By-product of drinking water disinfection |

## **Additional General Information on Drinking Water**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *U.S. Fish & Wildlife Service* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for

30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## **2014 Consumer Confidence Report**

### **Drinking Water Assessment Information**

#### **Assessment Information**

According to the Drinking Water Source Assessment and Protection Program's Source Water Assessments Public Access web page, the Public Water Sources WELL 03 of the RED BLUFF FISH & WILDLIFE OFFICE water system does not have a completed Source Water Assessment on file.

Well 03 - does not have a completed Source Water Assessment on file.

#### **Discussion of Vulnerability**

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

#### **Acquiring Information**

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

# U.S. Fish & Wildlife Service

## Analytical Results By FGL - 2014

### LEAD AND COPPER RULE

|                            |              | Units | MCLG | CA-MCL | PHG | Sampled    | Result | 90th Percentile | # Samples |
|----------------------------|--------------|-------|------|--------|-----|------------|--------|-----------------|-----------|
| <b>Copper</b>              |              | ppm   |      | 1.3    | .3  |            |        | 0.04            | 5         |
| CuPb1- Shop                | CH 1476174-1 | ppm   |      |        |     | 2014-08-13 | ND     |                 |           |
| CuPb2- Administration      | CH 1476174-2 | ppm   |      |        |     | 2014-08-13 | ND     |                 |           |
| CuPb3- Annex               | CH 1476174-3 | ppm   |      |        |     | 2014-08-13 | ND     |                 |           |
| CuPb4- Conference Restroom | CH 1476174-4 | ppm   |      |        |     | 2014-08-13 | ND     |                 |           |
| CuPb5- Bungalow            | CH 1476174-5 | ppm   |      |        |     | 2014-08-13 | 0.08   |                 |           |

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

|                 |              | Units | MCLG | CA-MCL | PHG  | Sampled    | Result | Avg. Result(a) | Range (b) |
|-----------------|--------------|-------|------|--------|------|------------|--------|----------------|-----------|
| <b>Sodium</b>   |              | ppm   |      | none   | none |            |        | 18             | 18 - 18   |
| Well 03         | CH 0775116-1 | ppm   |      |        |      | 2007-09-04 | 18     |                |           |
| <b>Hardness</b> |              | ppm   |      | none   | none |            |        | 142            | 142 - 142 |
| Well 03         | CH 0775116-1 | ppm   |      |        |      | 2007-09-04 | 142    |                |           |

### PRIMARY DRINKING WATER STANDARDS (PDWS)

|                    |              | Units | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b)   |
|--------------------|--------------|-------|------|--------|-----|------------|--------|----------------|-------------|
| <b>Aluminum</b>    |              | ppm   |      | 1      | 0.6 |            |        | 0.06           | 0.06 - 0.06 |
| Well 03            | CH 1270825-1 | ppm   |      |        |     | 2012-02-08 | 0.06   |                |             |
| <b>Nitrate</b>     |              | ppm   |      | 45     | 45  |            |        | 10.4           | 10.4 - 10.4 |
| Well 03            | CH 1474483-1 | ppm   |      |        |     | 2014-08-04 | 10.4   |                |             |
| <b>Gross Alpha</b> |              | pCi/L |      | 15     | (0) |            |        | ND             | ND - 1.91   |
| Well 03            | CH 1276587-1 | pCi/L |      |        |     | 2012-11-09 | ND     |                |             |
| Well 03            | CH 1275264-1 | pCi/L |      |        |     | 2012-08-17 | ND     |                |             |
| Well 03            | CH 1272578-1 | pCi/L |      |        |     | 2012-05-23 | 1.91   |                |             |
| Well 03            | CH 1270825-1 | pCi/L |      |        |     | 2012-02-08 | ND     |                |             |

### SECONDARY DRINKING WATER STANDARDS (SDWS)

|                               |              | Units    | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b) |
|-------------------------------|--------------|----------|------|--------|-----|------------|--------|----------------|-----------|
| <b>Chloride</b>               |              | ppm      |      | 500    | n/a |            |        | 35             | 35 - 35   |
| Well 03                       | CH 0775116-1 | ppm      |      |        |     | 2007-09-04 | 35     |                |           |
| <b>Iron</b>                   |              | ppb      |      | 300    | n/a |            |        | 160            | 160 - 160 |
| Well 03                       | CH 0775116-1 | ppb      |      |        |     | 2007-09-04 | 160    |                |           |
| <b>Specific Conductance</b>   |              | umhos/cm |      | 1600   | n/a |            |        | 377            | 377 - 377 |
| Well 03                       | CH 0775116-1 | umhos/cm |      |        |     | 2007-09-04 | 377    |                |           |
| <b>Sulfate</b>                |              | ppm      |      | 500    | n/a |            |        | 12             | 12 - 12   |
| Well 03                       | CH 0775116-1 | ppm      |      |        |     | 2007-09-04 | 12     |                |           |
| <b>Total Dissolved Solids</b> |              | ppm      |      | 1000   | n/a |            |        | 250            | 250 - 250 |
| Well 03                       | CH 0775116-1 | ppm      |      |        |     | 2007-09-04 | 250    |                |           |

### UNREGULATED CONTAMINANTS

|                 |              | Units | MCLG | CA-MCL | PHG | Sampled    | Result | Avg. Result(a) | Range (b)   |
|-----------------|--------------|-------|------|--------|-----|------------|--------|----------------|-------------|
| <b>Boron</b>    |              | ppm   |      | NS     | n/a |            |        | 0.3            | 0.3 - 0.3   |
| Well 03         | CH 0775116-1 | ppm   |      |        |     | 2007-09-04 | 0.3    |                |             |
| <b>Vanadium</b> |              | ppm   |      | NS     | n/a |            |        | 0.01           | 0.01 - 0.01 |
| Well 03         | CH 1270825-1 | ppm   |      |        |     | 2012-02-08 | 0.01   |                |             |

### DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE

|  |  | Units | MCLG | CA-MCL | PHG | Sampled | Result | Avg. Result(a) | Range (b) |
|--|--|-------|------|--------|-----|---------|--------|----------------|-----------|
|--|--|-------|------|--------|-----|---------|--------|----------------|-----------|

|                                      |              |     |  |    |     |            |     |     |           |
|--------------------------------------|--------------|-----|--|----|-----|------------|-----|-----|-----------|
| <b>Total Trihalomethanes (TTHMs)</b> |              | ppb |  | 80 | n/a |            |     | 8.6 | 8.6 - 8.6 |
| Shop                                 | CH 1474481-1 | ppb |  |    |     | 2014-08-04 | 8.6 |     |           |
| <b>Haloacetic Acids (five)</b>       |              | ppb |  | 60 | n/a |            |     | 3   | 3 - 3     |
| Shop                                 | CH 1474481-1 | ppb |  |    |     | 2014-08-04 | 3   |     |           |

# U.S. Fish & Wildlife Service

## CCR Login Linkage - 2014

| FGL Code       | Lab ID       | Date_Sampled | Method          | Description                    | Property                         |
|----------------|--------------|--------------|-----------------|--------------------------------|----------------------------------|
| SHOP           | CH 1476174-1 | 2014-08-13   | Metals, Total   | CuPb1- Shop                    | Copper & Lead Monitoring         |
| ADMINISTRATION | CH 1476174-2 | 2014-08-13   | Metals, Total   | CuPb2- Administration          | Copper & Lead Monitoring         |
| ANNEX          | CH 1476174-3 | 2014-08-13   | Metals, Total   | CuPb3- Annex                   | Copper & Lead Monitoring         |
| CONF RR        | CH 1476174-4 | 2014-08-13   | Metals, Total   | CuPb4- Conference Restroom     | Copper & Lead Monitoring         |
| BNGLOW         | CH 1476174-5 | 2014-08-13   | Metals, Total   | CuPb5- Bungalow                | Copper & Lead Monitoring         |
| HB N. CONF BLD | CH 1470149-1 | 2014-02-03   | Coliform        | HB-N Side Conference Rm. Bldg. | DW Bacti Monitoring-2            |
|                | CH 1472703-1 | 2014-05-05   | Coliform        | HB-N Side Conference Rm. Bldg. | DW Bacti Monitoring-2            |
|                | CH 1474480-1 | 2014-08-04   | Coliform        | HB-N Side Conference Rm. Bldg. | DW Bacti Monitoring-2            |
|                | CH 1477286-1 | 2014-11-04   | Coliform        | HB-N Side Conference Rm. Bldg. | DW Bacti Monitoring-2            |
| NE HB GARAGE   | CH 1470687-1 | 2014-03-03   | Coliform        | HB-N/E Corner Garage Bldg.     | DW Bacti Monitoring-3            |
|                | CH 1472449-1 | 2014-06-02   | Coliform        | HB-N/E Corner Garage Bldg.     | DW Bacti Monitoring-3            |
|                | CH 1475501-1 | 2014-09-02   | Coliform        | HB-N/E Corner Garage Bldg.     | DW Bacti Monitoring-3            |
|                | CH 1478098-1 | 2014-12-01   | Coliform        | HB-N/E Corner Garage Bldg.     | DW Bacti Monitoring-3            |
| SE HB MAIN OFF | CH 1470099-1 | 2014-01-13   | Coliform        | HB-S/E Corner Main Office      | DW Bacti Monitoring-1            |
|                | CH 1471404-1 | 2014-04-02   | Coliform        | HB-S/E Corner Main Office      | DW Bacti Monitoring-1            |
|                | CH 1473081-1 | 2014-07-02   | Coliform        | HB-S/E Corner Main Office      | DW Bacti Monitoring-1            |
|                | CH 1476442-1 | 2014-10-01   | Coliform        | HB-S/E Corner Main Office      | DW Bacti Monitoring-1            |
| Shop           | CH 1474481-1 | 2014-08-04   | EPA 552.2       | Shop                           | DBP Monitoring                   |
|                | CH 1474481-1 | 2014-08-04   | EPA 551.1       | Shop                           | DBP Monitoring                   |
| Well 03        | CH 0775116-1 | 2007-09-04   | General Mineral | Well 03                        | Drinking Water Monitoring        |
| WELL 03        | CH 1270825-1 | 2012-02-08   | Radio Chemistry | Well 03                        | RED BLUFF FISH & WILDLIFE OFFICE |
|                | CH 1270825-1 | 2012-02-08   | Metals, Total   | Well 03                        | RED BLUFF FISH & WILDLIFE OFFICE |
|                | CH 1272578-1 | 2012-05-23   | Radio Chemistry | Well 03                        | Water Quality - IOCs/Radio       |
|                | CH 1275264-1 | 2012-08-17   | Radio Chemistry | Well 03                        | Water Quality - IOCs/Radio       |
|                | CH 1276587-1 | 2012-11-09   | Radio Chemistry | Well 03                        | Water Quality - IOCs/Radio       |
|                | CH 1470150-1 | 2014-02-03   | Coliform        | Well 03                        | Source Bacti Monitoring          |
|                | CH 1472704-1 | 2014-05-05   | Coliform        | Well 03                        | Source Bacti Monitoring          |
|                | CH 1474483-1 | 2014-08-04   | Wet Chemistry   | Well 03                        | DW Quality Monitoring            |
|                | CH 1474482-1 | 2014-08-04   | Coliform        | Well 03                        | Source Bacti Monitoring          |
|                | CH 1477287-1 | 2014-11-04   | Coliform        | Well 03                        | Source Bacti Monitoring          |