

RECEIVED

JUL - 6 2015

2014 Annual Drinking Water Quality Report

STRATHMORE PUBLIC UTILITY DISTRICT

SWRCB - DDW
FRESNO, CA

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2014.

**Este informe contiene información muy importante sobre su agua de beber.
Tradúzcalo ó hable con alguien que lo entienda bien.**

We are pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is and always has been, to provide you with a safe and dependable supply of drinking water. Our water source comes from surface water via the Friant Kern Canal and one groundwater well, Well No. 2. The period of time that the system relies entirely on groundwater, during maintenance of the canal, is short. Treatment is by conventional filtration using dual media gravity filters followed by chlorination. Groundwater that exceeds the nitrate MCL is mixed with the surface water prior to treatment, with the blended supply having a nitrate level well below the allowed maximum.

A source water assessment was conducted for the District's water supply well and surface water source in March 2003. The water sources are considered most vulnerable to the following activities associated with contaminants detected in the water supply: fertilizer, pesticide and/or herbicide application. The water sources are considered most vulnerable to the following activities not associated with any detected contaminants: automobile – gas stations; septic systems – high density; and wastewater treatment plants and disposal facilities. A copy of the complete assessment may be viewed at: Strathmore Public Utility District, 19626 Orange Belt Drive, Strathmore, CA 93267. You may request a summary of the assessment be sent to you by contacting the District, at 559/568-1613 or 559/568-0240 (fax).

If you have any questions about this report or concerning your water utility, please contact the District at 559/568-1613. We want our customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings held on the second Thursday of each month at 5:30 p.m. at the District offices, 19631 Wallace Road, Strathmore, CA 93267.

The following are definitions of some of the TERMS USED IN THIS REPORT:

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Primary Drinking Water Standards (PDWS): MCLs or MRDLs for contaminants that affect health, along with their monitoring and reporting requirements, and water treatment requirements

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor or appearance of drinking water. Supplies with elevated SDWS do not affect the health at the MCL levels.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Variations and Exemptions: State Water Resources Control Board – Division of Drinking Water (DDW) permission to exceed an MCL or not comply with a treatment technique under certain conditions.

NA: not applicable.

ND: not detectable at testing limit.

ppm: parts per million or milligrams per liter (mg/l).

ppb: parts per billion or micrograms per liter (ug/l).

ppt: parts per trillion or nanograms per liter (ng/l).

pCi/l: picocuries per liter (a measure of radiation).

In general, sources of drinking water (both tap water and bottled water) may include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Constituents that may be present in source water to contamination levels include:

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides* may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.
- *Radioactive contaminants* that can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U. S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board – Division of Drinking Water (DDW) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. DDW regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Strathmore Public Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The tables below and on the following pages list all the drinking water constituents that were detected during the most recent samplings for the constituent. The presence of these constituents in the water does not necessarily indicate that the water poses a health risk. The DDW requires us to monitor for certain constituents less than once per year because the concentrations of these constituents are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are therefore more than one year old.

SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES				
Treatment Technique	Turbidity Performance Standards (TPS)	Lowest monthly percentage of samples that met TPS	Number of Months in Violation	Highest single turbidity measurement during the year
Conventional Filtration Treatment with Chlorination	Turbidity of the filtered water must: Be less than or equal to 0.3 NTU in 95% of measurements in a month.	98%	0	0.31

Turbidity (measured in NTU) is a measurement of the cloudiness of water and is an indicator of filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

TEST RESULTS (A)

Lead and Copper Rule	No. of samples collected	MCLG	Action Level	90 th percentile level detected	No. Sites Exceeding Action Level	Typical Source of Contamination
Lead (ppb) 2012	10	2	15	ND	0	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) 2012	10	0.3	1.3	0.01	0	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

RADIOACTIVE CONTAMINANTS (B)

Chemical or Constituent (and reporting units)	MCL	PHG (MCLG)	Sample Date	Weighted Average Level Detected (C)	Range (B)	Likely Source of Contamination
Gross Alpha Activity (pCi/L)	15	N/A	2011 & 2014	< 3	N/A	Erosion of natural deposits
Radium 228 (pCi/L)			2005 & 2006	0.76	0.52 to < 1	Erosion of natural deposits

SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	MCL	PHG [MCLG]	Sample Date	Weighted Average Level Detected (C)	Range	Likely Source of Contamination
Hardness (ppm)	None	None	2013 & 2014	76	20 to 180	Generally found in ground and surface water
Sodium (ppm)	None	None	2013 & 2014	23.7	3.6 to 61	Generally found in ground and surface water

Disinfection Byproduct Precursors

Control of DBP precursors (TOC)	MCL	MCLG	Range	Major Sources in Drinking Water
Source Water	TT	N/A	1.1 to 1.8	Various natural and manmade sources
Treated Water	TT	N/A	0.89 to 1.3	Various natural and manmade sources

VIOLATION OF A SURFACE WATER CT				
CT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
The District failed to maintain a daily CT ratio of 1.0 or greater for two (2) days in November 2014. (F)	The District is required to provide a daily CT ratio of at least 1.0 to determine compliance.	2 Days	The District increased the chlorine residual and is monitoring more closely.	<i>Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.</i>

- (A) Results reported due to regulatory requirement or detection of a constituent.
- (B) Results reported include amounts that are less than the State Department of Public Health required detection level for this constituent.
- (C) The weighted average reflects the quantity of water provided from each source of supply, be it groundwater (wells) and/or surface water along with the representative concentration for a particular constituent.
- (D) ABOUT NITRATE: Nitrate in drinking water at levels above 45 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. The range shown is for the delivered water supply after the blending of Friant-Kern Canal water with Well No. 2.
- (E) ABOUT SECONDARY DRINKING WATER STANDARDS: No constituents were found at levels exceeding the Secondary MCLs. These MCLs are set to protect you against unpleasant aesthetic effects such as odor or appearance of your drinking water. The elevated levels are typically due to naturally occurring organic materials.
- (F) **CT is the concentration of chlorine in your water times the time the water is in contact with that chlorine (CT = Concentration x Time).**

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of constituents does not necessarily indicate that the water poses a health risk. More information about constituents, contaminant levels and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1/800/426-4791 or their website <http://www.epa.gov/safewater/hfacts.html>.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders and some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1/800/426-4791.