Consumer Confidence Report
Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **Rio Plaza Water Co Inc**
Water System Number: **5610010**

The water system above hereby certifies that its Consumer Confidence Report was distributed on June 26, 2015 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:

Name: Frank Brommenschenkel

Signature: /S/

Title: Office Manager

Phone Number: (805-525-4200 Date: June 26, 2015

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

X CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

_____

_____

_____ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- _____ Posted the CCR on the internet at http:// _____
- _____ Mailed the CCR to postal patrons within the service area (attach zip codes used)
- _____ Advertised the availability of the CCR in news media (attach a copy of press release)
- _____ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- _____ Posted the CCR in public places (attach a list of locations)
- _____ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- _____ Delivery to community organizations (attach a list of organizations)
- _____ Other (attach a list of other methods used)

_____ *For systems serving at least 100,000 persons:* Posted CCR on a publicly-accessible internet site at the following address: http://_____

_____ *For privately-owned utilities:* Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2014 Consumer Confidence Report

Water System Name: Rio Plaza Water Co Inc Report Date: June 2015

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alquien que lo entienda bien.

Type of water source(s) in use: According to CDPH records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): Well 02 and Well 03 (1B)

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805)525-4200 and ask for Frank Brommenschenkel.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system mush follow.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants,* such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants,* such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides,* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants,* including synthetic and volatile organic chemicals, that are by-products if industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants,* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	**Sample Date**	**90th percentile level detected**	**No. Sites Exceeding AL**	**AL**	**PHG**	**Typical Sources of Contaminant**
Lead (ppb)	10 (2013)	2.1	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	10 (2013)	0.23	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Sources of Contaminant**
Sodium (ppm)	(2010 - 2013)	93	88 - 97	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2010 - 2013)	548	528 - 568	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL [MRDL]**	**PHG (MCLG) [MRDLG]**	**Typical Sources of Contaminant**
Fluoride (ppm)	(2010 - 2013)	0.7	N/A	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate (ppm)	(2014)	7.7	6.1 - 9.2	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2010 - 2013)	3.2	1.7 - 4.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ppb)	(2010 - 2013)	6	5 - 7	50	30	Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots(feed additive)
Gross Alpha (pCi/L)	(2013 - 2014)	3.99	2.44 - 5.54	15	(0)	Erosion of natural deposits.
Uranium (pCi/L)	(2008 - 2013)	3.27	2.85 - 3.68	20	0.43	Erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Sources of Contaminant**
Chloride (ppm)	(2010 - 2013)	61	51 - 71	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2010 - 2013)	3	ND - 5	15	n/a	Naturally-occurring organic materials
Iron (ppb)	(2013)	140	ND - 280	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2010 - 2013)	1345	1330 - 1360	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2010 - 2013)	505	460 - 550	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2010 - 2013)	985	970 - 1000	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2010 - 2013)	0.8	0.2 - 1.4	5	n/a	Soil runoff

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**Notification Level**	**Typical Sources of Contaminant**
Boron (ppm)	(2010 - 2013)	0.7	0.6 - 0.7	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

Table 6 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL (MRDL)**	**PHG (MCLG)**	**Typical Sources of Contaminant**
Total Trihalomethanes (TTHMs) (ppb)	(2014)	14.5	N/A	80	n/a	By-product of drinking water disinfection
Haloacetic Acids (five) (ppb)	(2014)	2	N/A	60	n/a	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-

compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Rio Plaza Water Co.* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Sulfate: Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

2014 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information
A source water assessment was conducted for the WELL 02 and the WELL 03 of the RIO PLAZA WATER CO INC water system in August, 2001.

Well 02	- is considered most vulnerable to the following activities not associated with any detected contaminants: Abandoned Septic systems - high density [>1/acre]
Well 03 (1B)	- is considered most vulnerable to the following activities not associated with any detected contaminants: Abandoned Septic systems - high density [>1/acre]

Acquiring Information
A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water
1180 Eugenia Place
Suite 200
Carpinteria, CA 93013

You may request a summary of the assessment be sent to you by contacting:
Jeff Densmore
District Engineer
805 566 1326

Rio Plaza Water Co.

Analytical Results By FGL - 2014

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ppb	0	15	0.2			2.1	3
1017 Lemar	SP 1306817-6	ppb				2013-07-06	ND		
1025 Will Ave.	SP 1306817-4	ppb				2013-07-06	ND		
1035 Salem Ave.	SP 1306817-8	ppb				2013-07-06	ND		
3321 Citrus	SP 1306817-7	ppb				2013-07-06	ND		
344 Helsam Ave.	SP 1306817-2	ppb				2013-07-06	ND		
3486 Cortez	SP 1306817-9	ppb				2013-07-06	7.4		
401 Will Ave.	SP 1306817-5	ppb				2013-07-06	ND		
808 Simon Way	SP 1306817-10	ppb				2013-07-06	ND		
971 Helsam	SP 1306817-11	ppb				2013-07-06	ND		
994 Helsam	SP 1306817-1	ppb				2013-07-06	ND		
Copper		ppm		1.3	.3			0.233	10
1017 Lemar	SP 1306817-6	ppm				2013-07-06	0.233		
1025 Will Ave.	SP 1306817-4	ppm				2013-07-06	ND		
1035 Salem Ave.	SP 1306817-8	ppm				2013-07-06	0.08		
3321 Citrus	SP 1306817-7	ppm				2013-07-06	ND		
344 Helsam Ave.	SP 1306817-2	ppm				2013-07-06	0.075		
3486 Cortez	SP 1306817-9	ppm				2013-07-06	0.364		
401 Will Ave.	SP 1306817-5	ppm				2013-07-06	0.134		
808 Simon Way	SP 1306817-10	ppm				2013-07-06	0.195		
971 Helsam	SP 1306817-11	ppm				2013-07-06	ND		
994 Helsam	SP 1306817-1	ppm				2013-07-06	0.05		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			93	88 - 97
Well 02	SP 1308458-1	ppm				2013-08-16	88		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	97		
Hardness		ppm		none	none			548	528 - 568
Well 02	SP 1308458-1	ppm				2013-08-16	528		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	568		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		ppm		2	1			0.7	0.7 - 0.7
Well 02	SP 1308458-1	ppm				2013-08-16	0.7		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	0.7		
Nitrate		ppm		45	45			7.7	6.1 - 9.2
Well 02	SP 1409260-1	ppm				2014-08-15	9.2		
Well 03 (1B)	SP 1409256-1	ppm				2014-08-15	6.1		
Nitrate + Nitrite as N		ppm		10	10			3.2	1.7 - 4.7
Well 02	SP 1308458-1	ppm				2013-08-16	1.7		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	4.7		
Selenium		ppb	50	50	30			6	5 - 7
Well 02	SP 1308458-1	ppb				2013-08-16	5		
Well 03 (1B)	SP 1009095-1	ppb				2010-09-03	7		
Gross Alpha		pCi/L		15	(0)			3.99	2.44 - 5.54
Well 02	SP 1409255-1	pCi/L				2014-08-15	2.44		
Well 03 (1B)	SP 1308835-1	pCi/L				2013-08-26	5.54		
Uranium		pCi/L		20	0.43			3.27	2.85 - 3.68
Well 02	SP 0809167-3	pCi/L				2008-08-22	3.68		

Well 03 (1B)	SP 1308835-1	pCi/L				2013-08-26	2.85		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Chloride		ppm		500	n/a			61	51 - 71
Well 02	SP 1308458-1	ppm				2013-08-16	71		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	51		
Color		Units		15	n/a			3	ND - 5
Well 02	SP 1308838-1	Units				2013-08-26	ND		
Well 03 (1B)	SP 1009095-1	Units				2010-09-03	5		
Iron		ppb		300	n/a			140	ND - 280
Well 02	SP 1308458-1	ppb				2013-08-16	280		
Well 03 (1B)	SP 1308449-1	ppb				2013-08-16	ND		
Specific Conductance		umhos/cm		1600	n/a			1345	1330 - 1360
Well 02	SP 1308458-1	umhos/cm				2013-08-16	1330		
Well 03 (1B)	SP 1009095-1	umhos/cm				2010-09-03	1360		
Sulfate		ppm		500	n/a			505	460 - 550
Well 02	SP 1308458-1	ppm				2013-08-16	550		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	460		
Total Dissolved Solids		ppm		1000	n/a			985	970 - 1000
Well 02	SP 1308458-1	ppm				2013-08-16	970		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	1000		
Turbidity		NTU		5	n/a			0.8	0.2 - 1.4
Well 02	SP 1308838-1	NTU				2013-08-26	1.4		
Well 03 (1B)	SP 1009095-1	NTU				2010-09-03	0.2		

UNREGULATED CONTAMINANTS									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Boron		ppm		NS	n/a			0.7	0.6 - 0.7
Well 02	SP 1308458-1	ppm				2013-08-16	0.6		
Well 03 (1B)	SP 1009095-1	ppm				2010-09-03	0.7		

DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	**MCLG**	**CA-MCL**	**PHG**	**Sampled**	**Result**	**Avg. Result(a)**	**Range (b)**
Total Trihalomethanes (TTHMs)		ppb		80	n/a			14.5	14.5 - 14.5
STG 2 - 3460 GEORGE ST.	SP 1409259-1	ppb				2014-08-15	14.5		
Haloacetic Acids (five)		ppb		60	n/a			2	2 - 2
STG 2 - 3460 GEORGE ST.	SP 1409259-1	ppb				2014-08-15	2		

Rio Plaza Water Co.
CCR Login Linkage - 2014

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
1017 Lemar	SP 1306817-6	2013-07-06	Metals, Total	1017 Lemar	Lead & Copper Monitoring System # 5610010
1025 Will Avenu	SP 1306817-4	2013-07-06	Metals, Total	1025 Will Ave.	Lead & Copper Monitoring System # 5610010
1035 Salem Ave	SP 1306817-8	2013-07-06	Metals, Total	1035 Salem Ave.	Lead & Copper Monitoring System # 5610010
3321 Citrus	SP 1306817-7	2013-07-06	Metals, Total	3321 Citrus	Lead & Copper Monitoring System # 5610010
344 Helsam Aven	SP 1306817-2	2013-07-06	Metals, Total	344 Helsam Ave.	Lead & Copper Monitoring System # 5610010
3460 George	SP 1400187-1	2014-01-08	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1401642-1	2014-02-12	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1402834-1	2014-03-12	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1404010-1	2014-04-09	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1406686-1	2014-06-11	Coliform	3460 George St.	Bacteriological Monitoring-George St.
	SP 1408191-1	2014-07-18	Coliform	3460 George St.	Bacteriological Monitoring-George St.
	SP 1409261-1	2014-08-15	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1410628-1	2014-09-16	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1411654-1	2014-10-08	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1413157-1	2014-11-12	Coliform	3460 George St.	Bacteriological Monitoring
	SP 1414370-1	2014-12-10	Coliform	3460 George St.	Bacteriological Monitoring
3475 Menna	SP 1400187-2	2014-01-08	Coliform	3475 Menna Dr.	Bacteriological Monitoring
3475 Minna	SP 1401642-2	2014-02-12	Coliform	3475 Menna Dr.	Bacteriological Monitoring
	SP 1402834-2	2014-03-12	Coliform	3475 Menna Dr.	Bacteriological Monitoring
3475 Menna	SP 1404010-2	2014-04-09	Coliform	3475 Menna Dr.	Bacteriological Monitoring
	SP 1405471-2	2014-05-14	Coliform	3475 Menna Dr.	George St. - Bacteriological Monitoring
	SP 1406686-2	2014-06-11	Coliform	3475 Menna Dr.	Bacteriological Monitoring-George St.
3475 Minna	SP 1408191-2	2014-07-18	Coliform	3475 Menna Dr.	Bacteriological Monitoring-George St.
	SP 1409261-2	2014-08-15	Coliform	3475 Menna Dr.	Bacteriological Monitoring
	SP 1410628-2	2014-09-16	Coliform	3475 Menna Dr.	Bacteriological Monitoring
	SP 1411654-2	2014-10-08	Coliform	3475 Menna Dr.	Bacteriological Monitoring
	SP 1413157-2	2014-11-12	Coliform	3475 Menna Dr.	Bacteriological Monitoring
	SP 1414370-2	2014-12-10	Coliform	3475 Menna Dr.	Bacteriological Monitoring
3486 Cortez	SP 1306817-9	2013-07-06	Metals, Total	3486 Cortez	Lead & Copper Monitoring System # 5610010
401 Will Avenue	SP 1306817-5	2013-07-06	Metals, Total	401 Will Ave.	Lead & Copper Monitoring System # 5610010
808 Simon Way	SP 1306817-10	2013-07-06	Metals, Total	808 Simon Way	Lead & Copper Monitoring System # 5610010
971 Helsam	SP 1306817-11	2013-07-06	Metals, Total	971 Helsam	Lead & Copper Monitoring System # 5610010
994 Helsam	SP 1306817-1	2013-07-06	Metals, Total	994 Helsam	Lead & Copper Monitoring System # 5610010
3460 George	SP 1405471-1	2014-05-13	Coliform	STG 2 - 3460 GEORGE ST.	George St. - Bacteriological Monitoring
DBP2 GEORGE	SP 1409259-1	2014-08-15	EPA 552.2	STG 2 - 3460 GEORGE ST.	Stage 2 DBP Monitoring
	SP 1409259-1	2014-08-15	EPA 551.1	STG 2 - 3460 GEORGE ST.	Stage 2 DBP Monitoring
STW-2	SP 0809167-3	2008-08-22	Radio Chemistry	Well 02	Drinking Water Monitoring
	SP 1308458-1	2013-08-16	General Mineral	Well 02	Well 2 - Water Quality
	SP 1308458-1	2013-08-16	Metals, Total	Well 02	Well 2 - Water Quality
	SP 1308838-1	2013-08-26	Wet Chemistry	Well 02	Well 2 - Water Quality
	SP 1409255-1	2014-08-15	Radio Chemistry	Well 02	Well 2 - Radio
	SP 1409260-1	2014-08-15	Wet Chemistry	Well 02	Well 2 - Water Quality
STW-3	SP 1009095-1	2010-09-03	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality
	SP 1009095-1	2010-09-03	General Mineral	Well 03 (1B)	Well 3 - Water Quality
	SP 1009095-1	2010-09-03	Metals, Total	Well 03 (1B)	Well 3 - Water Quality
	SP 1308449-1	2013-08-16	Metals, Total	Well 03 (1B)	Well 3 - Water Quality
	SP 1308835-1	2013-08-26	Radio Chemistry	Well 03 (1B)	Well 3 - Radio

	SP 1409256-1	2014-08-15	Wet Chemistry	Well 03 (1B)	Well 3 - Water Quality