

2015 Consumer Confidence Report

Water System Name: City of Kingsburg

Report Date: June 1, 2016

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015 and may include earlier monitoring data. Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

ਇਹ ਸੂਚਨਾ ਮਹੱਤਵਪੂਰਣ ਹੈ ।
ਕ੍ਰਿਪਾ ਕਰਕੇ ਕਿਸੀ ਤੋਂ ਇਸ ਦਾ ਅਨੁਵਾਦ ਕਰਾਉ ।

Your water came from the 7 active wells the City of Kingsburg had in service for 2015: Wells 09, 10, 12, 13, 14, 15 and 16

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Drinking Water Source Assessment Information

An assessment of the drinking water sources was completed in July 2015. These sources are considered most vulnerable to the following activities associated with contaminants detected in the water supply:

- Crops irrigated
- Chemical/Petroleum Processing/Storage
- Pesticide/Fertilizer/Petroleum Storage and Transfer Areas
- Fertilizer, Pesticide/Herbicide Application
- Housing – High Density
- Automobile – Gas Stations
- Historic Gas Stations
- Dry Cleaners
- Photo Processing/Printing
- Storm Drain Discharge Points
- Storm Water Detention Facilities

City Council meetings are held in the Council Chambers on the first and third Wednesday of each month at 6:00PM. You may also view packets on our website at www.cityofkingsburg-ca.gov

For more information about this report, or for any questions relating to your drinking water, please call (559)897-5328

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4 and 5, list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria*	1.1	1	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2015	30	0.001	0	0.015	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2015	30	.052	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	3/21/2013	17	9-23	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	3/21/2013	104	61.4-191	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG)	Typical Source of Contaminant	Health Effects Language
-------------------------	-------------	----------------	---------------------	------------	------------	-------------------------------	-------------------------

(and reporting units)					[MRDLG]		
Arsenic (As) Ppb	2015	.0028	.002-.004	0.010	0	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes	Some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer.
Barium (Ba) Ppb	2015	.3654	.132-.515	1	1	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits	Some people who drink water containing barium in excess of the MCL over many years may experience an increase in blood pressure.
Chromium (Total Cr) Ppb	2015	.0214	.01-.04	.10	.10	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits	Some people who use water containing chromium in excess of the MCL over many years may experience allergic dermatitis.
Nitrate (NO3) Ppm	2015	12.863	9.9 to 44	45	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits	Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of pregnant women.
Gross Alpha pCi/L	2015	9.806	03.92-10.42	15	None	Erosion of natural deposits.	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
Dibromochloropropane (DBCP) ppt	2015	.0875	ND to .130	0.02	1.7	Banned nematocide that may still be present in soils due to runoff or leaching from former use on soybeans, cotton, vineyards, tomatoes and tree fruit	Some people who use water containing DBCP in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant	
Chloride ppm	3/21/2013	17.5	9-31	500	n/a	Runoff/leaching from natural deposits; seawater influence	
Specific Conductance umhos/cm	3/21/2013	292.7	185-449	1600	n/a	Substances that form ions when in water; seawater influence	
Sulfate(SO4) ppm	3/21/2013	8.2	4-23	500	n/a	Runoff/leaching from natural deposits; industrial wastes	
TDS ppm	2013	190	120-300	1000	n/a	Runoff/leaching from natural deposits	
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	PHG	MCL	Health Effects Language

Vanadium ppm	2015	36.857	23 - 44	50	n/a	No MCL Established	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental defects, based on studies in laboratory animals.
123 TCP	2015	Well #9 Well #12 Well #13	.0029ug/L .001-0.034ug/L .015 - 0.016ug/L	0.0007 ug/L	0.0007 ug/L	No MCL Established	Some people who use water containing 1,2,3-trichloropropane in excess of the notification level or public health goal over many years may have an increased risk of getting cancer, based on studies in laboratory animals.

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Kingsburg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The City of Kingsburg is located in the highly developed agricultural area of the San Joaquin Valley and is susceptible to a variety of contaminants associated with agriculture. DBCP is a contaminant known to exist throughout the valley and has been detected in Wells 9, 10, 12 and 13. Even though DBCP has been detected the results are below the MCL and do not pose any health risk.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Total Coliform Bacteria*	There were higher than normal detections of bacteria in the City Water System during 1 month of 2015. Immediate chlorination was done to remedy the situation.	1 month	The City is undertaking an investigation to determine the cause of bacteriological problems. Once the problem is identified it will be corrected in conjunction with direction from the State Water Quality Board.	

NEW OUTDOOR WATERING REGULATIONS AS OF 6/1/2016 FOR THE CITY OF KINGSBURG

Let your gardener or landscaper know that watering regulations apply all year long.

Odd numbered addresses:

Your watering days are Tuesday, Thursday and Saturday ONLY!

Even numbered addresses:

Your watering days are Wednesday, Friday and Sunday ONLY!

Outdoor irrigation will be allowed three (3) days per week during the months of April through October.

Watering will be prohibited between the hours of 6am to 6pm (previously 6am to 8pm).

Water must not be allowed to flow beyond property line in the street or the alley.

NO watering on Monday

Individual monthly usage fines will be suspended.

Crews will continue to monitor regular watering practices and issue citations for those watering during non-water days or for wasting water (water flowing beyond the property line).

It should be noted no warnings will be issued and first violations start at \$25.00

THANK YOU FOR CONTINUING TO USE WATER WISELY.

Source Water Protection Tips for Consumers

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA’s Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network’s How to Start a Watershed Team.

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

Take short showers – a 5 minutes shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.

- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They are inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaking toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.

Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month’s water bill!




July 2016

Sun	Mon	Tue	Wed	Thu	Fri	Sat
Community Services and Chamber of Commerce— Community Calendar <small>For more information, please call 897-6549 or 897-1111.</small>					1 Friday Night Swim @ 7:00PM—Crandell	2
3 FIREWORKS @ 7:00PM—KHS	4	5	6	7 Summer Band Concert @ 1:00PM Memorial Park	8 Friday Night Swim @ 7:00PM—Crandell	9 The Never Ending Story @ 8:30PM Memorial Park
10	11 Session 3— Swim Lessons	12	13	14 Summer Band Concert @ 1:00PM Memorial Park	15 Friday Night Swim @ 7:00PM—Crandell	16
17	18	19	20	21 Summer Band Concert @ 1:00PM Memorial Park	22 Friday Night Swim @ 7:00PM—Crandell	23 Back to the Future @ 8:30PM Memorial Park
24	25 Session 4— Swim Lessons	26	27	28 Summer Band Concert @ 1:00PM Memorial Park	29 Friday Night Swim @ 7:00PM—Crandell	30
31						




August 2016

Sun	Mon	Tue	Wed	Thu	Fri	Sat
	1	2 National Night Out!! @ 6:00PM Memorial Park	3	4	5 Friday Night Swim @ 7:00PM—Crandell	6 Last day of Public Swim
7	8	9	10	11	12	13 School of Rock @ 8:30PM— Memorial Park
14	15	16	17	18	19	20
21	22	23	24	25	26	27
28	29	30	31	Community Services and Chamber of Commerce— Community Calendar <small>For more information, please call 897-6549 or 897-1111.</small>		



STOP LEAKS

192 gls a month wasted by a leaking faucet
30-500 gls a day lost from leaking toilet
970 gls a day potential loss from leaking pool equipment

UPGRADE

12 gls per load: used by old dishwasher
6 gls per load: used by new dishwasher
3.6 gls per flush: old toilet
1.6 gls per flush: new toilet
41 gls per load: top load washer
23 gls per load: front load washer

CHANGE HABITS

3 gls per day: saved if you turn off tap while brushing teeth
5 gls saved: by cutting a shower shorter by 2 minutes
17 gls saved: if shower is off except for wetting and rinsing
150 gls saved: if you sweep instead of hosing off sidewalks
40-80 gls: used if hose runs while washing car
12 gls: used for self-service car wash
45 gls: commercial car wash

PAY ATTENTION

40 gls day: if landscaping is adjusted for weather
25 gls day: if watering is done before 8 AM
16 gls day: benefit of fixing broken sprinklers & leaks
adjusting spray to avoid waste
33 percent: average savings if lawn is replaced with drought tolerant landscaping



City of Kingsburg
1401 Draper Street
Kingsburg, CA 93631