

# ATTACHMENT 7

## Consumer Confidence Report Certification Form (to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name: Seeley County Water District

Water System Number: 1310013

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 07/01/2016 to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: John H. Kemp  
Signature:   
Title: Chief Plant Operator  
Phone Number: (760) 352-6612 Date: 07/05/2016

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: \_\_\_\_\_

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

Posting the CCR on the Internet at www.\_\_\_\_\_

Mailing the CCR to postal patrons within the service area (attach zip codes used)

Advertising the availability of the CCR in news media (attach copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)

Posted the CCR in public places (attach a list of locations)

Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

Delivery to community organizations (attach a list of organizations)

Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.\_\_\_\_\_

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

*This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.*

# SEELEY COUNTY WATER DISTRICT

1898 West Main Street (P.O. Box 161) Seeley, CA 92273

Telephone: 760.352.6612 Facsimile: 760.352.0589



**Board President:** Beatriz Scroggins

**Board Members:** Alberto Aguilar, Jason Grima, Manuel Robles, Patrick Harris

2015 Consumer Confidence Report Page 2

A copy of the 2015 CCR was posted both inside and outside of Seeley Post Office. A copy was also posted outside the city market.

A copy of the 2015 CCR was delivered by mail to all customers within the service area at zip code 92273. In addition, the following zip codes were used in cases where property owners rent out housing within the service but live in/receive mail outside the service area:

92273  
92243  
92244  
92021  
91963  
95604  
92202  
92623  
91978

# 2015 Consumer Confidence Report

Water System Name: Seeley County Water District Report Date: 5/17/2016

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use:	Surface Water
Name & general location of source(s):	Imperial Irrigation District - Central Main - Elder Canal
Drinking Water Source Assessment information:	A Watershed Sanitary Survey of the IID's Central Main Canal was completed in September 2014. A copy of the complete assessment is available at the State Water Resources Control Board, Division of Drinking Water, 1350 Front Street Room 2050, San Diego, CA 92101. Phone: (619) 525-4159 Fax: (619) 525-4383.
Time and place of regularly scheduled board meetings for public participation:	Board meetings are held at 6:30 pm every other Tuesday at the Seeley County Water District Main Office. 1898 W. Main Street Seeley, Ca. 92273
For more information, contact:	<u>John Kemp</u> Phone: <u>760352-6612</u>

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variances and Exemptions:** State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	10/28/15	10	ND	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	10/28/15	10	0.083	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	10/22/15	120	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	10/22/15	340	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

\*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic ( $\mu\text{g/L}$ )	10/22/15	2.4	N/A	10	0.004	Erosion of natural deposits; runoff from orchards, runoff from glass and electronics production wastes
Barium ( $\mu\text{g/L}$ )	10/22/15	120	N/A	1000	2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (mg/L)	10/22/15	0.42	N/A	2	1	Erosion of natural deposits; discharge from fertilizer and aluminum factories
TTHMs (ppb)*	7/7/15	124	96-170	80	N/A	Byproduct of drinking water disinfection
HAA5 (ppb)*	7/7/15	77	34-110	60	N/A	Byproduct of drinking water disinfection

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride(mg/l)	10/22/15	130	N/A	250	N/A	Chlorides are leached from various rocks into soil and water by weathering. The chloride ion is highly mobile and is transported to closed basins or oceans.
Aluminum ( $\mu\text{g/l}$ )	10/22/15	190	N/A	200	N/A	Aluminum is released to the environment mainly by natural processes
Iron ( $\mu\text{g/l}$ )	10/22/15	180	N/A	300	N/A	Aeration of iron-containing layers in the soil can affect the quality of both groundwater and surface water if the groundwater table is lowered or nitrate leaching takes place. Dissolution of iron can occur as a result of oxidation and decrease in pH

**TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
pH	10/22/15	8.1	N/A	N/A	N/A
Calcium	10/22/15	84	N/A	N/A	N/A

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Seeley County Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

### Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
TTHM above MCL	TTHMs are disinfection by products (DBPs). Their formation is a result of a disinfectant (chlorine) reacting to naturally occurring organic matter present in water	01/01/2015 – 12/31/2015	The Holt Group, an engineering firm, was contacted. Plans and a timeline have been developed to install a sprinkler system inside the finished water tanks to help reduce DBP formation in our water.	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.
HAA5 above MCL	HAA5, a disinfection by product, is a result of a disinfectant (chlorine) reacting to naturally occurring organic matter present in the source water	07/01/2015 – 12/31/2015	The Holt Group, an engineering firm, was contacted. Plans and a timeline have been developed to install a sprinkler system inside the finished water tanks to help reduce DBP formation in our water.	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

## For Systems Providing Surface Water as a Source of Drinking Water

<b>TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES</b>	
Treatment Technique <sup>(a)</sup> (Type of approved filtration technology used)	Conventional Filtration
Turbidity Performance Standards <sup>(b)</sup> (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 – Be less than or equal to <b>0.30</b> NTU in 95% of measurements in a month. 2 – Not exceed <b>1.0</b> NTU for more than eight consecutive hours. 3 – Not exceed <b>1.49</b> NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	90%
Highest single turbidity measurement during the year	0.45 NTU
Number of violations of any surface water treatment requirements	

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

\* Any violation of a TT is marked with an asterisk. Additional information regarding the violation is provided below.