

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: **ENVIRONMENTAL CARE INDUSTRIES-VLY CREST**

Water System Number: **1900122**

The water system above hereby certifies that its Consumer Confidence Report was distributed on 7-1-16 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name Frank Tempel
Signature [Signature]
Title Report Manager
Phone Number (818) 844-5959 Date _____

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

Delivered in Person

_____ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

_____ Posted the CCR on the internet at http:// _____

_____ Mailed the CCR to postal patrons within the service area (attach zip codes used)

_____ Advertised the availability of the CCR in news media (attach a copy of press release)

_____ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

_____ Posted the CCR in public places (attach a list of locations)

_____ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

_____ Delivery to community organizations (attach a list of organizations)

_____ Other (attach a list of other methods used)

_____ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// _____

_____ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2015 Consumer Confidence Report

Water System Name: ENVIRONMENTAL CARE INDUSTRIES-VLY CREST

Report Date: July 2016

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 1 source(s): Well 01

For more information about this report, or any questions relating to your drinking water, please call (323) 852-1400 ext 140 and ask for Greg Tuttle.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4 and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ppb)	15 (2015)	1.9	1	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	15 (2015)	0.15	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2014)	69	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2014)	793	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (ppm)	(2014)	0.1	N/A	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (ppm)	(2015)	0.8	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2014)	0.8	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 4 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2014)	53	N/A	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2014)	520	N/A	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	(2014)	230	N/A	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2014)	1560	N/A	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2014)	559	N/A	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2014)	1230	N/A	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2014)	1.9	N/A	5	n/a	Soil runoff

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 5 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2014)	0.2	N/A	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts if some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Valley Crest Landscape Development* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you

can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Lead: Infants and children who drink water containing lead in excess of the action level may experience delays in their physical or mental development. Children may show slight deficits in attention span and learning abilities. Adults who drink this water over many years may develop kidney problems or high blood pressure.

About our Iron: Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Sulfate: Sulfate was found at levels that exceed the secondary MCL. The Sulfate MCL was set to protect you against unpleasant aesthetic effects such as color, taste or odor. Violating this MCL does not pose a risk to public health.

About our Total Dissolved Solids: The TDS or Total Dissolved Solids in your water was found at levels that exceed the secondary MCL. The TDS MCLs was set to protect you against unpleasant aesthetic affects such as color, taste or hardness. Violating this MCL does not pose a risk to public health.

2015 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment for the WELL 01 of the ENVIRONMENTAL CARE INDUSTRIES-VLY CREST water system in April, 2002.

Discussion of Vulnerability

is considered most vulnerable to the following activities not associated with any detected contaminants:

Boat services/repair/refinishing
Furniture repair/manufacturing

Acquiring Information

A copy of the complete assessment may be viewed at:

Los Angeles County Environmental Health
2525 Corporate Pl. Room 150
Monterey Park, CA 91754

You may request a summary of the assessment be sent to you by contacting:

Russ Johnson
Chief Environmental Health Specialist
(323) 881-4147

Valley Crest Landscape Development

Analytical Results By FGL - 2015

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ppb	0	15	0.2			1.9	15
CuPb-Building #1 Mens Restroom	SP 1508190-1	ppb				2015-07-21	ND		
CuPb-Building #3 Mens Restroom	SP 1508190-3	ppb				2015-07-21	35.2		
CuPb-Building 1 Top Sink	SP 1508190-2	ppb				2015-07-21	ND		
CuPb-Building A5 Mens Restroom	SP 1508190-5	ppb				2015-07-21	ND		
CuPb-CM Top Soil Mens Restroom	SP 1509163-10	ppb				2015-08-18	ND		
CuPb-CM Top Soil Mens Restroom	SP 1508190-4	ppb				2015-07-21	ND		
CuPb-CM Top Soil OutsideWash F	SP 1509163-9	ppb				2015-08-18	ND		
CuPb-CM Top Soil Wash Sink	SP 1509163-8	ppb				2015-08-18	ND		
CuPb-Enterprise Bldg.1-Mens RR	SP 1509163-4	ppb				2015-08-18	ND		
CuPb-Enterprise Bldg.1-Womens	SP 1509163-5	ppb				2015-08-18	ND		
CuPb-Enterprise Bldg.2-Mens RR	SP 1509163-6	ppb				2015-08-18	ND		
CuPb-Enterprise Bldg.2-Womens	SP 1509163-7	ppb				2015-08-18	ND		
CuPb-Office Bldg.1- Wash Sink	SP 1509163-3	ppb				2015-08-18	ND		
CuPb-Office Bldg.1-Mens Restro	SP 1509163-1	ppb				2015-08-18	ND		
CuPb-Office Bldg.1-Womens Rest	SP 1509163-2	ppb				2015-08-18	ND		
Copper		ppm		1.3	.3			0.15	15
CuPb-Building #1 Mens Restroom	SP 1508190-1	ppm				2015-07-21	0.15		
CuPb-Building #3 Mens Restroom	SP 1508190-3	ppm				2015-07-21	0.27		
CuPb-Building 1 Top Sink	SP 1508190-2	ppm				2015-07-21	ND		
CuPb-Building A5 Mens Restroom	SP 1508190-5	ppm				2015-07-21	0.13		
CuPb-CM Top Soil Mens Restroom	SP 1509163-10	ppm				2015-08-18	ND		
CuPb-CM Top Soil Mens Restroom	SP 1508190-4	ppm				2015-07-21	ND		
CuPb-CM Top Soil OutsideWash F	SP 1509163-9	ppm				2015-08-18	ND		
CuPb-CM Top Soil Wash Sink	SP 1509163-8	ppm				2015-08-18	0.07		
CuPb-Enterprise Bldg.1-Mens RR	SP 1509163-4	ppm				2015-08-18	0.11		
CuPb-Enterprise Bldg.1-Womens	SP 1509163-5	ppm				2015-08-18	0.09		
CuPb-Enterprise Bldg.2-Mens RR	SP 1509163-6	ppm				2015-08-18	0.09		
CuPb-Enterprise Bldg.2-Womens	SP 1509163-7	ppm				2015-08-18	0.20		
CuPb-Office Bldg.1- Wash Sink	SP 1509163-3	ppm				2015-08-18	0.08		
CuPb-Office Bldg.1-Mens Restro	SP 1509163-1	ppm				2015-08-18	0.09		
CuPb-Office Bldg.1-Womens Rest	SP 1509163-2	ppm				2015-08-18	0.08		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			69	69 - 69
Well 01	SP 1405509-1	ppm				2014-05-14	69		
Hardness		ppm		none	none			793	793 - 793
Well 01	SP 1405509-1	ppm				2014-05-14	793		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		ppm		2	1			0.1	0.1 - 0.1
Well 01	SP 1405509-1	ppm				2014-05-14	0.1		
Nitrate as N		ppm		10	10			0.8	0.81 - 0.81
Well 01	SP 1506780-2	ppm				2015-06-17	0.81		
Nitrate + Nitrite as N		ppm		10	10			0.8	0.8 - 0.8
Well 01	SP 1405509-1	ppm				2014-05-14	0.8		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
-------------------------------------------	--	--	--	--	--	--	--	--	--

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500	n/a			53	53 - 53
Well 01	SP 1405509-1	ppm				2014-05-14	53		
Iron		ppb		300	n/a			520	520 - 520
Well 01	SP 1405509-1	ppb				2014-05-14	520		
Manganese		ppb		50	n/a			230	230 - 230
Well 01	SP 1405509-1	ppb				2014-05-14	230		
Specific Conductance		umhos/cm		1600	n/a			1560	1560 - 1560
Well 01	SP 1405509-1	umhos/cm				2014-05-14	1560		
Sulfate		ppm		500	n/a			559	559 - 559
Well 01	SP 1405509-1	ppm				2014-05-14	559		
Total Dissolved Solids		ppm		1000	n/a			1230	1230 - 1230
Well 01	SP 1405509-1	ppm				2014-05-14	1230		
Turbidity		NTU		5	n/a			1.9	1.9 - 1.9
Well 01	SP 1405509-1	NTU				2014-05-14	1.9		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		ppm		NS	n/a			0.2	0.2 - 0.2
Well 01	SP 1405509-1	ppm				2014-05-14	0.2		

Valley Crest Landscape Development

CCR Login Linkage - 2015

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
Building #1 Men	SP 1508190-1	2015-07-21	Metals, Total	CuPb-Building #1 Mens Restroom	Lead & Copper Monitoring
Building #3 Men	SP 1508190-3	2015-07-21	Metals, Total	CuPb-Building #3 Mens Restroom	Lead & Copper Monitoring
Building 1 Top	SP 1508190-2	2015-07-21	Metals, Total	CuPb-Building 1 Top Sink	Lead & Copper Monitoring
Building A5 Men	SP 1508190-5	2015-07-21	Metals, Total	CuPb-Building A5 Mens Restroom	Lead & Copper Monitoring
CM Top Soil Men	SP 1508190-4	2015-07-21	Metals, Total	CuPb-CM Top Soil Mens Restroom	Lead & Copper Monitoring
CM Mens	SP 1509163-10	2015-08-18	Metals, Total	CuPb-CM Top Soil Mens Restroom	Lead & Copper Monitoring
CM Outside Fauc	SP 1509163-9	2015-08-18	Metals, Total	CuPb-CM Top Soil OutsideWash F	Lead & Copper Monitoring
CM Wash Sink	SP 1509163-8	2015-08-18	Metals, Total	CuPb-CM Top Soil Wash Sink	Lead & Copper Monitoring
Ent. 1 Mens	SP 1509163-4	2015-08-18	Metals, Total	CuPb-Enterprise Bldg.1-Mens RR	Lead & Copper Monitoring
Ent. 1 Womens	SP 1509163-5	2015-08-18	Metals, Total	CuPb-Enterprise Bldg.1-Womens	Lead & Copper Monitoring
Ent. 2 Mens	SP 1509163-6	2015-08-18	Metals, Total	CuPb-Enterprise Bldg.2-Mens RR	Lead & Copper Monitoring
Ent. 2 Womens	SP 1509163-7	2015-08-18	Metals, Total	CuPb-Enterprise Bldg.2-Womens	Lead & Copper Monitoring
Off Bldg1 Wash	SP 1509163-3	2015-08-18	Metals, Total	CuPb-Office Bldg.1- Wash Sink	Lead & Copper Monitoring
Off Bldg1 Mens	SP 1509163-1	2015-08-18	Metals, Total	CuPb-Office Bldg.1-Mens Restro	Lead & Copper Monitoring
Off Bldg1 Women	SP 1509163-2	2015-08-18	Metals, Total	CuPb-Office Bldg.1-Womens Rest	Lead & Copper Monitoring
Domestic Water	SP 1501029-1	2015-01-28	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1501178-1	2015-02-02	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1503014-1	2015-03-17	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1504423-1	2015-04-23	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1505513-1	2015-05-18	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1506780-1	2015-06-17	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1508191-1	2015-07-23	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1509158-1	2015-08-18	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1510639-1	2015-09-24	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1512028-1	2015-10-28	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1512749-1	2015-11-13	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
	SP 1514094-1	2015-12-17	Coliform	Domestic Water Storage Tank	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122
Well 01	SP 1405509-1	2014-05-14	General Mineral	Well 01	Water Quality Monitoring
	SP 1405509-1	2014-05-14	Wet Chemistry	Well 01	Water Quality Monitoring
	SP 1506780-2	2015-06-17	Wet Chemistry	Well 01	ECI - VC 12087 Lopez Cyn. Rd.-Sys No. 1900122