

ATTACHMENT 7

Consumer Confidence Report Certification Form


(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: John B. Sanfilippo & Sons, Inc.

Water System Number: 2400231

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/2/16 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Scott Crist
Signature: 
Title: System Operator
Phone Number: (209) 827-1799 Date: 5/31/16

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- ☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: _____
- ☒ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- ☐ Posting the CCR on the Internet at www.
 - ☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - ☐ Advertising the availability of the CCR in news media (attach copy of press release)
 - ☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - ☒ Posted the CCR in public places (attach a list of locations) Break rooms and bulletin boards.
 - ☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - ☐ Delivery to community organizations (attach a list of organizations)
 - ☐ Other (attach a list of other methods used)
- ☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.
- ☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

2015 Consumer Confidence Report

Water System Name:	John B. Sanfilippo & Son, Inc.	Report Date:	09/28/16
--------------------	---	--------------	----------

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015 and may include earlier monitoring data.

**Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use:	Groundwater Well
---------------------------------	------------------

Name & general location of source(s):	Well at 29241 W. Cottonwood Rd. Gustine, CA
---------------------------------------	---

Drinking Water Source Assessment information:	None Available
---	----------------

Time and place of regularly scheduled board meetings for public participation:	None
--	------

For more information, contact:	Scott Crist	Phone:	(209) 769-7205
--------------------------------	-------------	--------	----------------

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (and reporting units)	Sample Date	No. of Samples Collected	90 th Percentile Level Detected	No. Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	08/22/15	5	< 5	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	08/22/15	5	0.4	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 3 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate as Nitrogen (ppm)	2015	9	8 – 9	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/l)	2015	4	4 – 4	15	(0)	Erosion of natural deposits
Chromium (ppb)	08/21/15	14	14	50	(100)	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Hexavalent Chromium (ppb)	2015	12*	12 – 12	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, and textile manufacturing facilities; erosion of natural deposits

TABLE 4 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (ppm)	08/21/15	892	892	1000	N/A	Runoff/leaching from natural deposits
Specific Conductance (umho/cm)	08/21/15	1318	1318	1600	N/A	Substances that form ions when in water; seawater influence
Turbidity (NTU)	08/21/15	0.4	0.4	5	N/A	Soil runoff
Foaming Agents (MBAS) (ppm)	08/21/15	0.04	0.04	0.5	N/A	Municipal and industrial waste discharges
Chloride (ppm)	08/21/15	147	147	500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	08/21/15	119	119	500	N/A	Runoff/leaching from natural deposits' industrial wastes
Sodium (ppm)	08/21/15	110	110	None	None	Generally found in ground and surface water
Hardness (ppm)	08/21/15	462	462	None	None	Generally found in ground and surface water

TABLE 5 - DETECTION OF ADDITIONAL CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Range of Detections	MCL (MRDL)	Health Effects Language
Distribution System Chlorine Residual (ppm)	2015	0.2 – 0.5	(4)	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided on the next page.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.

Summary Information for Contaminants Exceeding an MCL or AL, or a Violation of any Treatment or Monitoring and Reporting Requirements

In 2015, hexavalent chromium was detected at the well above the maximum allowable limit. In response, the water system has gone to a quarterly testing schedule for hexavalent chromium. No further action from the State has been required at this time. Some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.