

2015 Consumer Confidence Report

Water System Name: MWD of So. California – Julian Hinds Pumping Plant Report Date: June 2, 2016

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1–December 31, 2015 and may include earlier monitoring data. **All primary drinking water standards were met during this period.**

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: River
Name & location of source(s): Colorado River at Lake Havasu, Whitsett Intake Pumping Plant
Drinking Water Source Assessment information: Metropolitan completed a Source Water Assessment of its Colorado River supplies upstream of the Whitsett Intake Pumping Plant in December 2002 and submitted an updated Colorado River watershed Sanitary Survey in March 2012. This source is considered to be most vulnerable to treated wastewater discharges, urbanization in the watershed, and recreation, which may contribute sources of nutrients, pathogens, metals, and other chemicals of concern.
Time and place of regularly scheduled board meetings for public participation: 11:30 A.M., 2nd Tuesday of every month, 700 N. Alameda St., Los Angeles, California 90012
For more information, contact: Sun Liang, Ph.D., P.E. Phone: (909) 392-5273

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Notification Level (NL): The level at which notification of the water system's governing body is required.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

CaCO₃ Calcium Carbonate

CFU: colony-forming units

DLR: State's detection limit for purposes of reporting

LRAA: Locational Running Annual Average

ND: not detected at testing limit or reporting level

NA: not applicable

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

pCi/L: picocuries per liter (a measure of radiation)

RAA: Running annual average; *highest RAA* is the highest of all RAA calculated as average of all the samples collected within a 12-month period; the calculated RAA for the first three quarters (quarters 1–3) are based on results from the previous quarters of the past calendar year

TON: threshold odor number

µS/cm: microSiemen per centimeter

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, motorized water-craft, urban storm water runoff, agricultural applications, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1 through 8 show results for constituents detected during the current reporting period. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1A – DISTRIBUTION SYSTEM SAMPLING RESULTS FOR COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0 <i>(In a month)</i>	0	No more than 1 positive monthly sample	0	Naturally present in the environment
<i>E. coli</i>	0 <i>(In the year)</i>	0	<u>Acute Violation:</u> A routine sample and a repeat sample are total coliform positive, and at least one of these is also <i>E. coli</i> positive	0	Human and animal fecal waste

TABLE 1B – SOURCE WATER SUPPLY SHOWING THE DETECTION OF COLIFORM BACTERIA ⁽¹⁾

Microbiological Contaminants	Sample Date	Range Average	Results	Trigger Level ⁽²⁾ (MCL)	Typical Source of Bacteria
Total Coliform Bacteria (CFU/100 ml)	1/15–12/15 (Weekly)	Range	ND–4,200	NA	Naturally present in the environment
		Median	1,500		
<i>E. coli</i> (CFU/100 ml)	1/15–12/15 (Weekly)	Range	ND–1	100 (None)	Human and animal fecal waste
		Median	ND		

- (1) Samples were taken from the Colorado River Aqueduct prior to Hinds’ sand trap. Reporting level is 1 CFU/100 ml for total coliform and *E. coli*.
- (2) If the *E. coli* levels exceed 100 CFU/100 ml as a weekly median, additional treatment or operational controls will be provided per the MWD action plan.

TABLE 2 – DISTRIBUTION SYSTEM MONITORING RESULTS FOR LEAD AND COPPER ⁽³⁾

Lead and Copper (and reporting units)	Sample Date	No. of Samples Collected	Results 90 th Percentile	No. Sites Exceeding AL	AL	PHG	Typical Source
Lead (ppb)	July 2014; August 2014	5	2	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	July 2014; August 2014	5	0.162	0	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SOURCE WATER MONITORING RESULTS FOR SODIUM AND HARDNESS ⁽⁴⁾

Chemical or Constituent (and reporting units)	Sample Date	Range Average	Results	MCL	PHG (MCLG)	Typical Source
Sodium (ppm)	April 2015; October 2015	Range	88–104	None	None	Generally found in ground and surface water
		Average	96			
Hardness (as CaCO ₃) (ppm)	April 2015; October 2015	Range	298–304	None	None	Generally found in ground and surface water
		Average	301			

TABLE 4 – SOURCE WATER MONITORING RESULTS FOR CONSTITUENTS WITH A PRIMARY DRINKING WATER STANDARD ⁽⁴⁾

Chemical or Constituent (and reporting units)	Sample Date	Range Average	Results	MCL	PHG (MCLG)	Typical Source of Contaminant
Arsenic (ppb)	April 2015	Range	2.7	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
		Average	2.7			
Barium (ppb)	April 2015	Range	128	1,000	2,000	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
		Average	128			
Chromium VI (ppb) ⁽⁵⁾	April 2015	Range	ND	10	0.02	Naturally-occurring; industrial processes
		Average	ND			
Fluoride (ppm) (naturally-occurring)	April 2015; October 2015	Range	0.3	2.0	1	Erosion of natural deposits; discharge from fertilizer and aluminum factories
		Average	0.3			
Nitrate (as Nitrogen) (ppm)	April 2015; October 2015	Range	ND–0.4	10	10	Runoff and leaching from fertilizer use; septic tank and sewage; natural deposits erosion
		Average	ND			
Perchlorate (ppb) ⁽⁶⁾	April 2015	Range	ND	6	1	Industrial waste discharge
		Average	ND			
Gross Alpha Particle Activity (pCi/L) ⁽⁷⁾	2014 (Quarterly)	Range	ND–3	15	(0)	Erosion of natural deposits
		Average	ND			
Gross Beta Particle Activity (pCi/L) ^(7,8)	2014 (Quarterly)	Range	4–6	50	(0)	Decay of natural and man-made deposits
		Average	6			
Uranium (pCi/L) ⁽⁷⁾	2014 (Quarterly)	Range	2–3	20	0.43	Erosion of natural deposits
		Average	2			

(3) The 90th percentile for lead was above the public health goal (PHG), but is in compliance with the federal and state lead and copper rule. Data are from samples collected (triennially) in 2014 and reported for three years until the next samples are collected.

(4) Samples were taken from the Colorado River at Lake Havasu, Whitsett Intake Pumping Plant.

(5) Metropolitan's chromium VI reporting level is 0.03 ppb, which is below the State DLR of 1 ppb. Results above Metropolitan's reporting level and below the DLR are reported as ND in this report. Chromium monitoring data are available upon request.

(6) Metropolitan's perchlorate reporting level is 0.1 ppb for Lake Havasu, which is below the State DLR of 4 ppb. Results above Metropolitan's reporting level and below the DLR are reported as ND in this report. Perchlorate monitoring data are available upon request.

(7) Data are from samples collected (triennially) during four consecutive quarters of monitoring in 2014 and reported for three years until the next samples are collected.

(8) The gross beta particle activity MCL is 4 millirem/year annual dose equivalent to the total body or any internal organ. The screening level is 50 pCi/L.

TABLE 5 – DISTRIBUTION SYSTEM MONITORING RESULTS FOR DISINFECTION BYPRODUCTS AND DISINFECTANT RESIDUALS

Chemical or Constituent (and reporting units)	Sample Date	Range Average	Results	MCL ⁽⁹⁾ [MRDL]	PHG [MRDLG]	Typical Source
Total Trihalomethanes (TTHM) (ppb)	1/15–12/15 (Quarterly)	Range	1.4–64	80	None	Byproduct of drinking water chlorination
		Highest LRAA	41			
Haloacetic Acids (Five) (HAA5) (ppb)	1/15–12/15 (Quarterly)	Range	ND–8.0	60	None	Byproduct of drinking water chlorination
		Highest LRAA	4.5			
Chlorine (Free) Residual (ppm)	1/15–12/15 (Quarterly)	Range	0.22–1.4	[4.0]	[4.0]	Drinking water disinfectant added for treatment
		Highest RAA	0.81			

TABLE 6A – DISTRIBUTION SYSTEM MONITORING RESULTS FOR CONSTITUENTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Range Average	Results	MCL	PHG (MCLG)	Typical Source
Odor Threshold (TON) ⁽¹⁰⁾	September 2015; November 2015	Range	8–10	3	NA	Naturally-occurring organic materials
		Average	9			
Turbidity (NTU) ⁽¹¹⁾	1/15–12/15	Range	ND–0.19	5	NA	Soil runoff
		Average	ND			

TABLE 6B – SOURCE WATER MONITORING RESULTS FOR CONSTITUENTS WITH A SECONDARY DRINKING WATER STANDARD ⁽⁴⁾

Chemical or Constituent (and reporting units)	Sample Date	Range Average	Results	MCL	PHG (MCLG)	Typical Source
Chloride (ppm)	April 2015; October 2015	Range	90–95	500	NA	Runoff/leaching from natural deposits
		Average	92			
Color (units)	April 2015; October 2015	Range	3–4	15	NA	Naturally-occurring organic materials
		Average	4			
Specific Conductance (µS/cm)	April 2015; October 2015	Range	1,020–1,030	1,600	NA	Substances that form ions in water; seawater influence
		Average	1,020			
Sulfate (ppm)	April 2015; October 2015	Range	240–249	500	NA	Runoff/leaching from natural deposits; industrial waste
		Average	245			
Total Dissolved Solids (ppm)	April 2015; October 2015	Range	646–662	1,000	NA	Runoff/leaching from natural deposits
		Average	654			

TABLE 7 – MONITORING RESULTS FOR UNREGULATED CONSTITUENTS

Chemical or Constituent (and reporting units)	Sample Date	Range Average	Results	NL	Health Effects Language
Boron (ppb) ⁽⁴⁾	April 2015	Range	130	1,000	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.
		Average	130		
Chlorate (ppb) (Domestic Tank Effluent)	August 2015	Range	144	800	Byproduct of drinking water chlorination; industrial processes
		Average	144		

(4) Samples were taken from the Colorado River at Lake Havasu, Whitsett Intake Pumping Plant.

(9) Compliance was based on the highest locational running annual average (LRAA) for TTHM and HAA5, and RAA for free chlorine residual. Metropolitan was in compliance with all provisions of the Stage 2 Disinfectants and Disinfection Byproducts Rule.

(10) In September 2015, the annual sample at this location was 10, exceeding the secondary MCL of 3. The TON level was reported to the county of Riverside. Required quarterly monitoring started in November and will continue to be monitored quarterly until the regulation is met. No taste and odor event was observed and no complaints were received during the period.

(11) The turbidity levels for grab samples at this location were in compliance with the Secondary Standard. Turbidity results below the State DLR of 0.1 NTU are reported as ND in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Additional Special Language for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **Julian Hinds Pumping Plant** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES

Treatment Technique ⁽¹²⁾ (Type of approved filtration technology used)	Microfiltration
Turbidity Performance Standards ⁽¹³⁾ (that must be met through the water treatment process)	Turbidity of the filtered water must: ⁽¹⁴⁾ NA 1 - Be less than or equal to ___ NTU in 95% of measurements in a month. 2 - Not exceed ___ NTU for more than eight consecutive hours. 3 - Not exceed ___ NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	NA ⁽¹⁴⁾
Highest single turbidity measurement during the year	0.10 NTU
The number of violations of any surface water treatment requirements	NA ⁽¹⁴⁾

(12) A required process intended to reduce the level of a contaminant in drinking water

(13) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results that meet performance standards are considered to be in compliance with filtration requirements.

(14) Not applicable for Julian Hinds Pumping Plant domestic water system since it is considered a small water system having at least 5 but no more than 14 service connections and does not regularly serve drinking water to more than an average of 25 individuals daily for more than 60 days out of the year. It meets the provisions set forth in California Code of Regulations Title 22, Chapter 14, Article 3 - State Small Water Systems.

Consumer Confidence Report Certification Form


(To be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at
http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: Metropolitan Water District of Southern California – Julian Hinds Pumping Plant

Water System Number: 3301317

The water system named above hereby certifies that its Consumer Confidence Report was distributed on June 3, 2016, to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Sup Liang, Ph.D., P.E.
Signature: 
Title: Water Purification Unit Manager
Phone Number: (909) 392-5273 Date: June 2, 2016

To summarize report delivery used and good-faith efforts taken, please complete this page by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods (attach description of other direct delivery methods used). **Water system emailed the CCR as an electronic file email attachment.**
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
 - Posting the CCR on the Internet at www._____
 - Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - Advertising the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - Posted the CCR in public places (**Hinds Pumping Plant bulletin board**)
 - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following URL: www._____
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.