

2015 Consumer Confidence Report

Hollister Ranch Estates

June 30, 2016

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 – December 31, 2015.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source: The water used by Hollister Ranch Estates consists of two ground water wells. The wells are located on Union Road in Hollister.

Drinking Water Source Assessment: The assessment was completed in 2007 and is available online.

Time and place of regularly scheduled board meetings for public participation: Annually

For more information, contact: MCSI Water Systems Management Phone: (831) 659-5360

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Water Quality Data Tables

The tables below list all of the drinking water contaminants that we detected during the most recent sampling for the constituent. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA					
Microbiological Contaminants (units)	Highest # Detected in a Month	# Of Months in Violation	MCL	MCLG	Typical Source
Total Coliform, Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform/E coli	0	0	A routine sample and repeat sample detect total coliform and either sample also detects fecal coliform or E. coli	0	Human & animal fecal waste

SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Contaminant(s) (units)	PHG	AL	# of Samples taken	90 th Percentile Level Detected	# of Samples > AI	Sample Date	Typical Source
Copper (ppm)	0.17	1.3	5	0.49	0	9/30/14	Erosion of natural deposits; leaching from wood preservatives; internal corrosion of household plumbing systems
Lead (ppb)	0.2	15	5	ND	0	9/30/14	Internal corrosion of household systems; erosion of natural deposits

SAMPLING RESULTS SHOWING THE DETECTION OF RADIOACTIVITY						
Contaminant(s) (units)	PHG/ (MCLG)	MCL	Level Detected (AVG)	Range	Sample Date	Typical Source
Alpha Activity, Gross (pCi/L) – Well 1	(0)	15	1.73		12/2015	Erosion of natural deposits
Alpha Activity, Gross (pCi/L) – Well 2	(0)	15	(7.67)	1.73-16.4	2015	Erosion of natural deposits
Uranium (pCi/L) – Well 2	0.43	20	(21.15)*	6.6-31	2015	Erosion of natural deposits

DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Contaminant(s) (units)	PHG/ (MCLG)	MCL/ (AL)	Level Detected (AVG)	Range	Sample Date	Typical Source
Arsenic (ppb) – Well 1	0.004	10	4.7		12/2013	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Arsenic (ppb) – Well 2	0.004	10	4.5		12/2013	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Hexavalent Chromium (ppb)	0.02	10	<1		10/2014	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refectory production, and textile manufacturing facilities; erosion of natural deposits
Fluoride (ppm) – Well 1	1	2	ND		12/2013	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Fluoride (ppm) – Well 2	1	2	0.3		12/2013	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (N) (ppm) Well 1	10	10	7.5		2015	Runoff and leaching from fertilizer us: leaching from septic tanks and sewage; erosion of natural deposits
Nitrate (N) (ppm) Well 2	10	10	(0.47)	ND-0.81	2015	Runoff and leaching from fertilizer us: leaching from septic tanks and sewage; erosion of natural deposits

DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD					
Contaminant(s) (units)	MCL	Level Detected (AVG)	Range	Sample Date	Typical Source
Chloride (ppm) – Well 1	500	650*		12/2013	Runoff/leaching from natural deposits; sea water influence
Chloride (ppm) – Well 2	500	150		12/2013	Runoff/leaching from natural deposits; sea water influence
Manganese (ppb) – Well 1	50	(57)*	20- 110*	2015	Leaching from natural deposits
Manganese (ppb) – Well 2	50	(60.25)*	20- 93*	2015	Leaching from natural deposits
Sulfate (ppm) – Well 1	500	40		12/2013	Runoff/leaching from natural deposits; industrial wastes
Sulfate (ppm) – Well 2	500	200		12/2013	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm) – Well 1	1000	1300*		12/2013	Runoff/leaching from natural deposits
Total Dissolved Solids (ppm) – Well 2	1000	1026.7*	880- 1100*	2015	Runoff/leaching from natural deposits
Zinc (ppm) – Well 1	5	0.074		12/2013	Runoff/leaching from natural deposits; industrial wastes

SUBSTANCES OF INTEREST						
Contaminant(s) (units)	PHG/ (MCLG)	MCL	AVG	Range	Sample Date	Typical Source
Sodium (ppm)	N/A	N/A	145	120-170	12/2013	Salt present in the water and is generally naturally-occurring
Hardness (ppm)	N/A	N/A	690	513-867	12/2013	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally-occurring.

Additional Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (1-800-426-4791).

Lead Statement for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hollister Ranch Estates is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Nitrate above 5 ppm (50% of the MCL), but below 10 ppm (the MCL) (as nitrogen): Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

- Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.

*** Summary Information for Violation of a MCL, MRDL, AL, TT or Monitoring and Reporting Violation:**

- *Chloride, Manganese, and Total Dissolved Solids* are secondary drinking water standard contaminants and are set to protect you against unpleasant aesthetic effects such as color, taste, odor, and the staining of plumbing fixtures, and clothing while washing. These are not health (Primary) constituents.
- *Uranium:* Some people who drink water containing uranium in excess of the MCL over many years may have kidney problems or an increased risk of getting cancer.

Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Violation of Ground Water TT

- None

For Systems Providing Ground Water as a Source of Drinking Water

SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year)/0	None	0	(0)	Human and animal fecal waste

SPECIAL NOTICE FOR UNCORRECTED DEFICIENCIES

- The water system is deficient due to high uranium results. The annual running average went over the MCL in the fourth quarter of 2015.

System Improvements and Updates:

- The water system plans to develop and execute a corrective action plan for radiologicals and manganese.

Conservation and Drought Tips:

- Contact MCSI at (831) 659-5360 or The Water Awareness Committee at www.waterawareness.org