

ATTACHMENT 7

Consumer Confidence Report Certification Form (to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: Exxon, Las Flores Canyon Project

Water System Number: 4200743

The water system named above hereby certifies that its Consumer Confidence Report was distributed on ~~7-1-16~~ 7-1-16 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Sylvia C Mechtold
Signature: 
Title: Operations Compliance Specialist
Phone Number: (805) 961-4044 Date: 7/1/16

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: _____

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

- Posting the CCR on the Internet at www._____
- Mailing the CCR to postal patrons within the service area (attach zip codes used)
- Advertising the availability of the CCR in news media (attach copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www._____

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

ATTACHMENT 7

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name: Exxon, Las Flores Canyon Project

Water System Number: 4200743

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 6/15/15 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified by: Name: Sylvia C Mechtold
Signature: 
Title: Operations Compliance Specialist
Phone Number: (805) 961-4044 Date: 7/1/16

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

- CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: _____
- "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:
- Posting the CCR on the Internet at www._____
 - Mailing the CCR to postal patrons within the service area (attach zip codes used)
 - Advertising the availability of the CCR in news media (attach copy of press release)
 - Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)
 - Posted the CCR in public places (attach a list of locations)
 - Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools
 - Delivery to community organizations (attach a list of organizations)
 - Other (attach a list of other methods used)
- For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www._____
- For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.

2015 Consumer Confidence Report

Water System Name: EXXON, LAS FLORES CYN PROJECT

Report Date: June 2016

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 5 source(s): Well 03P, Well 07P, Well 11P, Well 11P-2 and Well 8P-2

For more information about this report, or any questions relating to your drinking water, please call (805) 961 - 4044 and ask for Anthony Lopez.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Table 1 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2014)	61	20 - 100	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2014)	358	278 - 474	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 2 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (ppm)	(2008 - 2014)	0.2	0.1 - 0.3	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Gross Alpha (pCi/L)	(2009 - 2014)	2.9	1.70 - 5.86	15	(0)	Erosion of natural deposits.

Table 3 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2014)	31	22 - 45	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2014)	15823	250 - 46800	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ppb)	(2008 - 2014)	83	30 - 110	50	n/a	Leaching from natural deposits

Odor Threshold at 60 °C (TON)	(2014)	8	N/A	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2008 - 2014)	934	633 - 1280	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2008 - 2014)	224	109 - 370	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2008 - 2014)	630	410 - 900	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2008 - 2014)	15.8	1.5 - 69.2	5	n/a	Soil runoff
Zinc (ppm)	(2014)	0.62	0.21 - 1.03	5	n/a	Runoff/leaching from natural deposits

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 4 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2008 - 2014)	0.1	0.1 - 0.2	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *ExxonMobil* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Iron: Iron was found at levels that exceed the secondary MCL. The Iron MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Manganese: Manganese was found at levels that exceed the secondary MCL. The Manganese MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Odor Threshold at 60 °C: Odor was found at levels that exceed the secondary MCL. The Odor MCL was set to protect you against unpleasant aesthetic affects such as color, taste, odor and the staining of plumbing fixtures (e.g., tubs and sinks), and clothing while washing. Violating this MCL does not pose a risk to public health.

About our Turbidity: Turbidity is Secondary Drinking Water Standards and has found no health effects. However, high levels of turbidity can interfere with *disinfection and provide a medium for microbial growth*. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

2015 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 02 of the PACIFIC OFFSHORE PIPELINE COMP water system in September, 2002.

- Well 03P - is not considered vulnerable to any potentially contaminating activities at this time.
- Well 07P - is considered most vulnerable to the following activities not associated with any detected contaminants:
Wells - Water supply
- Well 11P - is not considered vulnerable to any potentially contaminating activities at this time.
- Well 11P-2 - does not have a completed Source Water Assessment on file.
- Well 8P-2 - is considered most vulnerable to the following activities not associated with any detected contaminants:
NPDES/WDR permitted discharges

Discussion of Vulnerability

There have been no contaminants detected in the water supply above the Maximum Contaminant Level, however the source is still considered vulnerable to activities located near the drinking water source.

Acquiring Information

Environmental Health Services
225 Camino del Remedio
Santa Barbara, CA 93110

You may request a summary of the assessment be sent to you by contacting:

Norman Fujimoto
Environmental Health Specialist
805-681-4917
805-681-4901 (fax)
Fujimoto@co.santa-barbara.ca.us

ExxonMobil

Analytical Results By FGL - 2015

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
1stFloorAdmin.Bldg.-PrimaryTap	SP 1507788-1					2015-07-14	Absent		
1stFloorAdmin.Bldg.-PrimaryTap	SP 1506353-1					2015-06-05	Absent		
1stFloorAdmin.Bldg.-PrimaryTap	SP 1504875-1					2015-05-05	Absent		
1stFloorAdmin.Bldg.-PrimaryTap	SP 1503719-1					2015-04-07	Absent		
1stFloorAdmin.Bldg.-PrimaryTap	SP 1502709-1					2015-03-10	Absent		
1stFloorAdmin.Bldg.-PrimaryTap	SP 1501591-1					2015-02-10	Absent		
1stFloorAdmin.Bldg.-PrimaryTap	SP 1500133-1					2015-01-06	Absent		
Building A Kitchen Sink	SP 1513403-1					2015-12-02	Absent		
Building A Kitchen Sink	SP 1512867-1					2015-11-17	Absent		
Building A Kitchen Sink	SP 1511437-1					2015-10-13	Absent		
Building A Kitchen Sink	SP 1510247-1					2015-09-15	Absent		
Building A Kitchen Sink	SP 1509184-1					2015-08-18	Absent		
Building A Kitchen Sink	SP 1507791-1					2015-07-14	Absent		
Building A Kitchen Sink	SP 1506354-1					2015-06-05	Absent		
Building A Kitchen Sink	SP 1504876-1					2015-05-05	Absent		
Building A Kitchen Sink	SP 1503720-1					2015-04-07	Absent		
Building A Kitchen Sink	SP 1502710-1					2015-03-10	Absent		
Building A Kitchen Sink	SP 1501590-1					2015-02-10	Absent		
Building A Kitchen Sink	SP 150132-1					2015-01-06	Absent		
Building A Kitchen Sink	SP 1500132-1					2015-07-17	<1.0		
Control Rm Break Room Sink	SP 1507995-1					2015-07-14	Present		
ControlRmBreakrmSink-PrimTap	SP 1507790-1					2015-06-05	Absent		
ControlRmBreakrmSink-PrimTap	SP 1506356-1					2015-05-05	Absent		
ControlRmBreakrmSink-PrimTap	SP 1504877-1					2015-04-07	Absent		
ControlRmBreakrmSink-PrimTap	SP 1503721-1					2015-03-10	Absent		
ControlRmBreakrmSink-PrimTap	SP 1502703-1					2015-02-10	Absent		
ControlRmBreakrmSink-PrimTap	SP 1501589-1					2015-01-06	Absent		
ControlRmBreakrmSink-PrimTap	SP 1500134-1					2015-12-02	Absent		
Kitchen Sink	SP 1513402-1					2015-11-17	Absent		
Kitchen Sink	SP 1512864-1					2015-10-13	Absent		
Kitchen Sink	SP 1511438-1					2015-09-15	Absent		
Kitchen Sink	SP 1510246-1					2015-08-18	Absent		
Kitchen Sink	SP 1509186-1					2015-07-17	<1.0		
Mens BR	SP 1507995-2					2015-07-28	Absent		
Mens Change Room	SP 1508359-1					2015-07-17	<1.0		
Well #7 P	SP 1507995-4					2015-07-17	<1.0		
Womens BR	SP 1507995-3					2015-07-17	<1.0		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			61	20 - 100
Well # 11P	SP 1400715-4	ppm				2014-01-21	98		
Well #3P Hose Bibb	SP 1400715-1	ppm				2014-01-21	26		
Well #7 P	SP 1400715-2	ppm				2014-01-21	100		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	20		
Hardness		ppm		none	none			358	278 - 474
Well # 11P	SP 1400715-4	ppm				2014-01-21	474		
Well #3P Hose Bibb	SP 1400715-1	ppm				2014-01-21	309		
Well #7 P	SP 1400715-2	ppm				2014-01-21	369		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	278		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		ppm		2	1			0.2	0.1 - 0.3
Well # 11P	SP 1400715-4	ppm				2014-01-21	0.3		
Well #3P Hose Bibb	SP 1400715-1	ppm				2014-01-21	0.2		
Well #7 P	SP 1400715-2	ppm				2014-01-21	0.1		
Well 11P-2	SP 0811123-1	ppm				2008-10-08	0.3		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	0.3		
Gross Alpha		pCi/L		15	(0)			2.90	1.70 - 5.86
Well # 11P	SP 1406998-6	pCi/L				2014-06-18	2.18		
Well # 11P	SP 1403112-6	pCi/L				2014-03-18	4.83		
Well #3P Hose Bibb	SP 1403112-3	pCi/L				2014-03-18	1.94		
Well #7 P	SP 1410945-4	pCi/L				2014-09-23	1.70		
Well #7 P	SP 1406998-4	pCi/L				2014-06-18	2.59		
Well #7 P	SP 1403112-4	pCi/L				2014-03-18	2.88		
Well 11P-2	SP 0903056-6	pCi/L				2009-03-30	5.86		
Well 8P-2	SP 1410945-5	pCi/L				2014-09-23	1.92		
Well 8P-2	SP 1406998-5	pCi/L				2014-06-18	2.17		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500	n/a			31	22 - 45
Well # 11P	SP 1400715-4	ppm				2014-01-21	45		
Well #3P Hose Bibb	SP 1400715-1	ppm				2014-01-21	22		
Well #7 P	SP 1400715-2	ppm				2014-01-21	34		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	23		
Iron		ppb		300	n/a			15823	250 - 46800
Well # 11P	SP 1400715-4	ppb				2014-01-21	420		
Well #7 P	SP 1400715-2	ppb				2014-01-21	250		
Well 8P-2	SP 1400715-3	ppb				2014-01-21	46800		
Manganese		ppb		50	n/a			83	30 - 110
Well # 11P	SP 1400715-4	ppb				2014-01-21	70		
Well #7 P	SP 1400715-2	ppb				2014-01-21	30		
Well 11P-2	SP 0811123-1	ppb				2008-10-08	90		
Well 11P-2	SP 0811124-2	ppb				2008-10-08	100		
Well 11P-2	SP 0811124-3	ppb				2008-10-08	90		
Well 11P-2	SP 0811124-1	ppb				2008-10-07	110		
Well 8P-2	SP 1400715-3	ppb				2014-01-21	90		
Odor Threshold at 60 °C		TON		3	n/a			8	8 - 8
Well #7 P	SP 1400715-2	TON				2014-01-21	8		
Specific Conductance		umhos/cm		1600	n/a			934	633 - 1280
Well # 11P	SP 1400715-4	umhos/cm				2014-01-21	1280		
Well #3P Hose Bibb	SP 1400715-1	umhos/cm				2014-01-21	709		
Well #7 P	SP 1400715-2	umhos/cm				2014-01-21	1120		
Well 11P-2	SP 0811123-1	umhos/cm				2008-10-08	930		
Well 8P-2	SP 1400715-3	umhos/cm				2014-01-21	633		
Sulfate		ppm		500	n/a			224	109 - 370
Well # 11P	SP 1400715-4	ppm				2014-01-21	370		
Well #3P Hose Bibb	SP 1400715-1	ppm				2014-01-21	153		
Well #7 P	SP 1400715-2	ppm				2014-01-21	325		
Well 11P-2	SP 0811123-1	ppm				2008-10-08	165		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	109		
Total Dissolved Solids		ppm		1000	n/a			630	410 - 900
Well # 11P	SP 1400715-4	ppm				2014-01-21	900		
Well #3P Hose Bibb	SP 1400715-1	ppm				2014-01-21	490		
Well #7 P	SP 1400715-2	ppm				2014-01-21	760		
Well 11P-2	SP 0811123-1	ppm				2008-10-08	610		
Well 11P-2	SP 0810562-1	ppm				2008-09-26	610		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	410		

Turbidity		NTU		5	n/a			15.8	1.5 - 69.2
Well # 11P	SP 1400715-4	NTU				2014-01-21	2.9		
Well #3P Hose Bibb	SP 1400715-1	NTU				2014-01-21	3.1		
Well #7 P	SP 1400715-2	NTU				2014-01-21	2.3		
Well 11P-2	SP 0811123-1	NTU				2008-10-08	1.5		
Well 8P-2	SP 1400715-3	NTU				2014-01-21	69.2		
Zinc		ppm		5	n/a			0.62	0.21 - 1.03
Well #7 P	SP 1400715-2	ppm				2014-01-21	0.21		
Well 8P-2	SP 1400715-3	ppm				2014-01-21	1.03		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		ppm		NS	n/a			0.1	0.1 - 0.2
Well # 11P	SP 1400715-4	ppm				2014-01-21	0.1		
Well #7 P	SP 1400715-2	ppm				2014-01-21	0.2		
Well 11P-2	SP 0811123-1	ppm				2008-10-08	0.1		

ExxonMobil

CCR Login Linkage - 2015

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
LFC PbCu 03	SP 1506734-3	2015-06-13	Metals, Total	1st Floor Laundry	LFC - Lead & Copper
LFC PbCu 01	SP 1506734-1	2015-06-13	Metals, Total	1st Floor Mens Room	LFC - Lead & Copper
1st Floor Admin	SP 1500133-1	2015-01-06	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
	SP 1501591-1	2015-02-10	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
LFC-1st Floor A	SP 1502709-1	2015-03-10	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
	SP 1503719-1	2015-04-07	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
	SP 1504875-1	2015-05-05	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
	SP 1506353-1	2015-06-05	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
	SP 1507788-1	2015-07-14	Coliform	1stFloorAdmin.Bldg.-PrimaryTap	LFC Routine Bacteriological
LFC PbCu 02	SP 1506734-2	2015-06-13	Metals, Total	2nd Floor Mens Room	LFC - Lead & Copper
LFC PbCu 05	SP 1506734-5	2015-06-13	Metals, Total	2nd Floor Sink	LFC - Lead & Copper
BLD A KIT SINK	SP 1500132-1	2015-01-06	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1501590-1	2015-02-10	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
LFC-BLD A KIT S	SP 1502710-1	2015-03-10	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1503720-1	2015-04-07	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1504876-1	2015-05-05	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1506354-1	2015-06-05	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1507791-1	2015-07-14	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1509184-1	2015-08-18	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1510247-1	2015-09-15	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1511437-1	2015-10-13	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1512867-1	2015-11-17	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
	SP 1513403-1	2015-12-02	Coliform	Building A Kitchen Sink	LFC-Upper Peanut Complex Routine Bacteriological
Control Rm Brea	SP 1507995-1	2015-07-17	Coliform	Control Rm Break Room Sink	Coliform Resample at LFC Lunch Room
Control Rm. Bre	SP 1500134-1	2015-01-06	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
	SP 1501589-1	2015-02-10	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
POPCO-Control R	SP 1502703-1	2015-03-10	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
	SP 1503721-1	2015-04-07	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
	SP 1504877-1	2015-05-05	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
	SP 1506356-1	2015-06-05	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
	SP 1507790-1	2015-07-14	Coliform	ControlRmBreakrmSink-PrimTap	POPCO Routine Bacteriological
LFC-KITCHEN SIN	SP 1509186-1	2015-08-18	Coliform	Kitchen Sink	LFC Administration Bldg. Routine Bacteriological
	SP 1510246-1	2015-09-15	Coliform	Kitchen Sink	LFC Administration Bldg. Routine Bacteriological
	SP 1511438-1	2015-10-13	Coliform	Kitchen Sink	LFC Administration Bldg. Routine Bacteriological
	SP 1512864-1	2015-11-17	Coliform	Kitchen Sink	LFC Administration Bldg. Routine Bacteriological
	SP 1513402-1	2015-12-02	Coliform	Kitchen Sink	LFC Administration Bldg. Routine Bacteriological
Mens BR	SP 1507995-2	2015-07-17	Coliform	Mens BR	Coliform Resample at LFC Lunch Room
Mens Change Roo	SP 1508359-1	2015-07-28	Coliform	Mens Change Room	Popco Routine Bacteriological
LFC-Well 11P	SP 1305282-4	2013-05-28	Metals, Total	Well # 11P	Env Health Serv (EHS) Permit #0743 - Triennial
	SP 1400715-4	2014-01-21	Wet Chemistry	Well # 11P	LFC - Water Quality Monitoring
	SP 1400715-4	2014-01-21	General Mineral	Well # 11P	LFC - Water Quality Monitoring

	SP 1403112-6	2014-03-18	Radio Chemistry	Well # 11P	Radio Monitoring
	SP 1406998-6	2014-06-18	Radio Chemistry	Well # 11P	Radio Monitoring
LFC-Well 03P	SP 1305282-1	2013-05-28	Metals, Total	Well #3P Hose Bibb	Env Health Serv (EHS) Permit #0743 - Triennial
	SP 1400715-1	2014-01-21	General Mineral	Well #3P Hose Bibb	LFC - Water Quality Monitoring
	SP 1400715-1	2014-01-21	Wet Chemistry	Well #3P Hose Bibb	LFC - Water Quality Monitoring
	SP 1403112-3	2014-03-18	Radio Chemistry	Well #3P Hose Bibb	Radio Monitoring
LFC-Well 07P	SP 1305282-2	2013-05-28	Metals, Total	Well #7 P	Env Health Serv (EHS) Permit #0743 - Triennial
	SP 1400715-2	2014-01-21	Wet Chemistry	Well #7 P	LFC - Water Quality Monitoring
	SP 1400715-2	2014-01-21	General Mineral	Well #7 P	LFC - Water Quality Monitoring
	SP 1403112-4	2014-03-18	Radio Chemistry	Well #7 P	Radio Monitoring
	SP 1406998-4	2014-06-18	Radio Chemistry	Well #7 P	Radio Monitoring
	SP 1410945-4	2014-09-23	Radio Chemistry	Well #7 P	Radio Monitoring
	SP 1507995-4	2015-07-17	Coliform	Well #7 P	Coliform Resample at LFC Lunch Room
LFC-Well 11P-2	SP 0810562-1	2008-09-26	Wet Chemistry	Well 11P-2	Exxon Mobil Well 11P-2
	SP 0811124-1	2008-10-07	Metals, Total	Well 11P-2	Well 11P-2
	SP 0811123-1	2008-10-08	General Mineral	Well 11P-2	Well 11P-2
	SP 0811123-1	2008-10-08	Metals, Total	Well 11P-2	Well 11P-2
	SP 0811123-1	2008-10-08	Wet Chemistry	Well 11P-2	Well 11P-2
	SP 0811124-2	2008-10-08	Metals, Total	Well 11P-2	Well 11P-2
	SP 0811124-3	2008-10-08	Metals, Total	Well 11P-2	Well 11P-2
	SP 0903056-6	2009-03-30	Radio Chemistry	Well 11P-2	Radio Monitoring
LFC-Well 8P-2	SP 1006300-3	2010-06-29	Metals, Total	Well 8P-2	Env Health Serv (EHS) Permit #0743 - Triennial
	SP 1400715-3	2014-01-21	General Mineral	Well 8P-2	LFC - Water Quality Monitoring
	SP 1400715-3	2014-01-21	Wet Chemistry	Well 8P-2	LFC - Water Quality Monitoring
	SP 1406998-5	2014-06-18	Radio Chemistry	Well 8P-2	Radio Monitoring
	SP 1410945-5	2014-09-23	Radio Chemistry	Well 8P-2	Radio Monitoring
Womens BR	SP 1507995-3	2015-07-17	Coliform	Womens BR	Coliform Resample at LFC Lunch Room

Mechtold, Sylvia C

From: Asher, Phyllis A
Sent: Thursday, June 30, 2016 4:40 PM
To: Mechtold, Sylvia C; Jones, Jack E
Subject: FW: 7230 - LFC Transformer Transport and Disposal
Attachments: 7230 - LFC Transformer Transport and Disposal 30-Jun-16 11-58-39.xlsm

PO 5200005489 is in Jack's inbox for approval.

ue PO 5200005489 Created by Phyl

Print Preview
 Messages

 Personal :

5200005489	Vendor	2095622 CLEAN HARE
al	Short Text	Pl
	LFC Sherpa Transformer Transport/Dispose	

Phyllis A. Asher
CMMS Specialist
California Operations

ExxonMobil U.S. Production
12000 Calle Real
Goleta, CA 93117
805 961 4157 - Office
661 340 0140 - Cell
phyllis.a.asher@exxonmobil.com

This message and any attachments may contain proprietary or confidential information. If you are not the intended recipient or you received the message in error, you must not use or distribute the message. Please notify the sender immediately and destroy the original message.

From: Mechtold, Sylvia C
Sent: Thursday, June 30, 2016 11:59 AM
To: Asher, Phyllis A
Cc: Jones, Jack E
Subject: 7230 - LFC Transformer Transport and Disposal

Please process this requisition.

Additional Comments: Sherpa Fire AFE