

**2015 Water Quality Consumer Confidence Report
Del Oro Water Company – Traver District
Public Water System Number 5400553**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Water for Del Oro Water Co., Traver District is produced from Wells No. 1, 2 & 3. A Drinking Water Source Assessment, was performed in 2015 and determined that Wells No. 1 & 3 in this system are most vulnerable to Septic systems, Gas Stations, Fertilizers and Transportation Corridors. This information is being provided to you from DOWC. You will be notified with your billing of any public meetings concerning your drinking water. For additional information concerning your drinking water, or for a copy of the Drinking Water Source Assessment, contact Community Relations at P.O. Drawer 5172, Chico, CA 95927 1-530-717-2511.

TERMS USED IN THIS REPORT:

<p>Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p> <p>Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).</p> <p>Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p> <p>Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.</p> <p>Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLG's are set by the U.S. Environmental Protection Agency.</p> <p>Primary Drinking Water Standards (PDWS): MCLs or MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p> <p>Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.</p>	<p>Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.</p> <p>Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.</p> <p>Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.</p> <p>ND: Not detectable at testing limit</p> <p>pCi/L: Picocuries per liter (a measure of radiation)</p> <p>ppm: Parts per million or milligrams per liter (mg/L)</p> <p>ppb: Parts per billion or micrograms per liter (ug/L)</p> <p>ppt: Parts per trillion or nanograms per liter (ng/L)</p> <p>ppq: Parts per quadrillion, or picograms per liter</p> <p>MFL: Million fibers per liter</p> <p>NTU: Nephelometric Turbidity Units</p>
--	---

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally – occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agriculture livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA – 2015 Monthly

Microbiological Contaminants	Highest Number of Detections	Number months in violation	MCL	MCLG (MPN/mL)	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or E. Coli	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or E.Coli	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead & Copper	Sample Date	No. of samples collected	90 th percentile level detected	No. of sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	2014	10	<5	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppb)	2014	10	<0.05	0	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Highest Level Detected	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (mg/L)	Well No. 1 Well No. 2 Well No. 3	55 30 47	None	None	Generally found in ground and surface water
Hardness (mg/L)	Well No. 1 Well No. 2 Well No. 3	240 96 170	None	None	Generally found in ground and surface water

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level of Detection	MCL	Typical Source of Contaminant
Nitrate (mg/L) ^{(1) **} Well No. 1 Well No. 2 Well No. 3	2015	97 ND 8.5	45	Fertilizer, natural deposits, septic systems
Gross Alpha (pCi/L) Well No. 1 Well No. 2 Well No. 3	2015	42.4 ND 5.11	15	Erosion of natural deposits
Uranium (pCi/L) Well No. 2 Well No. 3	2014	4.4 7.0	20	Erosion of natural deposits
Iron (ug/L) Well No. 1 Well No. 2 Well No. 3	2013 2014 2013	ND ND ND	300	Naturally Occurring
Manganese (ug/L) Well No. 1 Well No. 2 Well No. 3	2013 2014 2013	ND ND ND	50	Leaching from natural deposits
Fluoride (mg/L) Well No. 1 Well No. 2 Well No. 3	2013	0.11 0.14 0.14	2	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemicals or Constituent (and reporting units)	Sample Date	Level Detected	MCL	Typical Source of Contaminant
Sulfate (mg/L) Well No. 1 Well No. 2 Well No. 3	2013	27.0 6.7 14.0	600	Runoff/leaching from natural deposits' industrial wastes
Turbidity (NTU) Well No. 1 Well No. 2 Well No. 3	2015 2014 2014	0.25 ND ND	5	Soil runoff
Odor Threshold (TON) Well No. 1 Well No. 2 Well No. 3	2015 2014 2014	ND ND ND	3	Naturally-Occurring organic material
Chloride (MG/l) Well No. 1 Well No. 2 Well No. 3	2013	95.0 41.0 60.0	600	Runoff/leaching from natural deposits; seawater influence
Color (units) Well No. 1 Well No. 2 Well No. 3	2015 2014 2014	ND ND ND	15	Naturally-occurring organic materials

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemicals or Constituent (and reporting units)	Sample Date	Range of Detection	NL	Health Effects Language
Trichloropropane (1,2,3 TCP) (ppb) ** Well No. 1 Well No. 2 Well No. 3	2015	ND – 0.016 ND ND	0.005	Some people who use water containing 1,2,3 TCP in excess of the notification level (0.005 ppb) over many years may have an increased risk of getting cancer, based on studies in laboratory animals. The PHG for 1,2,3 TCP is 0.0007 ppb.

If any violation of an MCL, MRDL, or TT has a footnote (¹) additional information regarding the violations will be provided later in this report.

⁽¹⁾ Nitrate in drinking water at levels above 45 ppm is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 ppm may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

** Levels of 1,2,3 TCP above the State's notification level and levels of Nitrate which are higher than the MCL required by SWRCB-DDW were found in Well No. 1, which has been taken off line and is currently not being used to supply drinking water to Del Oro Water Co., Traver District customers.

ADDITIONAL GENERAL INFORMATION ON DRINKING WATER:

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly individuals, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The USEPA/Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791. Infants and young children are typically more vulnerable to lead in drinking water than the general populations. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your homes plumbing.

Del Oro Water Company would like to inform our customers to the safety of lead and copper testing. While Del Oro Water Company does not use lead pipes in the distribution lines that serve our customers, older homes may have been built using lead pipes or lead connectors. For this reason ***Lead and Copper Tap Monitoring*** by Del Oro Water Company is conducted at designated customer's homes and is an important part of a water utilities monitoring schedule.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Del Oro Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available for the Safe Drinking water Hotline or at <http://www.epa.gov/safewater/lead> .

TR Mailing Completed By: May 11, 2016