2015 Consumer Confidence Report

RECEIVED
MAY 04 2016
BY:

Water System Name: PONDEROSA MOBILE HOME PARK Report Date: 1 APR 2016

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2015.

Type of water source in use: GROUND WATER SYSTEM 5500O92

Name & location of source: Wells No. 3 (Main) & 2 (Standby)

Drinking Water Source Assessment information:

Completed in June 2001, the source is considered most vulnerable to the following activities **not** associated with any detected contaminants in the water supply: Septic systems/high density. A copy of the complete assessment is available or you may request a summary by contacting Merced District SWRCB-Division of Drinking Water 559) 447 3300.

Time and place of regularly scheduled board meetings for public participation: N/A

For more information, contact: Don Nessl Phone: 532 1551

TERMS USED IN THIS REPORT	
Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water. **Maximum Contaminant Level Goal (MCLG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA). **Public Health Goal (PHG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency. **ND**: not detectable at testing limit **ppm**: parts per million or milligrams per liter (mg/L)	**Primary Drinking Water Standards (PDWS)**: MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements. **Secondary Drinking Water Standards (SDWS)**: MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels. **Regulatory Action Level (AL)**: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. **Variances and Exemptions**: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions. **ppb**: parts per billion or micrograms per liter (ug/L) **pCi/L**: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides* that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.

- *Radioactive contaminants* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (TESTED MONTHLY)	ND	O	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or *E. coli*	ND	O	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or *E. coli*	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper	No. of samples collected	90th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb) SEP 2015	5	ND	O	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) SEP 2015	5	ND	O	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	7 /2013	16	-	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	7 /2013	170	-	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

**Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.*

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL**	**PHG (MCL G)**	**Typical Source of Contaminant**
Nitrate @ NO_3 (ppm)	10/2015	3.9	-	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Hexavalent Chromium (CrVI) (ppb)	8/2014	ND	-	10	0.02	Erosion of natural deposits; wood preservation leather tanneries, chemical synthesis, refractory production, textile manufacturing facilities, and electroplating factories.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	**Sample Date**	**Level Detected**	**Range of Detections**	**MCL**	**PHG (MCLG)**	**Typical Source of Contaminant**
Turbidity (Units)	7 /2013	0.09	-	5	N/A	Soil run off
Total Dissolved Solids (ppm)	7 /2013	208	-	1000	N/A	Run off / Leaching from natural deposits
Specific Conductance (micromhos)	7 /2013	408	-	1600	N/A	Substances that form ions in water; Seawater influence
Chloride (ppm)	7 /2013	5	-	500	N/A	Run off / Leaching from natural deposits Seawater influence
Sulfate (ppm)	7 /2013	10	-	500	N/A	Run off / Leaching from natural deposits Industrial wastes

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead - If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Ponderosa Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at www.epa.gov/safewater/lead.