

2017 Consumer Confidence Report

Water System Name: Morning Star Packing Co

Report Date: 05/17/2018

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2016 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Groundwater from wells #1, #2, #4 and #5

Your water comes from 4 sources: Wells located at 13448 Volta Road, Los Banos, Ca. 93635

Drinking water source assessments were completed on April 2002 for wells #1, and #2,. There are no detectable contaminants, the wells are not vulnerable to activities located near the wells.

Opportunities for public participation in decisions that affect drinking water quality: The Morning Star Packing Co. CCR is provided to seasonal colleagues in their paychecks and/or annual orientation packets. Fulltime colleagues receive the Morning Star Packing Co CCR via email.

For more information about this report, or have any questions relating to your drinking water, please contact Tod Harter at 209-829-5002 or tharter@morningstarco.com

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water are from groundwater wells. As water flows through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3 and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one-year-old.

| TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA | | | | | |
|--|---------------------------|----------------------------|--|------|--------------------------------------|
| Microbiological Contaminants | Highest No. of Detections | No. of months in violation | MCL | MCLG | Typical Source of Bacteria |
| Total Coliform Bacteria | 0 | | 1 positive monthly sample | 0 | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> | 0 | | A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive | | Human and animal fecal waste |
| <i>E. coli</i> | 0 | | (a) | 0 | Human and animal fecal waste |
| (a) Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> . | | | | | |

| TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER | | | | | | | |
|---|-------------|--------------------------|--|------------------------|-----|-----|---|
| Lead and Copper | Sample Date | No. of samples collected | 90 th percentile level detected | No. sites exceeding AL | AL | PHG | Typical Source of Contaminant |
| Lead (ppb) | 2015 | 5 | .0015 | 0 | 15 | 0.2 | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits |
| Copper (ppm) | 2015 | 5 | .1415 | 0 | 1.3 | 0.3 | Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

| Chemical or Constituent (and reporting units) | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant |
|---|-------------|----------------|---------------------|------|------------|--|
| Sodium (ppm) | 12/16/14 | 49 | none | none | none | Salt present in the water and is generally naturally occurring |
| Hardness (ppm) | 12/14/14 | 179 | none | none | none | Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring |

Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – SAMPLING RESULTS SHOWING THE DETECTION REGULATED AND NON-REGULATED CHEMICALS

| | Units | MCL | DLR | #1 | #2 | #4 | #5 |
|-------------------------------------|----------|------|-----|------|-------|-------|-------|
| Calcium | mg/L | | | 32 | 49 | 45 | 51 |
| Magnesium | mg/L | | | 29 | 29 | 27 | 31 |
| Potassium | mg/L | | | 1.7 | 2.0 | 2.1 | 1.9 |
| Hardness Total as CaCO ₃ | mg/L | | | 179 | 224 | 224 | 255 |
| Hydroxide OH | mg/L | | | 0 | 0 | 0 | 0 |
| Carbonate | mg/L | | | 0 | 0 | 0 | 0 |
| Bicarbonate HCO ₃ | mg/L | | | 244 | 244 | 244 | 305 |
| Sulfate SO ₄ | mg/L | 500 | 0.5 | 42 | 63 | 68 | 78 |
| Chloride CL | mg/L | 500 | | 37 | 62 | 87 | 97 |
| Fluoride F | mg/L | 2 | 0.1 | 0.24 | 0.13 | 0.14 | 0.18 |
| pH | | | | 7.6 | 7.5 | 7.6 | 7.7 |
| Specific Conductance (E.C.) | umho/cm+ | 1600 | | 650 | 630 | 620 | 1000 |
| Total dissolved solids | mg/L | | | 283 | 440 | 483 | 568 |
| Apparent Color (Unfiltered) | Units | 15 | | 3 | 3 | 3 | 3 |
| Odor Threshold | TON | 3 | 1 | 1 | 1 | 1 | 1 |
| Lab Turbidity (NTU) | NTU | 5 | | 2.61 | 0.03 | 0.27 | 0.41 |
| MBAS | mg/L | 0.5 | | 0 | 0 | 0 | 0 |
| Aluminum Al | ug/L | 1000 | 50 | 0 | 0 | 0 | 0 |
| Antimony | ug/L | 6 | 6 | 0 | 0 | 0 | 0 |
| Arsenic As | ug/L | 10 | 2 | 4.2 | 2.7 | 3.4 | 0 |
| Barium Ba | ug/L | 1000 | 100 | 0 | 110 | 100 | 110 |
| Beryllium | ug/L | 4 | 1 | 0 | 0 | 0 | 0 |
| Cadmium Cd | ug/L | 5 | 1 | 0 | 0 | 0 | 0 |
| Hexavalent Cr6 * | ug/L | 50 | 1 | 30 | 34 | 35 | 17 |
| Copper Cu | ug/L | 1000 | 50 | 0 | 0 | 0 | 0 |
| Iron Fe | ug/L | 300 | 100 | 212 | 0 | 0 | 0 |
| Manganese Mn | ug/L | 50 | 20 | 24 | 29 | 0 | 0 |
| Mercury Hg | ug/L | 2 | 1 | 0 | 0 | 0 | 0 |
| Nickel | ug/L | 100 | 10 | 0 | 0 | 16 | 0 |
| Selenium Se | ug/L | 50 | 0 | 0 | 0 | 0 | 0 |
| Sodium | mg/L | | | 49 | 75 | 75 | 103 |
| Color | ug/L | 15 | 0 | 3 | 3 | 3 | 3 |
| Aggressiveness Index | | | | 11.8 | 11.89 | 11.95 | 12.2 |
| Boron | ug/L | 1000 | 100 | 455 | 536 | — | 607 |
| Nitrate + Nitrite as Nitrogen N | mg/L | 10 | 0.4 | 0.88 | 2.1 | 1.4 | 3.16 |
| Nitrite as Nitrogen N | mg/L | 45 | 2 | 3 | 0 | 0 | 0 |
| Vanadium | ug/L | 50 | 3 | 14 | 4 | — | 7.3 |
| Gross Alpha | PCI/L | 15 | 3 | 2.88 | 0.0 | 4.53 | 0.0 |
| Gross Alpha Counting Error | PCI/L | | | 1.7 | 0.246 | 0.365 | 0.269 |
| Gross Alpha MDA95 | PCI/L | 3 | | 1.12 | 1.06 | 1.06 | 1.06 |

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

| VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT | | | | |
|---|--|----------|--|---|
| Violation | Explanation | Duration | Actions Taken to Correct the Violation | Health Effects Language |
| Violation of Title 22, California Code of Regulations, Section 64432.1(a) and Section 64469(a) and Section(c), nitrate monitoring and reporting violation | The State Water Resources Control Board-Division of Drinking Water has issued Citation No. 03-11-18C-013, The water system utilized a noncertified drinking water testing laboratory to conduct testing for nitrate in Well #5 PS Code 014 | 04/2018 | MSPC to use a certified drinking water laboratory to conduct testing | You do not need to use an alternative water supply (e.g. bottled water). This is not an immediate risk. If it had been, you would have been notified immediately. |

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Morning Star Packing Co is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.