



CONTROL GORGE POWER PLANT

DRINKING WATER QUALITY REPORT 2018

This 2018 Water Quality Report for Control Gorge Power Plant system was prepared by the Los Angeles Department of Water and Power (LADWP). The report provides information about drinking water at Control Gorge Power Plant during the 2018 calendar year. The data are compared to the current State and Federal Standards. Only those constituents that were detected are listed. The report is required by the State Water Resources Control Board (State Board), and was prepared in accordance with State Board, Division of Drinking Water (DDW) guidelines.

SUMMARY

The water provided to the Control Gorge Power Plant system meets all state and federal drinking water requirements. Only the following substances with primary standards were detected at low levels in the water supplied to Control Gorge system: arsenic, chlorine, fluoride, and uranium. The levels of these substances were below the established maximum contaminant levels (MCLs), which are the health protective standards set by the United States Environmental Protection Agency (USEPA) and the DDW. DDW allows us to monitor for a number of contaminants less than once per year, because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

The data for lead and copper on this table are the results of residential tap monitoring conducted in 2018 as required by the Lead and Copper Rule (LCR). For more information on these contaminants, please refer to the Table 1 "Primary Drinking Water Constituents Found in the Water."

**Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.**

WHERE DOES THE WATER COME FROM?

The term “source water” describes where LADWP obtains the water you drink. All drinking water, tap or bottled, comes from either surface water or groundwater sources. Surface water sources include rivers, lakes, streams, ponds, or reservoirs. Groundwater sources are springs or wells.

Control Gorge Power Plant receives natural spring water. The domestic water supply comes exclusively from Bircham Canyon Spring, an artesian well located along Bircham Canyon Road near the plant. It is disinfected with chlorine to ensure bacterial quality of the water. It is also treated by filtration to decrease turbidity and remove arsenic and other constituents.

WHY IS DRINKING WATER MONITORED AND TREATED?

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling EPA’s Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, the USEPA and the DDW prescribe regulations that limit the amount of certain contaminants in water provided by public water system. DDW regulations also establish limits for contaminants in bottled water that must provide the same protection for public health. Contaminants that may be present in source waters include:

- Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants such as salts and metals, which are naturally-occurring, or come from urban water run-off including industrial or domestic wastewater discharges, oil and gas production, and mining or farming.
- Pesticides and herbicides which may come from a variety of sources such as agriculture, urban water run-off, and residential uses.
- Organic chemicals including synthetic and volatile organics, which are by-products of industrial processes and petroleum production. These can also come from gas stations, urban water run-off, and septic systems.

- Radioactive contaminants which can be naturally occurring, or be generated by oil and gas production and mining activities.

SPECIAL NOTICE TO IMMUNO-COMPROMISED CONSUMERS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800 426-4791).

TERMS USED IN THIS REPORT

AL (Action Level) - Federal: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements a water system must follow.

DLR (Detection Limit for Reporting Purposes): The DLR is the lowest level at which all State-certified laboratories can accurately and reliably detect a compound. The DLR provides a standardized basis for reporting purposes.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the PHGs and MCLGs (see below) as economically or technologically feasible. For certain contaminants, compliance with the MCL is based on the average of all samples taken throughout the year.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

MRDL (Maximum Residual Disinfectant Level): The level of a disinfectant added for water treatment that may not be exceeded at the consumer’s tap.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLs are set by the U.S. Environmental Protection Agency.

NL (Notification Levels) - State: Health-based advisory levels established by DDW for chemicals in drinking water that lack maximum contaminant levels (MCLs). When chemicals are found at concentrations greater than their notification levels, certain requirements and recommendations apply.

PHG (Public Health Goal) - State: The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Primary Drinking Water Standard or PDWS: MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards: These standards are based on aesthetic qualities such as taste, odor, and appearance, which affect customer acceptance. They are not considered a health risk if exceeded.

TT (Treatment Technique): Required treatment process which will reduce the level of a contaminant in drinking water. For example, the filtration process is a treatment technique used to reduce turbidity (the cloudiness of water) and microbial contaminants from water. High turbidity may indicate poor or inadequate filtration.

MONITORING OF REGULATED CONSTITUENTS

There are over 110 regulated constituents (or contaminants). Utilities monitor for each constituent at varying frequencies based on the type of constituent and the type of source water. For example, groundwater sources are generally sampled once every three years. Those constituents that pose acute risk require more frequent monitoring. Nitrate sampling is required annually, and bacteriological sampling is required monthly. Since most constituents are not detected in our water, only those constituents that are detected are listed in the tables.

Arsenic

The current EPA standard for arsenic in drinking water is 10 ppb. The California Office of Environmental Health Hazard Assessment adopted a Public Health Goal of 0.004 ppb in April 2004. In November 2008, DDW adopted the EPA arsenic standard as the new State drinking water standard for arsenic. Arsenic compliance is based on a running

annual average. In 2018, the average amount of arsenic was 4.1 ppb.

Lead in Drinking Water

Lead and Copper Rule (LCR) sampling was conducted in April 2018 and in September and October 2018. Initial monitoring requirements were imposed as the Action Level (AL) was exceeded in consecutive sampling events.

A survey of the distribution system was initiated with an inventory of the service lines within the residential community. Lead and copper sampling of the source and finished water, prior to its entry into the distribution system, have been done to investigate the source of elevated lead levels at the tap.

Employee-residents and their families were notified of the elevated lead levels in several communications, including details on how to reduce exposure to lead, and have been urged to allow water to run for at least 30 seconds prior to using water for cooking or drinking purposes. Additional actions are planned to minimize lead exposure.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels may be higher at one home than at other homes in the community as a result of materials used in each home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and/or flush your tap for 30 seconds to 2 minutes before consuming water. More information is available from the EPA Safe Drinking Water Hotline at 800-426-4791, or at <https://www.epa.gov/lead>.

Turbidity

Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites such as *Cryptosporidium* and *Giardia* that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Unregulated Constituents

There are constituents found in drinking water that are not yet regulated. These "unregulated constituents" are monitored because they could be candidates for future regulations or are of interest to our consumers.

CONTROL GORGE POWER PLANT – 2018 CALENDAR YEAR

TABLE 1 – Health-Based Primary Drinking Water Contaminants Detected

Constituents/ Contaminants	Units	Control Gorge Water Quality		State Primary Standard (MCL) or [MRDL]	MEET PRIMARY STANDARD?	State PHG or Federal [MRDLG] or (MCLG)	Major Source in Drinking Water
		Range	Average				
Arsenic	µg/L	1.4-15.5	4.1	10	YES	0.004	Natural hot springs; erosion of natural deposits
Chlorine Residual	mg/L	2.0 – 3.7	2.64	[4]	YES	[4]	Disinfectant
Copper (at-the-tap)^a <i>April 2018</i>	µg/L	Number of samples exceeding AL = 0 in 5	90 th Percentile value = 128	AL=1300	YES	300	Internal corrosion of household water plumbing systems
Copper (at-the-tap)^a <i>September and October 2018</i>	µg/L	Number of samples exceeding AL = 0 in 5	90 th Percentile value = 86	AL=1300	YES	300	Internal corrosion of household water plumbing systems
Lead (at-the-tap)^a <i>April 2018</i>	µg/L	Number of samples exceeding AL = 2 in 5	90 th Percentile value = 21	AL=15	NO	0.2	Internal corrosion of household water plumbing systems
Lead (at-the-tap)^a <i>September and October 2018</i>	µg/L	Number of samples exceeding AL = 0 in 5	90 th Percentile value = 7.2	AL=15	YES	0.2	Internal corrosion of household water plumbing systems
Turbidity^b	NTU	99%	0.12	TT	YES	TT	Soil runoff
Uranium^c	pCi/L	5.6	5.6	20	YES	0.43	Erosion of natural deposits

TABLE 2 - Aesthetic-Based Secondary Drinking Water Contaminants Detected^d

Constituents/ Contaminants	Units	Control Gorge Water Quality		Secondary MCL	MEETS SECONDARY STANDARD?	Major Source in Drinking Water
		Range	Average			
Chloride	mg/L	30	30	500	YES	Runoff/leaching from natural deposits; seawater influence
Color	Units	4.0	4.0	15	YES	Naturally-occurring organic materials
Odor	Units	1.0-4.0	2.3	3	YES	Naturally-occurring organic materials
pH	Units	6.9 – 7.65	7.4	6.5 - 8.5	YES	Natural constituents
Specific Conductance	µS/cm	346 – 390	368	1600	YES	Natural constituents
Total Dissolved Solids (TDS)	mg/L	240	240	1000	YES	Runoff/leaching from natural deposits
Turbidity	NTU	0.06 – 0.45	0.12	5	YES	Soil runoff

CONTROL GORGE POWER PLANT – 2018 CALENDAR YEAR
TABLE 3 - Unregulated Drinking Water Constituents Detected^e

Constituents/Contaminants	Units	Control Gorge Water Quality	Major Source in Drinking Water
Alkalinity, Bicarbonate	mg/L	129	Natural constituent
Boron NL = 1000	µg/L	844	Erosion of natural deposit
Calcium	mg/L	19.5	Natural constituent
Magnesium	mg/L	4.0	Natural constituent
Potassium	mg/L	3.8	Natural constituent
Silica	mg/L	59	Erosion of natural deposit
Sodium	mg/L	50	Natural constituent

Footnotes for Tables

- a. Semi-annual samples for lead and copper were taken in April 2018 and again in September to October 2018. Initial monitoring was triggered since the 90th percentile concentration for lead exceeded the action level (AL) of 15 ppb in samples collected in the fall of 2017 and spring 2018. The 90th percentile value for lead was below the AL for samples taken in the fall of 2018. The next round of sampling is scheduled for the spring of 2019; if the 90th percentile value does not exceed the AL at that time, standard (annual) monitoring will be conducted in April 2020.
- b. Turbidity is a measure of the cloudiness of the water. For 2018, turbidity was recorded every 15 minutes at the effluent of the filtration plant. We monitor it because turbidity is a good indicator of the effectiveness of our filtration system. We report the highest single measurement and the lowest monthly percentage of samples meeting the requirements specified for this technology.
- c. Radioactivity was last analyzed in 2014. Groundwater is required to be tested once every six years for radiological constituents.
- d. Secondary standards and unregulated constituents were last taken in 2013 and are scheduled for sampling in 2022.

Abbreviations for Tables

mg/L = milligrams per Liter (equivalent to parts per million)

NTU = Nephelometric Turbidity Units; Turbidity is a measure of the cloudiness of the water. It is a good indicator of water quality. High turbidity can hinder the effectiveness of disinfectants.

pCi/L = picocuries per Liter (a unit of radioactivity)

µg/L = micrograms per Liter (equivalent to parts per billion)

µS/cm = micro Siemens per centimeter

TT = Treatment Technique

For more information regarding this report, please call Mr. Michael Mercado of the
 Water Quality Division at (213) 367-0395