

California Department of Public Health Product WorkSheet

Manufacturing Company Information
 Pentair Residential Filtration, LLC
 5730 N. Glen Park Road
 Milwaukee, Wisconsin 53209
 Phone: (262)-238-4400
 Website: www.pentairaqua.com

Product Brand: Everpure
 Product Model: S-54
 CDPH registration # 12-2103
 Replacement Cartridge S-54

Operating Parameters	SI Units	Metric Units
Service Flow Rate	0.5 gpm	1.9 lpm
System Capacity	750 gallons	(2839 L)
Pressure	10-125 psi	0.7 - 8.7 Kg/cm ²
Temperature	35-100°F	1.6–37.8°C

Everpure S-54 Performance Data Sheet

Contaminat Reduction Claims	Challenge Concentration	Maximum Permissible Product Water Concentration	Reduction Requirements	Reduction Average
Cyst	Minimum 50,000/mL		≥ 99.95%	99.99%
Lead (pH 6.5)	0.15 mg/L ± 10%	0.010 mg/L		99.30%
Lead (pH 8.5)	0.15 mg/L ± 10%	0.010 mg/L		99.20%

Note: The manufacturer is required to re-test the product every 5 years for material safety, structural integrity and all performance claims made. Any change to the product must be submitted to the certification agency for a technical review. Testing may be required sooner based on the technical review.

WARNING: Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Note: The system must be installed and maintained according to manufacturer's recommendations, including replacement of filter cartridges. The contaminants or other substances removed or reduced by this system are not necessarily in your water. Please see Product Installation manual for details.