



# Marine Corps Base Camp Pendleton

## ~ 2014 Consumer Confidence Report ~

This report provides information on the quality of the water provided to residents and personnel who lived and worked aboard Camp Pendleton during 2014. Included are details about where the water comes from, what it contains, and how it compares to established drinking water standards.

*Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.*

### Drinking Water Sources

Unlike most of southern California, which relies on imported water supplies, nearly all of Camp Pendleton's drinking water comes from local groundwater sources. Wells located on Base supply water to all portions of Camp Pendleton except for San Mateo Point Housing, which receives water from the South Coast Water District. Residents of San Mateo Point Housing should receive a consumer confidence report from this off-Base water purveyor.

### North Water System

- Service Area: all areas north of Las Pulgas Road except the 43 Area and San Mateo Point housing.
- Water Source: groundwater from wells located in the San Onofre and San Mateo River basins.

### South Water System

- Service Area: the 43 Area (Las Pulgas) and all areas south of Las Pulgas Road.
- Water Source: groundwater from wells located in the Las Pulgas and Santa Margarita River basins.

### Water Service Areas

As depicted below, Camp Pendleton provides water to the Base through one of the following two drinking water systems:



### Water Quality Monitoring

Camp Pendleton routinely tests the water to ensure that it meets safe drinking water standards. In addition to monitoring for contaminants with established drinking water standards, the Base also monitors for unregulated contaminants, which helps the U.S. Environmental Protection Agency (USEPA) and the California State Water Resources Control Board (SWRCB) determine where certain contaminants occur and whether such contaminants require regulation.

Last year Camp Pendleton performed over 20,000 water quality tests to evaluate compliance for over 200 different drinking water contaminants. While most contaminants registered below detectable levels, some occasionally did not achieve a drinking water standard. The table provided in the center of this report depicts these contaminants and others that require reporting. Note that the table contains separate columns to distinguish between the water quality measured in the North and South systems.

## 2014 CONSUMER CONFIDENCE REPORT

ENVIRONMENTAL SECURITY  
P.O. BOX 555008  
CAMP PENDLETON, CA 92055-5008

## Drinking Water Considerations

Drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

## Lead in Drinking Water

Sampling of residential taps during 2014 achieved standards for lead in drinking water; regardless, federal regulations require water systems to communicate the following health advisory concerning lead in drinking water:

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Camp Pendleton is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can*

*take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.*

## General Information about Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides* that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the SWRCB prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. These regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

## Consumer Notifications

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During April 2014 and October 2014, we did not complete all monitoring for total coliform bacteria in the South System. The following notifications apply to residents served by this system:

During April 2014, Camp Pendleton did not achieve the monitoring requirements of the USEPA Total Coliform Rule. Specifically, Camp Pendleton analyzed and reported only 49 of 50 required bacteriological samples. Mandatory public notification to the affected area occurred 12 June 2014.

During October 2014, Camp Pendleton did not achieve the monitoring and reporting requirements of the USEPA Federal Groundwater Rule. Specifically, Camp Pendleton collected only four of

eight required water quality samples from four drinking water wells within 24 hours of detecting total coliform bacteria in the water distribution system. Although subsequent bacteriological analyses performed at these wells achieved drinking water standards, State and Federal regulations require us to notify you within one year of this non-compliant monitoring and reporting event. This notice achieves this mandatory notification requirement.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

For more information, please contact the Water Resources Division at 760-725-3567, P.O. Box 555009, MCB Camp Pendleton, CA 92055.

## Terms Used in This Report

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Detection Level for Purposes of Reporting (DLR): The level above which a drinking water system must report contaminant detections to regulatory agencies.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. A Secondary MCL (SMCL) is a standard set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Notification Levels (NL): Health-based advisory levels established by the California Department of Public Health for chemicals in drinking water that lack MCLs. When chemicals are found at concentrations greater than their notification levels, certain regulatory requirements and recommendations apply.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

# 2014 Water Quality Monitoring Results

DISTRIBUTION SYSTEM MONITORING									
PARAMETER	Units	MCL {SMCL} [MRDL] <NL>	PHG {MCLG} [MRDLG]	DLR	NORTH SYSTEM		SOUTH SYSTEM		Typical Source
					Average {Detects}	Range {Violations}	Average {Detects}	Range {Violations}	
<b>Detection of Contaminants with a Primary Drinking Water Standard</b>									
Arsenic	ppb	10	0.004	2	ND	ND - 2.8	ND	ND - 4.1	Erosion of natural deposits
Fluoride (Natural-Source)	ppm	2	1	0.1	0.29	0.25 - 0.37	0.36	0.11 - 0.50	Erosion of natural deposits
Nitrate as NO <sub>3</sub>	ppm	45	45	2	3.8	2.1 - 5.5	ND	ND - 2.8	Runoff and fertilizer use; erosion of natural deposits
Total Coliform Bacteria	(a)	(b)	{0}	N/A	{1}	{0}	<b>{6.1%}</b> (c)	{2}	Naturally present in the environment
Haloacetic Acids	ppb	60	N/A	N/A	3.5	ND - 6.1	6.5	ND - 12	By-product of drinking water disinfection
Total Trihalomethanes	ppb	80	N/A	N/A	14	7.2 - 23	55.8	27 - <b>95</b> (d)	By-product of drinking water disinfection
Total Chlorine Residual	ppm	[4]	[4]	N/A	1.2	0.44 - 2.1	1.6	0.14 - 3.0	Drinking water disinfectant added for treatment
Gross Alpha	pCi/L	15	{0}	3	ND	ND - 4.8	ND	ND - 3.9	Erosion of natural deposits
Thallium	ppb	2	0.1	1	0.12	ND - 1.4	ND	ND	Leaching from natural deposits; industrial waste
Uranium	pCi/L	20	0.43	1	1.2	0.94 - 1.6	N/A	N/A	Erosion of natural deposits
<b>Detection of Contaminants with a Secondary Drinking Water Standard</b>									
Odor	units	{3}	N/A	1	2.2	ND - <b>8.0</b> (e)	1.6	ND - 3.0	Naturally-occurring organic materials
Sulfate	ppm	{500}	N/A	0.5	90	62 - 150	131	65 - 220	Runoff/leaching from natural deposits; industrial waste
Turbidity	units	{5}	N/A	0.1	ND	ND - 0.20	ND	ND - 0.18	Soil runoff
<b>Sodium and Hardness</b>									
Sodium	ppm	N/A	N/A	N/A	67	61 - 150	114	56 - 150	Leaching from natural deposits
Total Hardness	ppm	N/A	N/A	N/A	232	200 - 310	316	110 - 410	Naturally occurring minerals
<b>Unregulated Contaminant Monitoring (f)</b>									
Chlorate	ppb	<800>	N/A	N/A	185	120 - 220	320	97 - 560	Agricultural defoliant; disinfection by-product
Molybdenum	ppb	N/A	N/A	N/A	3.3	3.1 - 3.8	4.4	1.7 - 7.6	Naturally present in the environment
Perfluorohexanesulfonic Acid	ppb	N/A	N/A	N/A	ND	ND	0.02	ND - 0.06	Industrial use chemical
Perfluorooctanoic Acid	ppb	N/A	N/A	N/A	ND	ND	ND	ND - 0.02	Naturally present in the environment
Strontium	ppb	N/A	N/A	N/A	323	270 - 450	365	130 - 590	Naturally present in the environment
Vanadium	ppb	<50>	N/A	N/A	2.7	2.4 - 3	3	0.24 - 7.4	Naturally present in the environment

This table depicts contaminants that did not achieve a drinking water standard along with other contaminants that also require reporting. The table contains separate columns to distinguish between drinking water served in Camp Pendleton's North System and South System. Contaminant detections over a regulatory standard are depicted in bold.

**Footnotes:**

- (a) Highest number or percentage of positive samples collected in any one month.
- (b) The MCL for total coliform bacteria varies by water system size. The North System complies when no more than one monthly sample tests positive. The South System complies when no more than 5% of monthly samples test positive.
- (c) During October 2014, 5.8% of South System samples tested positive. During November 2014, 6.1% of South System samples tested positive. Mandatory notifications for these events occurred 3 November and 29 December, respectively.
- (d) Compliance is based on the running annual average of all samples collected. Overall, the South System was in compliance for 2014.
- (e) One out of 12 samples collected exceeded the MCL for odor in the North System. All resample test results were in compliance.
- (f) Testing for unregulated contaminants is performed to comply with USEPA's Unregulated Contaminant Monitoring Rule (UCMR 3) assessment protocol. Each system requires two sampling events. South System UCMR 3 samples were collected during 2013 and 2014. North System UCMR 3 first round samples were collected in 2014; second round samples will be collected in 2015.
- (g) Compliance is based on the 90th percentile of all samples collected, which must be less than the regulatory Action Level (AL). The system is out of compliance when more than 10% of samples collected exceed the AL.

**Abbreviations:**

- AL = Action Level
- DLR = Detection Level for Purposes of Reporting
- MCL = Maximum Contaminant Level
- MCLG = Maximum Contaminant Level Goal
- MRDL = Maximum Residual Disinfection Level
- MRDLG = Maximum Residual Disinfection Level Goal
- N/A = Not applicable
- ND = Non-detect
- NL = Notification Level
- pCi/L = picoCuries per liter. A measure of radioactivity
- PHG = Public Health Goal
- ppm = parts per million or milligrams per liter (mg/L)
- ppb = parts per billion or micrograms per liter (µg/L)
- SMCL = Secondary Maximum Contaminant Level
- USEPA = U.S. Environmental Protection Agency

TAP WATER MONITORING									
PARAMETER	Units	AL	PHG	DLR	NORTH SYSTEM		SOUTH SYSTEM		Typical Source
					90 <sup>th</sup> percentile	# of samples over AL	90 <sup>th</sup> percentile	# of samples over AL	
<b>Lead and Copper (g)</b>									
Copper	ppm	1.3	0.3	0.05	0.668	0 of 30	0.125	0 of 30	Internal corrosion of household plumbing systems
Lead	ppb	15	0.2	5	ND	0 of 30	ND	0 of 30	Internal corrosion of household plumbing systems

### A Note on Fluoride

Camp Pendleton currently does not add fluoride to the drinking water; however, the presence of naturally-occurring fluoride in our source water may help to prevent tooth decay. General information on the oral health benefits of fluoride in drinking water is available at the following web links:

SWRCB, Division of Drinking Water (DDW) [http://www.waterboards.ca.gov/drinking\\_water/certification/drinkingwater/Fluoridation.shtml](http://www.waterboards.ca.gov/drinking_water/certification/drinkingwater/Fluoridation.shtml).

Department of Health and Human Services, Center for Disease Control and Prevention (CDC) <http://www.cdc.gov/fluoridation/index.htm>.

### Source Water Assessment

The California Department of Public Health conducted an assessment of the Base's drinking water sources during July 2002. The assessment evaluated whether Camp Pendleton's groundwater supplies are vulnerable to contamination from activities that occur, or have occurred, on Base. The assessment determined that wells in both water systems are most vulnerable to contamination commonly associated with military installations; chemical or petroleum processing or storage; historic and operational waste dumps and landfills; and airport maintenance and fueling areas.

You may request a summary of this assessment by contacting Environmental Security at 760-725-9741. The complete assessment is also available for viewing at Environmental Security, Building 22165.

### Source Water Protection

Because Camp Pendleton's groundwater resources are located near the areas where we live and work, our activities have the potential to introduce contaminants to our drinking water supplies. Water runoff from storm and non-stormwater related events can pickup and deposit contaminants into the rivers and streams that recharge our aquifers. Surface water contamination can also harm aquatic life and pollute our beaches.

Below are some simple ways you can help us to reduce water pollution, safeguard our drinking water resources and protect the environment:

- Check your car for leaks.
- Wash your car on the grass or take your car to a carwash instead of washing it in the driveway.
- Pick up after your pet.
- Use fertilizers and herbicides sparingly.
- Sweep driveways and sidewalks instead of using a hose.
- Dispose of chemicals properly; never dispose of waste, trash or any materials down storm drains.

For more information on stormwater, or to report illegal discharges into the storm drain system, call Environmental Security at 760-763-7880.

### Disposal of Household Hazardous Waste

Another way to help protect our source water is to properly dispose of household hazardous waste. These are products that contain corrosive, toxic, ignitable, or reactive ingredients, such as paints, cleaners, oils, batteries, and pesticides. The Housing District Offices provide a free program for disposal of household hazardous waste. This program provides Base residents with a convenient, safe, and environmentally-friendly way to dispose of household hazardous waste.

Never discard unwanted hazardous waste into the trash, as this may injure sanitation workers and contaminate the environment. Similarly, never pour household hazardous waste liquids down your drains, as this also provides an easy pathway for hazardous waste to enter the environment. If you have questions or need information on household hazardous waste drop-off points, call the managers of the following Housing District Offices at:

<i>Del Mar</i>	760-430-0040
<i>Mountain</i>	760-430-8476
<i>San Onofre</i>	949-940-9178
<i>Stuart Mesa</i>	760-430-0694
<i>DeLuz</i>	760-385-4835
<i>Mesa</i>	760-385-5318

### Bottle vs. Tap

Many people prefer bottled water to tap water for taste and perceived health considerations.



Both bottled water and tap water must meet strict regulatory standards. Varying factors, such as residence time in the water distribution system, natural mineral content and residual chlorine from the water disinfection process can impart an unpleasant taste to tap water. Flushing water from the tap for a couple of seconds, allowing it to air for a period of time and/or chilling it prior to consumption may help to improve the taste of tap water.

Tap water is not only one of the best bargains Camp Pendleton consumers can find, but it also alleviates the cost and environmental burden associated with the manufacture, transport, and recycling or disposal of plastic water bottles. Go ahead and give our drinking water a try.

### Water Conservation

Camp Pendleton relies on finite groundwater resources to provide water service to the Base. Our groundwater resources are vulnerable to wasteful water-use activities.



In order to help conserve our groundwater supplies, we ask that you consider your water consumption, and use only the water that you need.

Some simple water conservation measures you can implement include:

- Report leaking or broken faucets, toilets and irrigation systems.
- Wash full loads of laundry and dishes.
- Do not leave water running unattended.
- Sweep driveways and sidewalks instead of hosing them off.
- Use a spray nozzle that allows you to adjust or stop flow.
- Take short, five-minute showers.
- Run water only when using it, not while brushing teeth, shaving or washing counters.

For more information about water conservation, visit [www.epa.gov/watersense](http://www.epa.gov/watersense)

### Questions?

For questions or additional information regarding this report, contact Environmental Security at 760-725-9741.



### Additional Sources of Water Quality Information

California State Water Resources Control Board: [http://www.waterboards.ca.gov/drinking\\_water/programs/index.shtml](http://www.waterboards.ca.gov/drinking_water/programs/index.shtml)  
California Office of Environmental Health Hazard Assessment: [www.oehha.ca.gov/water.html](http://www.oehha.ca.gov/water.html)  
U.S. Environmental Protection Agency (USEPA): <http://water.epa.gov/drink>  
USEPA Safe Drinking Water Hotline: 1-800-426-4791